



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA C200-17
(Revision of ANSI/AWWA C200-12)

AWWA Standard

Steel Water Pipe, 6 In. (150 mm) and Larger

Effective date: August 1, 2017.

First edition approved by AWWA Board of Directors June 26, 1975.

This edition approved Jan. 14, 2017

Approved by American National Standards Institute Feb. 23, 2017.




AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the Official Notice section of *Journal – American Water Works Association*. The action becomes effective on the first day of the month following the month of *Journal – American Water Works Association* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval mark on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; 212.642.4900; or emailing info@ansi.org



ISBN-13, print: 978-1-58321-906-5

eISBN-13, electronic: 978-1-61300-201-8

DOI: <http://dx.doi.org/10.12999/AWWA.C200.17>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including photocopy, recording, or any information or retrieval system, except in the form of brief excerpts or quotations for review purposes, without the written permission of the publisher.

Copyright © 2017 by American Water Works Association
Printed in USA

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword			
I	Introduction.....	ix	
I.A	Background.....	ix	
I.B	History.....	ix	
I.C	Acceptance.....	x	
II	Special Issues.....	xi	
II.A	Advisory Information on Product Application.....	xi	
II.B	Chlorine and Chloramine Degradation of Elastomers	xii	
III	Use of This Standard.....	xiii	
III.A	Purchaser Options and Alternatives	xiii	
III.B	Modification to Standard.....	xiv	
IV	Major Revisions.....	xiv	
V	Comments	xiv	
Standard			
1 General			
1.1	Scope	1	
1.2	Purpose.....	1	
1.3	Application.....	1	
2 References 2			
3 Definitions 4			
4 Requirements			
4.1	Permeation	7	
4.2	Materials	8	
4.3	Drawings.....	8	
4.4	Calculations	8	
4.5	Selection of Materials	9	
4.6	Requirements for Welding Qualification	11	
4.7	Fabrication of Pipe	11	
4.8	Production Weld Test	15	
4.9	Permissible Variations in Dimensions	19	
4.10	Ancillary Pipe	19	
4.11	Preparation of Ends.....	20	
4.12	Protective Coatings and Linings.....	24	
4.13	Special Sections	25	
4.14	Fabrication of Special Sections	25	
5 Verification			
5.1	Inspection	25	
5.2	Test Procedures	26	
5.3	Calibration of Equipment.....	28	
5.4	Test Reports	29	
6 Delivery			
6.1	Marking.....	29	
6.2	Handling and Loading.....	29	
6.3	Affidavit of Compliance	29	
Figures			
1	Charpy Test Evaluation	10	
2	Repair Method by Offset Value and Wall Thickness	12	
3	Bridge Cam Gauge.....	13	

SEC.		PAGE	SEC.		PAGE
4	Reduced-Section Tension Test		Tables		
	Specimen.....	15	1	Steel Plate, Sheet, or Coils for Fabricated Pipe.....	9
5	Guided-Bend Test Specimen	16	2	Repair Requirements Based On Offset Value and Wall Thickness	13
6	Jig for Guided-Bend Test.....	16	3	Guided-Bend Test Jig Dimensions	17
7	Alternative Guided-Bend Wraparound Jig.....	17			
8	Alternative Guided-Bend Roller Jig	18			



American Water Works Association

Dedicated to the World's Most Important Resource®

ANSI/AWWA C200-17
(Revision of ANSI/AWWA C200-12)

AWWA Standard

Steel Water Pipe, 6 In. (150 mm) and Larger

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes electrically butt-joint-welded straight-seam or spiral-seam pipe and seamless pipe, 6 in. (150 mm)* in nominal diameter and larger, for the transmission and distribution of water or for use in other water system facilities.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for steel water pipe, 6 in. (150 mm) and larger, including materials and quality of work, fabrication, and testing of pipe and special sections.

Sec. 1.3 Application

This standard can be referenced in the purchaser's documents for steel water pipe, 6 in. (150 mm) and larger. The stipulations of this standard apply when this document has been referenced and then only to steel water pipe, 6 in. (150 mm) and larger.

* Metric conversions given in this standard are direct conversions of US customary units and are not those specified in the International Organization for Standardization (ISO) standards.