

ANSI/AWWA **C561-21**
(Revision of ANSI/AWWA C561-14)

AWWA Standard

Fabricated Stainless-Steel Slide Gates

Effective date: Jan. 1, 2022.

First edition approved by Board of Directors Jan. 18, 2004.

1st edition approved Jan. 25, 2021.

Approved by American National Standards Institute July 1, 2021.



American Water Works
Association



AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags and labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.



ISBN-13, print: 978-1-64717-000-9

ISBN-13, electronic: 978-1-61300-599-6

DOI: 10.12999/AWWA.C561.21

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher. Please send any requests or questions to permissions@awwa.org.

Copyright © 2021 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Slide Gates, which reviewed and approved this standard, had the following personnel at the time of approval:

Kirk H. Hipps, *Chair*

General Interest Members

S. Barraco, Jones and Carter Inc., Dallas, Tex.

M.D. Bennett, Stantec, Cleveland, Ohio

L.C. Gerbig, Lee C. Gerbig LLC, Avon, Ind.

J.W. Green (*liaison, nonvoting*), Standards Council Liaison, Lockwood Andrews & Newnam, Oakbrook Terrace, Ill.

K.H. Hipps, Black & Veatch, West Hartford, Conn.

J.E. Koch, HDR Engineering Inc., Burlington, Wash.

E. Meek (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.

C. Reames, CB&I, Inc., Baton Rouge, La.

R.M. Scott, Pelham, Mass.

Z.R. Yu, Jacobs, Kitchener, Ont.

Producer Members

J. Baker, Hydro Gate, Denver, Colo.

P.E. Brunelle, Rodney Hunt Inc., Orange, Mass.

M. Larrea, Orbinox Valves International, Donostia-San Sebastian, Spain

J.R. Nelson, Golden Harvest Inc., Tulare, Calif.

R. Niedzwiecki, Whinper, Inc., Athol, Mass.

H. Reed, Plasti-Fab, Ridgefield, Wash.

User Members

R.J. Alberts, City of Pasco, Pasco, Wash.

B. Hasa-abadi, Colorado Springs Utilities, Colorado Springs, Colo.

M.R. Johnson, Upper Blackstone Clean Water, Millbury, Mass.

A.J. Quiniones, US Bureau of Reclamation, Denver, Colo.

This page intentionally blank.

Currently in preview, click buy full version

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		3	Definitions 4
I	Introduction..... vii	4	Requirements
I.A	Background..... vii	4.1	Data to Be Provided by the Supplier..... 5
I.B	History..... viii	4.2	Data to Be Provided by the Manufacturer..... 5
I.C	Acceptance..... viii	4.3	Materials..... 6
II	Special Issues..... ix	4.4	General Design..... 8
II.A	Chlorine and Chloramine Degradation of Elastomers..... ix	4.5	Manufacture..... 17
III	Use of This Standard..... x	4.6	Installation..... 18
III.A	Purchaser Options and Alternatives..... x	5	Verification
III.B	Modification to Standard..... xi	5.1	Inspection..... 19
IV	Major Revisions..... xi	5.2	Test Procedures..... 19
V	Comments.....	5.3	Basis for Rejection..... 20
Standard		6	Delivery
1	General	6.1	Marking..... 20
1.1	Scope..... 1	6.2	Shipment..... 20
1.2	Purpose..... 1	6.3	Affidavit of Compliance..... 20
1.3	Application..... 1	Appendix	
2	References 2	A	Force Required to Actuate Fabricated Stainless-Steel Slide Gates..... 21

This page intentionally blank.

Currently in preview, click buy full version

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C561.

I. Introduction.

I.A. *Background.* A fabricated stainless-steel slide gate is a vertically sliding gate with a fabricated, reinforced stainless-steel slide and a frame with ultra-high-molecular-weight polyethylene (UHMW-PE) seating faces and seals or UHMW-PE seating faces and resilient rubber seals. The slide gate consists of a self-contained frame or non-self-contained frame and a slide. Examples of where this type of gate is used include the control of water and wastewater through orifice openings in walls, at the ends of pipes, at the ends of open-top channels or within open-top channels and controlling flow at openings in tank walls. Downward-opening gates act as weir gates. Slide gates are raised and lowered by means of a stem or rod using a manually operated screw stem actuator, an electrically driven screw stem actuator, or by a hydraulic cylinder. Gates are mounted directly to concrete walls with anchor bolts, grouted into blockouts within concrete channel walls, or bolted to a pipe flange or wall thimble. Other terms used to describe slide gates include “penstocks” and “sluice gates”.

The term “slide gate” has been adopted for use by this series of standards, which supersede ANSI/AWWA C501-92. The standards are:

ANSI/AWWA C560—Cast-Iron Slide Gates

ANSI/AWWA C561—Fabricated Stainless-Steel Slide Gates

ANSI/AWWA C562—Fabricated Aluminum Slide Gates

ANSI/AWWA C563—Fabricated Composite Slide Gates

The slide gates represented by ANSI/AWWA C560 through ANSI/AWWA C563 differ in material and means of sealing between the slide and the fixed frame as described below.

ANSI/AWWA C560 gates have a cast-iron or cast-ductile-iron slide and frame with machined metal seating faces and wedges to force the slide to seal between the seating faces on the slide and frame.

ANSI/AWWA C561 gates have a fabricated, reinforced stainless-steel slide and a frame with UHMW-PE seating faces and seals or UHMW-PE seating faces and resilient rubber seals.

ANSI/AWWA C562 gates have a fabricated, reinforced aluminum slide and a frame with UHMW-PE seating faces and seals or UHMW-PE seating faces and resilient rubber seals.

ANSI/AWWA C563 gates have fiberglass-reinforced composite-plastic or rigid compressed plastic slides and frames of either fiberglass-reinforced composite-plastic, stainless steel, or coated carbon steel, with UHMW-PE seating faces and seals or UHMW-PE seating faces and resilient rubber seals.

I.B. *History.* The original AWWA standard for slide gates (then referred to as “sluice gates”) was approved as tentative on June 26, 1941 and described cast-iron gates. The tentative standard was revised and approved on June 4, 1967, as AWWA C501. Subsequent editions were approved in January 1980, June 1987, and June 1992. Following the latest revision, the Standards Council authorized the development of additional standards for slide gates to recognize the widespread use of slide gates similar to ANSI/AWWA C501 gates in performance but manufactured by different methods and from different materials. For consistency among the new standards and recognizing the new designs employed, the Standards Council directed that each of the standards use the name “slide gate” in lieu of the term “sluice gate.” The Standards Council also directed that ANSI/AWWA C501 be redesignated ANSI/AWWA C560, with subsequent slide gate standards numbered consecutively. The first edition of ANSI/AWWA C561, Fabricated Stainless-Steel Slide Gates, was approved on Jan. 18, 2004. Subsequent editions were approved on Jan. 22, 2011, and June 8, 2014. This edition was approved Jan. 25, 2021.

I.C. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.* Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including:

1. Specific policies of the state or local agency.

* Persons outside the United States should contact the appropriate authority having jurisdiction.

2. Two standards developed under the direction of NSF,[†] NSF/ANSI/[‡] CAN[§] 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects.

3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[¶] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI/CAN 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdictions. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI/CAN 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on priority testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

ANSI/AWWA C561 does not address additives requirements. Thus, users of this standard should consult the appropriate state or local agency having jurisdiction in order to:

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues

II.A. *Chlorine and Chloramine Degradation of Elastomers.* The selection of materials is critical for water service and distribution piping in locations where there is a possibility that elastomers will be in contact with chlorine or chloramines. Documented research has shown that elastomers such as gaskets, seals, valve seats, and enclosures may be degraded when exposed to chlorine or chloramines. The impact of degradation is a function of the type of elastomeric material, chemical concentration, contact surface area, elastomer cross section, environmental conditions as well as temperature. Careful selection of and specifications for elastomeric materials and the

[†] NSF International, P.O. Box 130140, 789 North Dixboro Road, Ann Arbor, MI 48105.

[‡] American National Standards Institute, 25 West 43rd Street, 4th Floor, New York, NY 10036.

[§] Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5 Canada.

[¶] Both publications available from The National Academies Press, 500 Fifth Street NW, Keck 360, Washington, DC 20001.

specifics of their application for each water system component should be considered to provide long-term usefulness and minimum degradation (swelling, loss of elasticity or softening) of the elastomer specified.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following items shall be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C561, Fabricated Stainless-Steel Slide Gates, of latest revision.
2. Whether compliance with NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects, is required.
3. Number of units required.
4. Type of closure—conventional or flush-bottom.
 - a. Size—by width and height of clear opening
5. Design head measured from the surface of water or wastewater to centerline of gate, in feet (meters), for the following:
 - a. Seating head.
 - b. Unseating head.
6. Operating head measured from surface of water or wastewater to centerline of gate, in feet (meters), in both seating and unseating conditions.
7. Type of lift actuator—manual, electric-motor-driven, or hydraulic-cylinder. If electric-motor-driven or hydraulic cylinder, the purchaser should refer to ANSI/AWWA C542, Electric Motor Actuators for Valves and Slide Gates, or ANSI/AWWA C541, Hydraulic and Pneumatic Cylinder and Vane-Type Actuators for Valves and Slide Gates, respectively, of latest revision.
8. Conventional mounted frame or self-contained thrust reaction frame.
9. Upward- or downward-opening gate.
10. If hydraulic actuators are specified, provide cylinder operating media and pressure (refer to ANSI/AWWA C541, Hydraulic and Pneumatic Cylinder and Vane-Type Actuators for Valves and Slide Gates, of latest revision).
11. Definition of any special design and construction required for conditions beyond the scope of this standard, such as throttling service, environmental conditions, sediment or grit exposure, and intended operation frequency and duration.
12. Frequency of operation and special operating conditions, such as ice formation.

13. An installation-requirement drawing showing clearances, wall and floor thicknesses, details of wall pipe and thimble installation, and location of actuator.
14. Any drawings and material requirements required of the supplier or of the manufacturer (Sec. 4.1 and Sec. 4.2).
15. Details of federal, state, provincial, territorial, and local requirements (Sec. 4.3).
16. If test records must be viewed (Sec. 4.3.2).
17. Acceptable materials (Sec. 4.3.3).
18. If seals, separate from seats, are to be provided (Sec. 4.3.3.8).
19. Rising stem or nonrising stem (Sec. 4.4.7 and 4.4.11).
20. Type of gate mounting used; if a wall thimble is used, required length and shape (Sec. 4.4.10).
21. Omission of stem covers if not required (Sec. 4.4.13.6).
22. If a gate position indicator is to be provided with the actuator (Sec. 4.4.13.7).
23. If an actuator stand is needed (Sec. 4.4.14).
24. Weld inspections, if required (Sec. 4.5.1.3.2).
25. Inspection by purchaser, if required (Sec. 5.1).
26. Leakage tests in the shop (Sec. 5.2.1) and in the field (Sec. 5.2.2), if required.
27. Separate shipment of embedded items, if required (Sec. 6.2).
28. Affidavit of compliance, if required (Sec. 6.3).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major revisions made to the standard in this edition include the following:

1. A section on chlorine and chloramine degradation of elastomers was added to the foreword (Sec. II.A.).
2. The definition of constructor has been removed from the standard.
3. Sec. 4: Requirements, was extensively updated to read consistently among the four slide gate standards, except for where materially different.
4. Tensile, compressive, and critical buckling loads were readdressed and clarified, along with the definitions for rated and extreme loads.
5. A basis for rejection section was added (Sec. 5.3)

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX 303.795.7603; write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098; or email at standards@awwa.org.

This page intentionally blank.



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA C561-21
(Revision of ANSI/AWWA C561-14)

AWWA Standard

Fabricated Stainless-Steel Slide Gates

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes vertically mounted, fabricated stainless-steel slide gates with full-aperture closure, designed for either seating head or unseating head or both, in ordinary water supply and wastewater service. The gates are primarily used to shut off or throttle water or wastewater flow through a rectangular or round orifice, end of channel, or in-channel opening. They may be of either conventional-closure or flush-bottom-closure type and may open upward or downward. This standard also describes manual gate actuator mechanisms together with standard accessories. Power-actuated mechanisms (including electric or hydraulic) are described in ANSI/AWWA C541 and ANSI/AWWA C542.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for fabricated stainless-steel slide gates, including materials, general design, manufacture, testing, inspection, and shipment.

Sec. 1.3 Application

This standard can be referenced in specifications for purchasing and receiving stainless-steel slide gates and can also be used as a guide for designing and manufacturing fabricated stainless-steel slide gates. The stipulations of this