

ANSI/AWWA **C715-18(R22)**

*(First Edition)
(Reaffirmed without revision 2022)*

AWWA Standard

Cold-Water Meters— Electromagnetic and Ultrasonic Type, for Revenue Applications

Effective date: May 1, 2023.

First edition approved by Board of Directors June 9, 2018.

2022 Reaffirmation approved Oct. 24, 2022.

Approved by American National Standards Institute Nov. 17, 2022.



American Water Works
Association



AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or code of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags or labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900; or e-mailing info@ansi.org.



ISBN-13, print: 978-1-64717-100-7

ISBN-13, electronic: 978-1-61300-671-9

DOI: <http://dx.doi.org/10.12999/AWWA.C715.22>

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher.

Copyright © 2022 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Water Meters, which reaffirmed this standard without revision, had the following personnel at the time:

Thomas A. Kelly Jr., *Chair*
Craig C. Hannah, *Vice-Chair*
Michael L. Mastic, *Secretary*

General Interest Members

J.E. Cray, Wright-Pierce, Andover, Mass.
D. Faber, Faber & Associates, Terra Alta, W.Va.
R.C. Graff, Poway, Calif.
J.G. Gunn (*alternate*), Johnson Controls, Inc., Victor, N.Y.
C.C. Hannah, Johnson Controls Inc., Lubbock, Tex.
D.E. Hood, M.E. Simpson Company Inc., Valparaiso, Ind.
A.M. Horbovetz (*alternate*), M.E. Simpson Company Inc., Valparaiso, Ind.
M.C. Johnson, Utah Water Research Laboratory, Utah State University, Logan, Utah
T.A. Kelly Jr., Meter Consultant, Martinsburg, W. Va.
F.S. Kurtz (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.
M.L. Mastic, MARS Company, Ocala, Fla.
M.R. Merkel, SL-serco Inc., Evansville, Ind.
K.C. Molli, Water Industry Consultant, Menomonee Falls, Wis.
R.A. Richter, National Institute of Standards and Technology, Gaithersburg, Md.

Producer Members

R.A. Barillas (*alternate*), Badger Meter, Milwaukee, Wis.
T.D. Bianchi, Neptune Technology Group Inc., Tallassee, Ala.
C. Brunson (*alternate*), Neptune Technology Group Inc., Tallassee, Ala.
D. Camper (*alternate*), Mueller Systems, Cleveland, N.C.
M.D. Cole, Meter Technology Werks, Tampa, Fla.
D.J. Devane, Zenner USA, Leeds, Ala.
R. Gallon (*alternate*), Zenner USA, Banning, Calif.
L. Gregory (*alternate*), RG3 Meter Company, Longview, Tex.
A. Hendey Sr., Hendey Meter, Beaumont, Calif.
B. Kaffenberger, Itron, Liberty Lake, Wash.

R.N. Koch, Master Meter Inc., Pittsburgh, Pa.
M. Laird (*alternate*), Metron-Farnier LLC, Boulder, Colo.
J.A. McCraven, Mueller Systems, Cleveland, N.C.
J.A. Olson, Badger Meter, Milwaukee, Wis.
J. Pintok, RG3 Meter Company, Lake Mary, Fla.
M. Shamley, Metron-Farnier LLC, Boulder, Colo.
J.R. Solanes (*alternate*), Meter Technology Werks, Tampa, Fla.
S.M. Swanson, Sensus, Uniontown, Pa.
J. Szweczyk (*alternate*), Sensus, Uniontown, Pa.
W.J. Vetter (*alternate*), Master Meter Inc., Mansfield, Tex.

User Members

M.J. Aragon, Denver Water, Denver, Colo.
M.C. Bowen, City of Columbus, Division of Water, Columbus, Ohio
J. Conover Jr., City of Sacramento, Sacramento, Calif.
G.M. Gehringer, Philadelphia Water Department, Philadelphia, Pa.
A. Haas, Arizona Water Company, Phoenix, Ariz.
P.A. Hayes, Mammoth Community Water District, Mammoth Lakes, Calif.
D.M. Hill, American Water, Voorhees, N.J.
N.D. Kaufman, Truckee Donner Public Utility District, Truckee, Calif.
A. Land, Dallas Water Utilities, Dallas, Tex.
S.U. Mills-Wright (*liaison, nonvoting*), Standards Council Liaison, Dallas Water Utilities, Dallas, Tex.
R. Molhoek, Desert Water Agency, Palm Springs, Calif.
C. Patterson, Washington Suburban Sanitary Commission, Laurel, Md.
B. Schade, WaterOne, Lenexa, Kans.
R. Sloan, Birmingham Water Works Board, Birmingham, Ala.
D. Strub, Austin Water Utility, Austin, Tex.

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		5	Verification
I	vii	5.1	Basis for Rejection 12
I.A	vii	6	Delivery
I.B	vii	6.1	Packaging and Shipping 12
I.C	vii	6.2	Affidavit of Compliance 12
II	ix	Appendix	
II.A	ix	A	Supplemental Information..... 13
	ix	A.1	Units of Measure 13
III	ix	A.2	Register Types..... 13
III.A	ix	A.3	Tests 13
III.B	x	A.4	Testing Equipment 15
IV	x	A.5	Registration Accuracy 15
V	x	A.6	Periodic Tests..... 16
		A.7	Meter Storage 16
		A.8	Installation 16
Standard		Tables	
1	1	1	Operating Characteristics 6
1.1	1	2a	Meter Dimension Limits, Meters with Threaded Ends (Casing Spuds), Exact Dimensions..... 7
1.2	1	2b	Meter Dimension Limits, Meters with Flanged End Connections, Maximum Required Dimensions 7
1.3	1	3	Meter Connections Companion Flange Dimensions..... 10
2	2	4	Maximum Indication on Initial Display and Minimum Register Capacity 11
3	3		
4	Requirements		
4.1	4		
4.2	6		
4.3	8		
4.4	12		

This page intentionally blank.

Currently in preview, click buy full version

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C715.

I. Introduction

I.A. *Background.* Electronic meters of the electromagnetic and ultrasonic types have been used in water distribution systems in North America for many years. These modern meter types offer alternatives to traditional mechanical-type meters, which were first standardized in the United States in 1913. Electronic meters require an energy source, such as line power or a battery. They have no moving parts. As such, mechanical wear and tear is low compared to mechanical meters.

I.B. *History.* This standard is the first edition for meters used in this application. It was developed by the AWWA Standards Subcommittee on Cold-Water Meters, Electronic Revenue Type, and it was approved by the AWWA Standards Committee on Water Meters. This first edition of the standard was approved by the AWWA Board of Directors on June 9, 2018, and it was reaffirmed without revision on Oct. 24, 2022.

I.C. *Acceptance.* In May 1985, the U.S. Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states.[†] Local agencies may choose to impose requirements more stringent than those required by the state. To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

[†] Persons outside the United States should contact the appropriate authority having jurisdiction.

2. Two standards developed under the direction of NSF[‡]: NSF/ANSI 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI 61, Drinking Water System Components—Health Effects.

3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[‡] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by a USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicology guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the supplier.

In an alternative approach to inadvertent drinking water additives, some jurisdictions (including California, Louisiana, Maryland, and Vermont, at the time of this writing) are calling for reduced lead limits for materials in contact with potable water. Various third-party certifiers have been assessing products against these lead content criteria, and a new ANSI-approved national standard, NSF/ANSI 372, Drinking Water System Components—Lead Content, was published in 2010.

On Jan. 4, 2011, legislation was passed revising the definition for “lead free” within the Safe Drinking Water Act (SDWA) as it pertains to “pipe, pipe fittings, plumbing fittings, and fixtures.” The changes went into effect on Jan. 4, 2014. In brief, the new provisions to the SDWA require that these products meet a weighted average lead content of not more than 0.25 percent.

ANSI/AWWA C715 does not address additive requirements. Users of this standard should consult the appropriate state or local agency having jurisdiction in order to

1. Determine additive requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

[‡] NSF International, 789 North Dixboro Road, Ann Arbor, MI 48105.

[§] Both publications available from National Academy of Sciences, 500 Fifth Street NW, Washington, DC 20001.

II. Special Issues.

II.A. *Chlorine and Chloramine Degradation of Elastomers.* The selection of materials is critical for water service and distribution piping in locations where there is a possibility that elastomers will be in contact with chlorine or chloramines. Documented research has shown that elastomers such as gaskets, seals, valve seats, and encapsulations may be degraded when exposed to chlorine or chloramines. The impact of degradation is a function of the type of elastomeric material, chemical concentration, contact surface area, elastomer cross section, environmental conditions, and temperature. Careful selection of and specifications for elastomeric materials and the specifics of their application for each water system component should be considered to provide long-term usefulness and minimum degradation (swelling, loss of elasticity, or softening) of the elastomer specified.

III. **Use of This Standard.** It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Purchaser Options and Alternatives.* The following information should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C715, Cold-Water Meters—Electromagnetic and Ultrasonic Type, for Revenue Applications, of latest revision.
2. Whether compliance with NSF/ANSI 61 Drinking Water System Components—Health Effects; NSF/ANSI 372, Drinking Water System Components—Lead Content; or an alternative lead content criterion is required.
3. Whether specific warranty provisions are required.
4. If meters are required to be listed by Underwriters Laboratories Inc. (UL), Factory Mutual Insurance Company (FM Global), or other insurance underwriting agency as fire-service type meters.
5. Detail of other federal, state or provincial, or local requirements (Sec. 4).
6. Limitations on acceptable materials, if any, as referenced throughout Sec. 4.1.
7. Restrictions on corrosion resistant treatment process (Sec. 4.1), if any.
8. Special materials required, if any, to resist corrosion if water is highly aggressive (Sec. 4.1).
9. If meters are to be provided with full polymer liners (Sec. 4.1.2).
10. Length of filler piece (Sec. 4.1.7 and 4.3.4), if required.
11. If meters are to be provided with coupling nuts and tailpieces (Sec. 4.1.7 and Sec. 4.3.4).

12. If flanged meters are to be provided with companion flanges, gaskets, bolts, and nuts (Sec. 4.1.8 and Sec. 4.3.5).

13. Meter size (not pipe size) (Sec. 4.2.1) and number of units required.

14. If 2 in. meters are to be supplied with internal NPT threaded ends, external NPSM threaded ends, flanged oval ends, or flanged round ends (Sec. 4.2.3, Sec. 4.3.3.1, and Sec. 4.3.3.2).

15. If 1½ meters are to be supplied with internal NPT threaded ends, external NPSM threaded ends, or flanged oval ends (Sec. 4.2.3, Sec. 4.3.3.1, and Sec. 4.3.3.2).

16. Details of register to be provided, where there is a preference, with regard to whether the registers shall read in US gallons, cubic feet, or cubic meters (Sec. 4.3.6.6).

17. Whether the meter serial number is imprinted on the main case (Sec. 4.4).

18. Whether an affidavit of compliance (Sec. 6.2), a certificate of testing for accuracy (Sec. A.3.3), or both are to be provided.

19. Modification of test specifications, if required, if operating water temperatures are to exceed 80°F (27°C) (Sec. A.5.1).

III.B. *Modification to Standard.* Any modification to the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. This is the first edition of this standard.

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603, write to the department at 666 W. Quincy Ave., Denver, CO 80235-3098, or e-mail at standards@awwa.org.



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA C715-18(R22)
(First Edition)
(Reaffirmed without revision 2022)

AWWA Standard

Cold-Water Meters—Electromagnetic and Ultrasonic Type, for Revenue Applications

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard describes two performance classes of potable cold-water meters of the electromagnetic and ultrasonic type, in sizes ½ in. (13 mm) through 20 in. (500 mm), for revenue applications, and the materials and workmanship employed in their fabrication.

1. Type I. This type represents residential and commercial applications where low flow accuracy is of particular concern.
2. Type II. This type represents commercial applications where low flow is not of primary concern.

Sec. 1.2 Purpose

The purpose of this standard is to provide the minimum requirements for potable cold-water meters of the electromagnetic and ultrasonic type, in sizes ½ in. (13 mm) through 20 in. (500 mm), for revenue applications.

Sec. 1.3 Application

This standard can be referenced in specifications for purchasing and receiving potable cold-water meters of the electromagnetic and ultrasonic type, in sizes ½ in.