

ANSI/AWWA **C800-21**
(Revision of ANSI/AWWA C800-14)

AWWA Standard

Underground Service Line Valves and Fittings

Effective date: Oct. 1, 2021.

First edition approved by AWWA Board of Directors Sept. 1, 1948.

1st edition approved June 10, 2021.

Approved by American National Standards Institute May 27, 2021.



American Water Works
Association




AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed in the Official Notice section of *Journal AWWA*. The action becomes effective on the first day of the month following the month of *Journal AWWA* publication of the official notice.

American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether that person has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions. Producers of goods made in conformity with an American National Standard are encouraged to state on their own responsibility in advertising and promotional materials or on tags and labels that the goods are produced in conformity with particular American National Standards.

CAUTION NOTICE: The American National Standards Institute (ANSI) approval date on the front cover of this standard indicates completion of the ANSI approval process. This American National Standard may be revised or withdrawn at any time. ANSI procedures require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of ANSI approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036; (212) 642-4900, or e-mailing info@ansi.org.



ISBN-13, print: 978-1-64717-051-0

ISBN-13, electronic: 978-1-61300-590-3

DOI: 10.12999/AWWA.C800.21

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including scanning, recording, or any information or retrieval system. Reproduction and commercial use of this material is prohibited, except with written permission from the publisher. Please send any requests or questions to permissions@awwa.org.

Copyright © 2021 by American Water Works Association
Printed in USA

Committee Personnel

The AWWA Standards Committee on Water Service Line Fittings, which reviewed and approved this standard, had the following personnel at the time of approval:

Savas C. Danos, *Chair*
Chad Harbour, *Vice-Chair*

General Interest Members

P. Banschbach, Garver, Frisco, Texas
S.C. Danos, Panton McLeod Americas, Charlestown, R.I.
J.W. Hellums, Booth Hellums and Associates LLC, Lake Charles, La.
M.V Liga, LAN Inc., Houston, Texas
E.S. Ralph (*liaison, nonvoting*), Standards Engineer Liaison, AWWA, Denver, Colo.
R.A. Waggenpack, Owen & White Inc., Baton Rouge, La.

Producer Members

A. Bain, Ford Meter Box Company Inc., Wabash, Ind.
A. Brock, Philmac, Rowlett, Texas
R.R. Collins, JCM Industries, Nash, Texas
P. Gifford (*alternate*), Mueller Company, Chattanooga, Tenn.
T.C. Harbour, Mueller Company, Decatur, Ill.
B.J. Haas (*alternate*), A.Y. McDonald Manufacturing Company, Dubuque, Iowa
D.A. Miller (*non-voting*), Apollo Conbraco Industries, Inc., Pageland, S.C.
L. Muller, Wieland Chase, Montpelier, Ohio
C. Shanks (*alternate*), Ford Meter Box Company Inc., Wabash, Ind.
S. Tefft, A.Y. McDonald Manufacturing Company, Dubuque, Iowa

User Members

I. Freeman, Canby Utility Board, Danby, Ore.
C. Cary (*liaison, nonvoting*), Standards Council Liaison, Western Virginia Water Authority, Roanoke, Va.
L. De Los Santos (*alternate*), Las Vegas Valley Water District, Las Vegas, Nev.

P.J. Dicken, Citizens Water, Indianapolis, Ind.

J.F. Gruber, Lehigh County Authority, Allentown, Penn.

G.P. Kodweis, Las Vegas Valley Water District, Las Vegas, Nev.

B.E. Perron, Salem-Beverly Water Supply Board, Beverly, Mass.

V. Price, City of Houston, Houston, Texas

K. Ross, Denver Water, Denver, Colo.

Currently in preview, click buy full version

Contents

All AWWA standards follow the general format indicated subsequently. Some variations from this format may be found in a particular standard.

SEC.	PAGE	SEC.	PAGE
Foreword		4.3	Detailed Design..... 7
I	Introduction..... vii	4.4	End Connections 10
I.A	History..... vii	4.5	Fabrication 16
I.B	Acceptance viii	4.6	Permeation 17
II	Special Issues ix	5	Verification
II.A	Lead Fittings ix	5.1	Inspection 17
II.B	Chlorine and Chloramine Degradation of Elastomers ix	5.2	Testing 17
III	Use of This Standard ix	5.3	Basis for Inspection..... 17
III.A	Products Intended for Waterworks Applications ix	6	Delivery
III.B	Purchaser Options and Alternatives x	6.1	Marking 18
III.C	Modification to Standard x	6.2	Packing and Shipping..... 18
IV	Major Revisions xi	6.3	Affidavit of Compliance 18
V	Comments xi	Appendixes	
Standard		A	Collected Standards for Service Line Materials 19
1	General	B	Field Testing..... 25
1.1	Scope 1	C	Installation 27
1.2	Purpose 2	Figures	
1.3	Application 2	1	Curb Valve Heads..... 8
2	References 2	2	Standard AWWA Corporation Stop Inlet Thread 12
3	Definitions 3	3	Coupling Nut for Use With Flared Copper Service Tube, Types K and L..... 14
4	Requirements	4	Outlet End of Corporation Stop Showing Increased-Size NPT External Threads and Internal Driving Threads 14
4.1	Materials 5		
4.2	General Design 6		

SEC.	PAGE	SEC.	PAGE
5	14	7	11
Flared Fitting End Showing Threads for Use With Flared Copper Service Tube (Minimum Length, <i>L</i> , Is from Table 4.).....		Standard AWWA Corporation Stop Inlet Threads and Corresponding Internal Threads for Saddles.....	
6	14	8	12
Outlet End of Corporation Stop Showing Special-Purpose Coupling Threads and Internal Driving Threads.....		Standard AWWA Corporation Stop Tolerance of Thread Truncation	
7	15	9	12
Meter Coupling Nut		Standard AWWA Corporation Stop Tolerance of Thread Taper, Lead and Angle.....	
8	16	10	13
Meter Flange		Tapered External Iron Pipe (NPS) Threads for Outlet End of Corporation Stops.....	
Tables			
1	7	11	15
Maximum Drill Sizes for Installation of Corporation Stops in Service Clamps or Saddles With a Drilling Machine.....		Internal Driving Thread for Corporation Stops.....	
2	7	12	15
Maximum Overall Body Dimensions for Corporation Stops for Use With Tapping Machine.....		Meter Coupling Nut	
3	10	13	16
Curb Valve Head Dimensions		Meter Flanges.....	
4	10	A.1	20
Fitting Thread for Use With Flared Copper Service Tube		Dimensions, Weights, and Tolerances in Diameter and Wall Thickness for Nominal or Standard Copper Water Tube Sizes	
5	11	A.2	21
Coupling Nut for Use With Flared Copper Service Tube		Dimensions, Weights, and Tolerances for Standard Sizes of Seamless Red Brass Pipe	
6	11	A.3	22
Corporation Stop Outlet special- Purpose Coupling Threads		Standard Weights and Dimensions of Welded and Seamless Steel Pipe.....	

Foreword

This foreword is for information only and is not a part of ANSI/AWWA C800.*

I. Introduction.

I.A. *History.* In 1929, the development of a standard for threads for underground service fittings was undertaken by the American Standards Association (ASA). In 1932, the subcommittee that had been appointed for the task asked to be discharged after it had submitted its proposed standards in the form of two drawings. No action was taken by ASA on these proposed standards.

The American Water Works Association (AWWA) recognized the need for standardization of these threads and appointed a committee in 1940 to prepare a standard. The New England Water Works Association (NEWWA) also appointed a committee to prepare a standard for these threads. The AWWA and NEWWA committees cooperated closely in developing a tentative standard in 1947. This was approved as a standard by AWWA on Sept. 1, 1948, and by NEWWA on Sept. 14, 1948. Revisions to the standard were made effective Jan. 17, 1955. In July 1963, a committee was formed to revise C800-55 regarding the evaluation of types K and L copper tubing for water services. In the revision, published in 1966, threads representing current practice were established for those fittings generally used in the water utility field. Sizes 1/2 in. and 5/8 in. were added for inlet and outlet threads for fittings and couplings for use with flared copper service tubing. The 1966 revision introduced an appendix that was not part of the standard but which listed standards for water service line materials. The appendix was provided for information only because the materials were covered by other standards. The appendix also contained specifications for copper water tubing, red brass pipe, cast-iron pipe, and steel pipe.

In 1974, a standing committee was formed to revise and update C800-66. The committee recognized the need to expand the scope of this standard beyond being a standard covering only threads for underground service fittings. Previous versions of C800 described only the threads for fittings that were in common use in water distribution systems. Subsequently, the scope of the standard was changed to include performance standards for underground service line fittings as well as for the threads. The 1984 revision to C800 was approved by the AWWA Board of Directors on Jan. 29, 1984. Subsequent revisions were approved on Jan. 1, 1990; Jan. 21, 2001; Jan. 16, 2005; June 10, 2012; and June 8, 2014. This revision was approved on June 10, 2021.

* American National Standards Institute, 25 West 43rd Street, Fourth Floor, New York, NY 10036.

I.B. *Acceptance.* In May 1985, the US Environmental Protection Agency (USEPA) entered into a cooperative agreement with a consortium led by NSF International[†] (NSF) to develop voluntary third-party consensus standards and a certification program for direct and indirect drinking water additives. Other members of the original consortium included the Water Research Foundation, (formerly AwwaRF) and the Conference of State Health and Environmental Managers (COSHEM). The American Water Works Association (AWWA) and the Association of State Drinking Water Administrators (ASDWA) joined later.

In the United States, authority to regulate products for use in, or in contact with, drinking water rests with individual states. Local agencies may choose to impose requirements more stringent than those required by the states.[‡] To evaluate the health effects of products and drinking water additives from such products, state and local agencies may use various references, including

1. Specific policies of the state or local agency.
2. Two standards developed under the direction of NSF, NSF/ANSI/CAN[§] 60, Drinking Water Treatment Chemicals—Health Effects, and NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects.
3. Other references, including AWWA standards, *Food Chemicals Codex*, *Water Chemicals Codex*,[¶] and other standards considered appropriate by the state or local agency.

Various certification organizations may be involved in certifying products in accordance with NSF/ANSI/CAN 61. Individual states or local agencies have authority to accept or accredit certification organizations within their jurisdiction. Accreditation of certification organizations may vary from jurisdiction to jurisdiction.

Annex A, “Toxicology Review and Evaluation Procedures,” to NSF/ANSI/CAN 61 does not stipulate a maximum allowable level (MAL) of a contaminant for substances not regulated by the USEPA final maximum contaminant level (MCL). The MALs of an unspecified list of “unregulated contaminants” are based on toxicity testing guidelines (noncarcinogens) and risk characterization methodology (carcinogens). Use of Annex A procedures may not always be identical, depending on the certifier.

In an alternative approach to inadvertent drinking water additives, some jurisdictions (including California, Maryland, Vermont, and Louisiana at the time of this writing)

[†] NSF International, P.O. Box 130140, 789 N. Dixboro Rd., Ann Arbor, MI 48105.

[‡] Persons outside the United States should contact the appropriate authority having jurisdiction.

[§] Standards Council of Canada, 55 Metcalfe Street, Suite 600, Ottawa, ON K1P 6L5, Canada.

[¶] Both publications available from The National Academies Press, 500 Fifth St., NW, Washington, DC 20001.

are calling for reduced lead limits for materials in contact with potable water. Various third-party certifiers have been assessing products against these lead content criteria, and a new ANSI-approved national standard, NSF/ANSI 372, Drinking Water System Components—Lead Content, was published in 2010.

On Jan. 4, 2011, legislation was signed revising the definition for “lead free” within the Safe Drinking Water Act (SDWA) as it pertains to “pipe, pipe fittings, plumbing fittings, and fixtures.” The changes went into effect on Jan. 4, 2014. In brief, the new provisions to the SDWA require that these products meet a weighted average lead content of not more than 0.25 percent when used with respect to wetted surfaces.

ANSI/AWWA C800 does not address additives requirements. Users of this standard should consult the appropriate state, or local agency having jurisdiction in order to

1. Determine additives requirements, including applicable standards.
2. Determine the status of certifications by parties offering to certify products for contact with, or treatment of, drinking water.
3. Determine current information on product certification.

II. Special Issues.

II.A. *Lead Fittings.* References to lead fittings have been removed from ANSI/AWWA C800 and the attached appendixes. The AWWA Standards Department has available to users of ANSI/AWWA C800 copies of ANSI/AWWA C800-84 information that contains references to lead fittings.

II.B. *Chlorine and Chloramines Degradation of Elastomers.* The selection of materials is critical for water service and distribution piping in locations where there is a possibility that elastomers will be in contact with chlorine or chloramines. Documented research has shown that elastomers such as gaskets, seals, valve seats, and encapsulations may be degraded when exposed to chlorine or chloramines. The impact of degradation is a function of the type of elastomeric material, chemical concentration, contact surface area, elastomer cross section, environmental conditions as well as temperature. Careful selection of and specifications for elastomeric materials and the specific of their application for each water system component should be considered to provide long-term usefulness and minimum degradation (swelling, loss of elasticity or stiffening) of the elastomer specified.

III. Use of This Standard. It is the responsibility of the user of an AWWA standard to determine that the products described in that standard are suitable for use in the particular application being considered.

III.A. *Products Intended for Waterworks Applications.* A variety of valves, fittings, and other water conveyance devices are available on the market for water service.

For the user, it is important to distinguish between products designated plumbing style versus waterworks service style and to ensure the proper product is selected for the specific application. Waterworks products are designed and constructed for belowground installation. This helps ensure long-term performance under a variety of installation and service conditions. The specific materials established in ANSI/AWWA C800 were selected to provide long-term performance and corrosion resistance from both internal and external sources. The user is cautioned that underground service line valves and fittings not compliant with ANSI/AWWA C800 may result in unsatisfactory performance or failure of the product. When in doubt concerning product suitability, contact a waterworks manufacturer for assistance.

III.B. *Purchaser Options and Alternatives.* The following information should be provided by the purchaser:

1. Standard used—that is, ANSI/AWWA C800, Standard for Underground Service Line Valves and Fittings, of latest revision.
2. Whether compliance with NSF/ANSI/CAN 61, Drinking Water System Components—Health Effects is required.
3. Whether compliance with NSF/ANSI 37, Drinking Water System Components—Lead Content, or an alternative lead content criterion, is required.
4. The size and type of fitting or valve.
5. Quantity required.
6. Details of federal, state, and local requirements (Sec 4.1.1).
7. Working pressures under which the valve or fitting will be operated after installation—normal or high pressure (Sec. 4.2).
8. Minimum inside diameter of waterway through corporation stops (Sec. 4.3.1.1).
9. If meter set spacing is other than shown to accommodate meter lengths listed in Table 12 or 13 (Sec. 4.3.14).
10. Type of inlet thread (Sec. 4.4).
11. Size and type of outlet thread (Sec. 4.4).
12. If meter flanges other than oval are required (Sec. 4.4.12).
13. Whether records of factory tests are to be provided (Sec. 5.2.1).
14. Description of special castings or patterns, if required. Special casting markings, if required, should be stated, including location of these markings (Sec. 6.1).
15. Whether an affidavit of compliance is to be provided (Sec. 6.3).

III.C. *Modification to Standard.* Any modification of the provisions, definitions, or terminology in this standard must be provided by the purchaser.

IV. Major Revisions. Major revisions made to the standard in this edition include the following:

1. An advisory statement was added in the foreword (Sec. II.B) regarding chlorine and chloramine degradation of elastomers.
2. Updated Sec. 1.3 Applicability to address considerations regarding suitability for wastewater applications.
3. Sec. 2 References was updated.
4. Added definitions for potable water, reclaimed water, and wastewater in Sec. 3.
5. Three non-Bismuth low-lead silicon-based material options were added to Sec. 4.1.2 Castings.
6. A new Sec. 4.1.2.2 was added to address dezincification performance of alloys utilized in areas with aggressive water.
7. A new Sec. 4.1.2.2.1 was added to make purchaser requirements from gate valve and/or hydrant specifications, such as maximum zinc content, applicable to C800.
8. Sec. 4.1.3 Cast service saddles was revised to include the option of using the low-lead copper alloys that are accepted for use in Sec. 4.1.2 Castings.
9. A new Sec. 4.1.6.1 was added to make Sec. 4.1.2.2 applicable to component parts.
10. Sec. 4.1.5 Saddle corrosion protection was revised to reflect the changes made to Sec. 4.1 and a requirement was added for materials in contact with potable water to conform to NSF/ANSI/CAN 61.
11. A new Sec. 4.4.4.1.2 was added on angle of thread, thread height, and thread truncation.
12. A new Sec. 4.4.4.1.2 was added for tolerances for thread truncation, taper, lead, and angle.
13. Two new tables were added: new Table 8, Standard AWWA Corporation Stop Tolerance of Thread Truncation, and new Table 9, Standard AWWA Corporation Stop Tolerance of Thread Taper, Lead, and Angle.

V. Comments. If you have any comments or questions about this standard, please call AWWA Engineering and Technical Services at 303.794.7711, FAX at 303.795.7603, write to the department at 6666 West Quincy Avenue, Denver, CO 80235-3098, or email at standards@awwa.org.

This page intentionally blank.



**American Water Works
Association**

Dedicated to the World's Most Important Resource®

ANSI/AWWA C800-21
(Revision of ANSI/AWWA C800-14)

AWWA Standard

Underground Service Line Valves and Fittings

SECTION 1: GENERAL

Sec. 1.1 Scope

This standard covers valves, fittings, service saddles, and meter setters for use in a service line from the main through the meter valve or meter-setting appurtenance. Valves, fittings, and meter setters described in this standard include ½ in. (12.5 mm) through 2 in. (50.8 mm). Service saddles described have outlet sizes ½ in. (12.5 mm) through 2 in. (50.8 mm) and fit mains of 2 in. (50.8 mm) through 12 in. (304.8 mm). Valves include corporation stops and curb stops. Fittings include various types of couplings and adapters. Service saddles include various types of devices circumferentially attached to the main. Meter setters include various configurations of copper tubing, valves, and fittings for the holding of ⅝-in. (15.875-mm) through 2-in. (50.8-mm) meters.

1.1.1 *Installation.* The performance of products depends on proper installation. The purchaser must follow instructions supplied by or available from the manufacturer. If these instructions are not available, good installation practices shall be followed.