

BS 750:2023



BSI Standards Publication

**Underground fire hydrants – Surface  
box frames and covers – Specification**

**bsi.**

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2023

Published by BSI Standards Limited 2023

ISBN 978 0 59 05179 7

ICS 3.22.10

The following BSI references relate to the work on this document:

Committee reference FSH/17

Draft for comment 22/30396867 DC

**Amendments/corrigenda issued since publication**

Date	Text affected
------	---------------

---

# Contents

	Page
<b>Foreword</b>	<b>III</b>
Introduction	1
1 Scope	1
2 Normative references	1
3 Terms and definitions	3
4 Fire hydrants	3
4.1 General	3
4.2 Type 1 fire hydrant	3
<i>Figure 1 — Type 1 fire hydrant showing required dimensions</i>	4
<i>Figure 2 — Type 1 fire hydrant showing required dimensions (integral)</i>	5
4.3 Type 2 fire hydrant	5
<i>Figure 3 — Type 2 fire hydrant showing required dimensions</i>	7
<i>Figure 4 — Type 3 fire hydrant showing required dimensions (through-bore)</i>	8
<i>Figure 5 — Example of primary and secondary seals within the chambers</i>	10
5 Outlets	11
<i>Figure 6 — Screwed outlet (round thread) and outlet cap showing required dimension</i>	12
6 Stem drive	12
6.1 Dimensional and performance requirements	12
6.2 Closing direction	13
6.3 Stem termination	13
7 Draining system	13
8 Coating	13
9 Maintenance of water purity (potable water systems only)	13
10 Type requirements	13
10.1 General	13
10.2 Hydraulic characteristics	13
10.3 Load/deflection requirements of screwed outlets	14
10.4 Strength and leak tightness requirements of type 2a and type 2d screwed outlets – resistance of screwed outlets to rotational force	14
10.5 Resistance of fire hydrants to operating forces	14
10.6 Strength and leak tightness requirements of type 2a and type 2d bonnets – resistance of bonnets to rotational force	14
10.7 Endurance of the outlet	15
10.8 Air release	15
10.9 Obturator impact resistance	15
11 Fire hydrant assembly – resistance to internal pressure of the shell and of all pressure containing components and resistance of the obturator to differential pressure	15
12 Hydrostatic test certificate	15
13 Marking and additional data	15
14 Surface box frames and covers	16
14.1 General	16
14.2 Grading	16
14.3 Materials	16
14.4 Manufacture, workmanship and coating	16
14.5 Design features	16
14.6 Frame depth and width	17
<i>Figure 7 — Minimum bedding width of surface box frame showing required dimensions</i>	17
14.7 Surface box cover lifting arrangement	17

	<i>Figure 8 — Prising bar dimensions</i>	18
	<i>Figure 9 — Geometry of prising slots</i>	19
	<i>Figure 10 — Detail of keyhole and key</i>	20
15	Fire hydrant chamber alignment	20
16	Marking	20
17	Type requirements	20
18	Production requirements	21
	<i>Table 1 — Production test load requirements and acceptance criteria</i>	21
19	Test certificate	21
<b>Annex A</b>	<b>(normative) Type tests for fire hydrant strength, security and endurance</b>	<b>22</b>
	<i>Figure A.1 — Load/deflection test apparatus</i>	23
<b>Annex B</b>	<b>(normative) Type hydrostatic tests for screwed outlets</b>	<b>25</b>
<b>Annex C</b>	<b>(normative) Air release test</b>	<b>26</b>
	<i>Figure C.1 — Example arrangement of test apparatus</i>	26
<b>Annex D</b>	<b>(normative) Obturator impact resistance test</b>	<b>27</b>
<b>Annex E</b>	<b>(normative) Hydrant box cover opening procedure</b>	<b>28</b>
<b>Annex F</b>	<b>(normative) Type and production loading tests for surface coatings and covers</b>	<b>28</b>
<b>Annex G</b>	<b>(informative) Information to be supplied by the purchaser</b>	<b>30</b>
<b>Annex H</b>	<b>(normative) Alignment and depth of the hydrant in the chamber</b>	<b>31</b>
	<i>Figure H.1 — Hydrant chamber offset (horizontal)</i>	31
	<i>Figure H.2 — Hydrant chamber offset (vertical)</i>	32
	<b>Bibliography</b>	<b>33</b>

### Summary of pages

This document comprises a front cover, an inside front cover, pages I to IV, pages 1 to 33, an inside back cover and a back cover.

# Foreword

## Publishing information

This British Standard is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 31 July 2023. It was prepared by Technical Committee FSH/17, *Fire and rescue service equipment*. A list of organizations represented on this committee can be obtained on request to the committee manager.

## Supersession

This British Standard supersedes [BS 750:2012](#), which is withdrawn.

## Information about this document

This is a full revision of the document, and introduces the following principal changes.

- new figures for integral and through-bore hydrant types;
- updated requirements for stem seals, drive and termination;
- revision of pressure units for consistency to SI units, for example, converting bar to MPa;
- inclusion of non-metallic materials used for the manufacture of surface boxes installed in areas subject to non-vehicular traffic; and
- new annex containing requirements for alignment and depth of the fire hydrant in the chamber.

This publication can be withdrawn, revised, partially superseded or superseded. Information regarding the status of this publication can be found in the Standards Catalogue on the BSI website at [bsigroup.com/standards](https://bsigroup.com/standards), or by contacting the Customer Services team.

Where websites and webpages have been cited, they are provided for ease of reference and are correct at the time of publication. The location of a webpage or website, or its contents, cannot be guaranteed.

## Presentational conventions

The provisions of this document are presented in roman (i.e. upright) type. Its requirements are expressed in sentences in which the principal auxiliary verb is “shall”.

*Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.*

Where words have alternative spellings, the preferred spelling of the *Shorter Oxford English Dictionary* is used (e.g. “organization” rather than “organisation”).

## Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient’s own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

**Compliance with a British Standard cannot confer immunity from legal obligations.**

Currently in preview, click buy full version

## Introduction

A fire hydrant is installed primarily for use by the Fire and Rescue Service (FRS) to quickly secure a supply of water to extinguish a fire in the vicinity. A fire hydrant may also be installed for other purposes that allow a water supplier access to the pressurized water network.

*NOTE* A fire hydrant installed for non-fire fighting purposes is commonly known as a washout.

The water supplier is responsible for installing and maintaining fire hydrants for both purposes.

It is advisable to consult the FRS and the water supplier during the development of products in accordance with this standard. In general terms, the FRS requires quick access to a supply of water from a fire hydrant using an operating key/bar and a standpipe. The water supplier does not require such quick access but carries a wider range of tools and equipment for operation and maintenance.

Surface boxes manufactured in non-metallic materials are now included for use in low alkaline environments not subject to vehicular traffic.

## 1 Scope

This British Standard specifies the operational and health and safety requirements for underground fire hydrants conforming to the dimensional, material and performance requirements of [BS EN 14339](#) and [BS EN 1074-6](#). It also includes specific national requirements not included in [BS EN 14339](#) and [BS EN 1074-6](#).

This British Standard applies to underground fire hydrants

- a) to be installed in a water supply system;
- b) of size DN80;
- c) suitable for a maximum allowable operating pressure (PFA) of 1.6 MPa or 2.5 MPa;
- d) with operating valves; and
- e) with one outlet.

It also specifies requirements for their surface box frames and covers.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes provision, or limits the application, of this document<sup>1)</sup>. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

### Standards publications

[BS 1336](#), *Specification for fire hose couplings and ancillary equipment*

[BS 5163-1](#), *Valves for waterworks purposes – Part 1: Predominantly key-operated cast iron gate valves – Code of practice*

[BS 5163-2](#), *Valves for waterworks purposes – Part 2: Stem caps for use on isolating valves and associated water control apparatus – Specification*

[BS 5834-2:2011](#), *Surface boxes, guards and underground chambers for the purposes of utilities – Part 2: Specification for surface boxes*

<sup>1)</sup> Documents that are referred to solely in an informative manner are listed in the Bibliography.