

**Power cables with
XLPE insulation and
metallic sheath, and
their accessories, for
rated voltages from
66 kV ($U_m = 72.5$ kV)
to 132 kV
($U_m = 145$ kV) —
Requirements and test
methods**

(Implementation of HD 632)

ICS 29.060.20

Confirmed
December 2011

Committees responsible for this British Standard

The preparation of this British Standard was entrusted by Technical Committee GEL/20, Electric cables, to Subcommittee GEL/20/2, Mains cables, 1 kV and above, upon which the following bodies were represented:

Association of Consulting Engineers
British Approvals Service for Cables
British Cables Association
British Plastics Federation
Electricity Association
ERA Technology Ltd.
London Underground Ltd.
UK Steel Association

This British Standard, having been prepared under the direction of the Electrotechnical Sector Policy and Strategy Committee, was published under the authority of the Standards Policy and Strategy Committee on 7 November 2001

© BSI 7 November 2001

Amendments issued since publication

Amd. No.	Date	Comments

The following BSI references relate to the work on this British Standard:
Committee reference GEL/20/2
Draft for comment 95/215801 DC

Contents

	Page
Committees responsible	Inside front cover
Foreword	ii
<hr/>	
1 Scope	1
2 Normative references	1
3 Definitions	2
4 Voltage designation and materials	2
5 Precautions against water penetration in cables	3
6 Cable characteristics	4
7 Accessory characteristics	5
8 Test categories and conditions	5
9 Routine tests on cables	6
10 Sample tests on cables	8
11 Type tests — Summary	13
12 Electrical type tests on cables	14
13 Type tests on cable components	17
14 Water penetration type test on complete cable	20
15 Mechanical and thermal type tests on complete cables	22
16 Type tests on accessories	25
17 Type tests on ancillary equipment	29
18 Electrical tests after installation	36
<hr/>	
Bibliography	41
<hr/>	
Figure 1 — Swell height for water blocking tape	11
Figure 2 — Shrinkage test	20
Figure 3 — Schematic diagram of apparatus of water penetration test	21
Figure 4 — Possible arrangement of sample in saline bath	24
<hr/>	
Table 1 — Test voltage	3
Table 2 — Cable maximum temperatures	4
Table 3 — Number of samples for sample tests	8
Table 4 — Test conditions and requirements for particular characteristics of cable insulating materials	9
Table 5 — Type tests on cable components	14
Table 6 — Tan δ in relation to voltage	16
Table 7 — Tan δ in relation to temperature	16
Table 8 — Power frequency voltage test	17
Table 9 — Tests and requirements for mechanical characteristics of XLPE insulating material before and after ageing	18
Table 10 — Tests and requirements for mechanical characteristics of cable sheathing materials before and after ageing	19
Table 11 — D.C. voltage test values	26
Table 12 — Impulse voltage test levels	28
Table 13 — Salt fog test voltage levels	28
Table 14 — Internal pressure levels for hydraulic test	28
Table 15 — Construction of single core bonding leads	30
Table 16 — Construction of concentric bonding leads	30
Table 17 — Test voltages for bonding leads	32
Table 18 — Conductor resistance	32
Table 19 — Short circuit requirements for terminal posts and links	34
Table 20 — Maximum contact resistance values	37
Table 21 — Voltage and current range for silicon carbide units	40

Foreword

This British Standard has been prepared by Subcommittee GEL/20/2, Mains cables, 1 kV and above, under the direction of Technical Committee GEL/20, Electric cables.

It implements the nationally applicable parts of Harmonization Document HD 632 published by the European Committee for Electrotechnical Standardization (CENELEC), in accordance with the decision of the CENELEC Technical Board.

BS 7912 applies to power cables with XLPE insulation and metallic sheath, and their accessories for rated voltages $U(U_m)$ from 66 kV (72.5 kV) to 132 kV (145 kV).

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, pages 1 to 41 and a back cover.

The BSI copyright notice displayed in this document indicates when the document was last issued.

1 Scope

This British Standard specifies tests and requirements for power cables with XLPE insulation and metallic sheath and their accessories for rated voltages from 66 kV (72.5 kV) to 132 kV (145 kV) for fixed installations.

This British Standard is applicable to single core cables and 3-core cables with separate cores and to their accessories for usual conditions of installation and operation. It is not applicable to special cables and their accessories, such as those designed for submarine cables, for which modification to the standard test methods may be necessary or special test conditions may need to be devised.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of this British Standard. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. For undated references, the latest edition of the publication referred to applies.

- BS 228:1994, *Specification for short-pitch transmission precision roller chains and chain wheels.*
- BS 4727-2:Group 08:1994, *Glossary of electrotechnical, power, telecommunication, electronics, lighting and colour terms — Part 2: Terms particular to power engineering — Group 08: Electric cables.*
- BS 6346, *Specification for 600/1000 V and 1900/3300 V armoured electric cables having PVC insulation.*
- BS 7870-2, *LV and MV polymeric insulated cables for use by distribution and generation utilities — Part 2: Methods of test.*
- BS EN 50062, *Ceramic pressurized hollow insulators for high-voltage switchgear and controlgear.*
- BS EN 60811-1-1:1995, *Insulating and sheathing materials of electric cables — Common test methods — General application — Part 1-1: Measurement of thickness and overall dimensions — Tests for determining the mechanical properties.*
- BS EN 60811-1-2:1995, *Insulating and sheathing materials of electric cables — Common test methods — General application — Part 1-2: Thermal ageing methods.*
- BS EN 60811-1-3:1995, *Insulating and sheathing materials of electric cables — Common test methods — General application — Part 1-3: Methods for determining the density — Water absorption tests — Shrinkage test.*
- BS EN 60811-2-1:1995, *Insulating and sheathing materials of electric cables — Common test methods — Methods specific to elastomeric compounds — Part 2-1: Ozone resistance test — Hot set test — Mineral oil immersion test.*
- BS EN 60811-3-1:1995, *Insulating and sheathing materials of electric cables — Common test methods — Methods specific to PVC compounds — Part 3-1: Pressure test at high temperature — Tests for resistance to cracking.*
- IEC 60060-1, *Guide to high-voltage testing techniques — Part 1: General (published as BS 923 Part 1).*
- IEC 60228, *Conductors of insulated cables (published as BS 6360).*
- IEC 60229, *Tests on cable oversheaths which have a special protective function and are applied by extrusion.*
- IEC 60230, *Impulse tests on cables and their accessories (implemented by CENELEC as HD 48).*
- IEC 60297:1991, *Artificial pollution tests on high-voltage insulators to be used on a.c. systems.*
- IEC 60845-2, *Electrical test methods for electric cables — Part 2: Partial discharge tests.*
- IEC 60885-3, *Electrical test methods for electric cables — Part 3: Test methods for partial discharge measurements on lengths of extruded power cable.*