

BS 9251:2021



BSI Standards Publication

**Fire sprinkler systems for domestic  
and residential occupancies —  
Code of practice**

**bsi.**

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2021

Published by BSI Standards Limited 2021

ISBN 978 0 59 06716 3

ICS 3.22.20

The following BSI references relate to the work on this document:

Committee reference FSH/18/2

Draft for comment 20/30403871 DC

**Amendments/corrigenda issued since publication**

Date	Text affected
------	---------------

---

# Contents

	Page
<b>Foreword</b>	<b>iii</b>
0 Introduction	1
1 Scope	1
2 Normative references	2
3 Terms and definitions	3
<i>Figure 1 — Height of top storey in building</i>	4
4 Preliminary work and consultation	7
4.1 Initial considerations	7
4.2 Consultation	7
4.3 Category of system	10
<i>Table 1 — Category of system</i>	11
5 Design	11
5.1 General	11
5.2 System type	12
5.3 Design density and duration of supply	12
<i>Table 2 — Minimum design parameters</i>	13
5.4 Extent of sprinkler protection	14
5.5 Classification of residential and non-residential occupancies	14
<i>Table 3 — Examples of classification of areas and design criteria for areas protected with “Residential” BS EN 12259-14 sprinkler heads</i>	15
5.6 Ordinary hazard protected areas	16
<i>Table 4 — Examples of classification of areas and design criteria for areas to be protected with BS EN 12259-1 sprinkler heads</i>	17
5.7 Sprinkler coverage and positioning	17
<i>Figure 2 — Two examples of shadow areas (plan views)</i>	19
<i>Figure 3 — Bay windows and similar features</i>	19
5.8 Ceiling pockets	20
5.9 Residential pattern sprinkler heads	20
5.10 Hydraulic calculations	21
5.11 Water supplies	21
<i>Figure 4 — Stored water supply</i>	24
<i>Figure 5 — Examples of water volumes for various shared water supplies</i>	26
<i>Figure 6 — Typical shared pump and water supply with PDV</i>	27
5.12 Pumps	28
<i>Figure 7 — Typical power supply arrangement to sprinkler pump and ancillary equipment</i>	29
<i>Figure 8 — Enhanced water supply</i>	32
<i>Figure 9 — Examples of primary and secondary power supply configurations</i>	33
5.13 Pipes and fittings	33
5.14 Flexible sprinkler connection	34
5.15 Valves	35
5.16 Pressure reducing valves	35
5.17 Frost protection	36
5.18 Sprinkler system fire and fault alarm functionality	36
<i>Table 5 — Fault conditions to be monitored in category 2, 3 and 4 systems</i>	38
6 Installation, commissioning and documentation	39
6.1 Installation	39
6.2 Commissioning	41
6.3 Documentation	42

6.4	Block plan	43
6.5	System data label	43
6.6	Location plate	43
	<i>Figure 10 — Example of a location plate</i>	44
7	Maintenance	44
7.1	Inspecting and testing routines	44
7.2	Reinstatement of the system	45
7.3	Log book	45
<hr/>		
<b>Annex A</b>	<b>(informative) Elements of a typical residential sprinkler system</b>	<b>46</b>
	<i>Figure A.1 — Elements of a typical mains-fed sprinkler system</i>	46
	<i>Figure A.2 — Elements of a typical pump and tank sprinkler system</i>	47
	<i>Figure A.3 — Typical arrangement of a multi-storey building with shared water supply and shared riser</i>	48
	<i>Figure A.4 — Typical arrangement of a multi-storey building with shared water supply and dedicated sprinkler riser</i>	49
<hr/>		
<b>Annex B</b>	<b>(normative) Hydraulic calculations</b>	<b>50</b>
	<i>Table B.1 — C values for various type of pipes</i>	51
	<i>Table B.2 — K values for carbon steel tube conforming to BS EN 10255 Medium series</i>	51
	<i>Table B.3 — K values for CPVC conforming to ASTM F442</i>	51
	<i>Table B.4 — K values for copper tube conforming to BS EN 1057:2006 A1, half-hard, R250 designation</i>	51
	<i>Table B.5 — Typical equivalent lengths for steel fittings and valves</i>	52
	<i>Table B.6 — Typical equivalent lengths for CPVC fittings and valves</i>	53
	<i>Table B.7 — Typical equivalent lengths for copper fittings and valves</i>	53
	<i>Figure B.1 — Example of a square law graduation graph</i>	54
	<i>Figure B.2 — Blank template of a square law graduation graph</i>	55
	<i>Figure B.3 — Example sprinkler head layout scheme</i>	56
	<i>Table B.8 — Example data extracted from a typical sprinkler head manufacturers datasheet</i>	57
	<i>Table B.9 — Re-calculated parameters for BS 9251 application providing a minimum of 2.1 mm/min as required for BS 9251 category 1</i>	57
	<i>Table B.10 — Worked example actual coverage areas</i>	58
<hr/>		
<b>Annex C</b>	<b>(informative) Example of system data label</b>	<b>59</b>
	<i>Figure C.1 — System data label</i>	59
<hr/>		
<b>Annex D</b>	<b>(normative) Pipework support</b>	<b>60</b>
	<i>Table D.1 — Maximum spacing of fixings for copper and stainless steel pipework</i>	60
	<i>Table D.2 — Maximum spacing of fixings for steel pipework</i>	60
	<i>Table D.3 — Maximum spacing of fixings for CPVC pipework</i>	60
<hr/>		
<b>Annex E</b>	<b>(informative) Hydraulic test</b>	<b>61</b>
	<i>Figure E.1 — Test rig for hydraulic test</i>	62
<hr/>		
<b>Annex F</b>	<b>(normative) Long-term inspection and testing of pipework and sprinklers</b>	<b>62</b>
	<i>Table F.1 — Number of sprinklers to be removed and tested</i>	63
<hr/>		
	<b>Bibliography</b>	<b>64</b>
<hr/>		

### Summary of pages

This document comprises a front cover, and inside front cover, pages i to vi, pages 1 to 64, an inside back cover and a back cover.

## Foreword

### Publishing information

This British Standard is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 30 June 2021. It was prepared by Subcommittee FSH/18/2, *Sprinkler systems*, under the authority of Technical Committee FSH/18, *Fixed fire fighting systems*. A list of organizations represented on these committees can be obtained on request to their committee managers.

### Supersession

This British Standard supersedes [BS 9251:2014](#), which is withdrawn.

### Relationship with other publications

Reference is made in the publication to the advice on selection of fire protection systems set out in [BS 5306-0](#). Attention is also drawn to the requirements of [BS EN 806](#), with particular regard to backflow prevention, to BS EN 805 where appropriate, and to [BS 1710](#) for guidance on identification and marking of pipework. Where pumps are provided, attention is drawn to the electrical supply requirements of [BS 7671](#).

Sprinkler protection for industrial premises and commercial buildings other than those listed in this British Standard is specified in BS EN 12845. Where sprinklers are not installed primarily for life protection in domestic and residential occupancies, sprinkler installations conforming to BS EN 12845 might be more appropriate than those conforming to this British Standard.

Guidance on the application of sprinkler systems is given in [BS 5306-0](#), [BS 9991](#), [BS 9999](#), the Building Regulations 2010, Approved Document B for use in England [1], [2], Wales [3], [4] and its equivalents in Scotland [5], [6] and Northern Ireland [7].

BS 9251 covers fire sprinkler systems for residential and domestic premises that are more than four storeys or above 18 m in height; additionally fixed residential fire sprinkler systems in buildings for residential occupancies up to four storeys or 18 m in height, whichever are lower, are covered in [BS EN 16925](#). FSH/18/2 has detailed their concerns about [BS EN 16925](#) in the National Foreword for that publication.

### Information about this document

This is a full revision of the standard, and introduces the following principal changes.

- Introduction of a fourth category of system to cater for taller residential buildings (greater than 18 m) and higher risk scenarios. The building height of over 18 m for a fourth category was chosen for the following reasons:
  - to align with Fire and Rescue Service national operational guidance, which determines capability, e.g. access and response time;
  - for consistency with [BS EN 16925](#); and
  - greater risk profile in higher rise buildings, including the need for improved resilience.
- Additional recommendations for larger capacity minimum water supplies for taller buildings and higher risk scenarios.
- Further recommendations for duplicate pumps and other reliability enhancements in certain scenarios.

- Further recommendations for non-residential occupancies in protected buildings.
- Additional measures and information for the fire service to interact with the installation.
- Clarification of alarm and fault signalling requirements.
- Clarification of roles and responsibilities.

**Product certification/inspection/testing.** Users of this British Standard are advised to consider the desirability of third-party certification/inspection/testing of product conformity to this British Standard. Appropriate conformity attestation arrangements are described in BS EN ISO 9001. Users seeking assistance in identifying appropriate conformity assessment bodies or schemes may ask BSI to forward their enquiries to the relevant association.

**Test laboratory accreditation.** Users of this British Standard are advised to consider the desirability of selecting test laboratories that are accredited to BS EN ISO/IEC 17025 by a national or international accreditation body.

This publication can be withdrawn, revised, partially superseded or superseded. Information regarding the status of this publication can be found in the Standards Catalogue on the BSI website at [bsigroup.com/standards](http://bsigroup.com/standards), or by contacting the Customer Services team.

### Use of this document

As a code of practice, this British Standard takes the form of guidance and recommendations.

It should not be quoted as if it were a specification and particular care should be taken to ensure that claims of compliance are not misleading.

Any user claiming compliance with this British Standard is expected to be able to justify any course of action that deviates from its recommendations.

It has been assumed in the preparation of this British Standard that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

Where websites and webpages have been cited, they are provided for ease of reference and are correct at the time of publication. The location of a webpage or website, or its contents, cannot be guaranteed.

### Presentational conventions

The provisions of this standard are presented in roman (i.e. upright) type. Its recommendations are expressed in sentences in which the principal auxiliary verb is "should".

*Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.*

### Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

**Compliance with a British Standard cannot confer immunity from legal obligations.**

Particular attention is drawn to the Water Supply (Water Fittings) Regulations 1999 [8], the Water Supply (Water Fittings) (Scotland) Byelaws 2014 [9] and the Water Regulations (Northern Ireland) 2006 [10] in respect of requirements for any fire sprinkler system which conveys, or is likely to convey, water supplied by a water undertaker or licensed water supplier.

Currently in preview, click buy full version

## 0 Introduction

Sprinkler systems have demonstrated their value in protecting life and property in industrial and commercial applications for many years. The advent of sprinklers that operate at an earlier stage in the development of a fire, plus the recognition that the largest numbers of deaths from fire occur in the home, have led to the introduction of sprinkler systems specifically designed for domestic and residential occupancies.

A correctly designed and installed sprinkler system can detect and control a fire at an early stage of development and activate an alarm. Operation of the sprinkler system rapidly reduces the rate of production of heat and smoke, allowing more time for the occupants to escape to safety or be rescued.

Sprinkler systems can also assist firefighters in carrying out search and rescue operations by limiting fire development, which significantly reduces the risks to firefighters.

This British Standard accordingly covers design, installation, components, water supplies, maintenance and testing of residential sprinkler systems installed for the purpose of reducing risk to life and minimizing the spread of fire.

In classifying the design of the system for any specified occupancy, care needs to be taken when considering the fire loading such that it does not exceed that which would typically be expected in that occupancy.

Residential sprinkler systems consist of a water supply, backflow prevention device (e.g. check valve), stop valve, priority demand valve (where required), automatic alarm system and pipework to sprinkler heads. The sprinklers are fitted at specified locations, the appropriate sprinkler type being used for each location. The main elements of a typical residential sprinkler system are shown in [Annex A](#).

Sprinklers operate at a predetermined temperature to discharge water over a known area below. The flow of water initiated causes the actuation of an alarm. Only sprinkler heads individually heated above their operating temperature by the heat from the fire operate to discharge water.

The provision of a sprinkler system does not negate the need for other fire precautions or practical measures, which can include structural fire resistance, escape routes with emergency lighting and signs, fire detectors and good fire safety management practices. Even with the installation of a sprinkler system, normal actions on the discovery of a fire need to be taken, such as immediate evacuation and the calling of the fire service. The sprinkler system is typically only to be turned off following liaison with the fire and rescue service and when it is deemed safe to do so.

Sprinkler system maintenance is not complex but is essential (see [Clause 7](#)). It is important that owners and occupants are provided with adequate information.

## 1 Scope

This British Standard gives recommendations for the design, installation, components, water supplies and backflow protection, commissioning, maintenance and testing of fire sprinkler systems installed for life safety purposes in residential and domestic premises.

*NOTE 1 Sprinkler systems also provide additional benefits for property protection and prevention of fire spread.*

This British Standard is applicable for sprinkler protection of domestic and residential premises and contains specific recommendations for sprinkler systems in those premises of more than four storeys or above 18 m in height.

*NOTE 2 Unless otherwise specified, references to residential sprinkler system in this British Standard include domestic sprinkler systems.*