



BSI Standards Publication

Low-voltage fuses

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application)

— Examples of standardized systems of fuses A to K

National foreword

This British Standard is the UK implementation of HD 60269-2:2013+A1:2022. It is derived from IEC 60269-2:2013, incorporating amendment 1:2016. It supersedes BS HD 60269-2:2013, which is withdrawn.

The CENELEC common modifications have been implemented at the appropriate places in the text. The start and finish of each common modification is indicated in the text by tags **[C]** **[C]**.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to IEC text carry the number of the IEC amendment. For example, text altered by IEC amendment 1 is indicated by **[A1]** **[A1]**.

This standard covers the following British Fuse systems that are included in BS HD 60269-2:2013 (BS 88-2:2013):

Fuse system E — Fuses with fuse-links for bolted connections (BS bolted fuse system)

Fuse system G — Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)

Fuse system I — gU fuse-links with wedge tightening contacts

This standard is part of a series of British Standards for Low Voltage Fuses. These cover the related parts and examples of systems of fuses in the associated IEC 60269 series of standards.

These British Standards together with their IEC counterparts are:
BS EN 60269-1:2009+A1:2009 (BS 88-1:2007) — General requirements (IEC 60269-1)

BS HD 60269-2:2013 (BS 88-2:2013) — Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) (IEC 60269-2, Fuse systems E, G and I)

BS HD 60269-3:2010 (BS 88-3:2010) — Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications) (IEC 60269-3, Fuse system C)

BS EN 60269-4:2009+A1:2012 (BS 88-4:2009+A1:2012) — Supplementary requirements for fuse-links for the protection of semiconductor devices (IEC 60269-4)

PD IEC/TR 60269-5:2010 (PD 88-5:2010) — Guidance for the application of low voltage fuses (IEC/TR 60269-5:2010)

BS EN 60269-6:2011 — Supplementary requirements for fuse-links for the protection of solar photovoltaic energy system (IEC 60269-6:2010).

The text for BS HD 60269-2:2013/BS 88-2:2013 has been extracted from IEC 60269-2:2013 and is identical to the text for sections E, G, and I. However, wherever a reference is made to IEC 60269-1 in the text this should be taken as a reference to BS EN 60269-1 (BS 88-1).

The UK participation in its preparation was entrusted to Technical Committee PEL/32, Fuses.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 580 89293 6

ICS 29.120.50

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2013.

Amendments/corrigenda issued since publication

Date	Text affected
31 March 2014	Standard amended to only include fuses E, G and I
28 February 2023	Implementation of EC amendment 1:2016 with CENELEC endorsement A1:2022

HARMONIZATION DOCUMENT

HD 60269-2+A1

DOCUMENT D'HARMONISATION

HARMONISIERUNGSDOKUMENT

November 2022

ICS 29.120.50

English version

**Low-voltage fuses -
Part 2: Supplementary requirements for fuses for use by authorized
persons (fuses mainly for industrial application) -
Examples of standardized systems of fuses A to K
(IEC 60269-2:2013, modified)**

Fusibles basse tension -
Partie 2: Exigences supplémentaires pour
les fusibles destinés à être utilisés par des
personnes habilitées (fusibles pour
usages essentiellement industriels) -
Exemples de systèmes de fusibles
normalisés A à K
(CEI 60269-2:2013, modifiée)

Niederspannungssicherungen -
Teil 2: Zusätzliche Anforderungen an
Sicherungen für den Gebrauch durch
Elektrofachkräfte bzw. elektrotechnisch
unterwiesene Personen (Sicherungen
überwiegend für den industriellen
Gebrauch) -
Beispiele für genormte
Sicherungssysteme A bis K
(IEC 60269-2:2013, modifiziert)

This Harmonization Document was approved by CENELEC on 2013-08-15. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 32B/611/FDIS, future edition 5 of IEC 60269-2:2013, prepared by SC 32B, "Low-voltage fuses", of IEC/TC 32, "Fuses" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as HD 60269-2:2013.

A draft amendment, which covers common modifications to IEC 60269-2:2013, was prepared by CLC/SR 32B "Low-voltage fuses" and approved by CENELEC.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-08-15
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2010-08-15

This document supersedes HD 60269-2:2010.

HD 60269-2:2013 includes the following significant technical changes with respect to HD 60269-2:2010:

- a) fuse systems A and B: modified values for the power dissipation of NH aM fuse-links;
- b) fuse systems A and B: introduction of dimension r for NH fuse-links;
- c) addition of new fuse system K: gK fuse-links with contacts for bolted connections.

This part is to be used in conjunction with EN 60269-1:2007 + A1:2009, *Low-voltage fuses – Part 1: General requirements*.

This Part 2 supplements or modifies the corresponding clauses or subclauses of Part 1.

Where no change is necessary, this Part 2 indicates that the relevant clause or subclause applies.

Tables and figures which are additional to those in Part 1 are numbered starting from 101 in fuse system A, from 201 in fuse system B, etc. Additional annexes are numbered AA, BB, etc.

Clauses, subclauses, notes, tables, figures and annexes which are additional to those in IEC 60269-2:2013 are prefixed "7".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC and/or CEN shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

Endorsement notice

The text of the International Standard IEC 60269-2:2013 was approved by CENELEC as a Harmonisation Document with agreed common modifications.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60060-1	NOTE	Harmonised as EN 60060-1.
IEC 60060-2	NOTE	Harmonised as EN 60060-2.
IEC 60060-3	NOTE	Harmonised as EN 60060-3.
IEC 60529	NOTE	Harmonised as EN 60529.
IEC 60672-1	NOTE	Harmonised as EN 60672-1.
IEC 60672-2	NOTE	Harmonised as EN 60672-2.
IEC 60672-3	NOTE	Harmonised as EN 60672-3.
IEC 62262	NOTE	Harmonised as EN 62262.
ISO 898-1	NOTE	Harmonised as EN ISO 898-1.
ISO 1207	NOTE	Harmonised as EN ISO 1207.
ISO 4589-1	NOTE	Harmonised as EN ISO 4589-1.

European foreword to Amendment 1

The text of document 32B/641/CDV, future IEC 60269-2/A1, prepared by SC 32B "Low-voltage fuses" of IEC/TC 32 "Fuses" was submitted to the IEC/CENELEC parallel vote and approved by CENELEC as HD 60269-2:2013/A1:2022.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2023-05-11
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2025-11-11

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any inquiries and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Endorsement notice to Amendment 1

The text of the International Standard IEC 60269-2:2013/A1:2016 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (n.d.), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60112	-	Method for the determination of the proof and the comparative tracking indices of solid insulating materials	EN 60112	-
IEC 60269-1	-	Low-voltage fuses Part 1: General requirements	EN 60269-1	-
IEC 60664-1	-	Insulation coordination for equipment with low-voltage systems Part 1: Principles, requirements and test procedures	EN 60664-1	-
IEC 60999	Series	Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units	EN 60999	Series
IEC 60999-1	-	Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm ² up to 35 mm ² (included)	EN 60999-1	-
IEC 60999-2	-	Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units Part 2: Particular requirements for clamping units for conductors above 35 mm ² up to 300 mm ² (included)	EN 60999-2	-
ISO 6988	-	Metallic and other non-organic coatings - Sulfur dioxide test with general condensation of moisture	EN ISO 6988	-

CONTENTS

INTRODUCTION.....	9
1 General scope.....	10
1.1 Scope.....	10
1.2 Normative references.....	11
Fuse system E – Fuses with fuse-links for bolted connections (BS bolted fuse system)	12
1 General.....	12
1.1 Scope.....	12
2 Terms and definitions.....	12
3 Conditions for operation in service.....	12
4 Classification.....	12
5 Characteristics of fuses.....	12
5.3.1 Rated current of the fuse-link.....	12
5.3.2 Rated current of the fuse-holder.....	12
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder.....	13
5.6 Limits of time-current characteristics.....	13
5.6.1 Time-current characteristics, time-current zones and overload curves.....	13
5.6.2 Conventional times and currents.....	13
5.6.3 Gates.....	13
5.7.2 Rated breaking capacity.....	13
6 Markings.....	13
6.1 Markings of fuse-holders.....	14
6.2 Markings of fuse-links.....	14
7 Standard conditions for construction.....	14
7.1 Mechanical design.....	14
7.1.2 Connections including terminals.....	14
7.2 Insulating properties and suitability for insulation.....	14
7.9 Protection against electric shock.....	14
8 Tests.....	14
8.3 Verification of temperature rise and power dissipation.....	14
8.3.1 Arrangement of the fuse.....	14
8.3.2 Measurement of the power dissipation of the fuse-link.....	14
8.4 Verification of operation.....	15
8.4.1 Arrangement of the fuse.....	15
8.5 Verification of breaking capacity.....	15
8.5.1 Arrangement of the fuse.....	15
8.5.8 Acceptability of test results.....	15
8.9 Verification of resistance to heat.....	15
8.10 Verification of non-deterioration of contacts.....	15
8.10.1 Arrangement of the fuse.....	15
8.10.2 Test method.....	15
8.10.3 Acceptability of the results.....	16
8.11 Mechanical and miscellaneous tests.....	16
FIGURES.....	17

Fuse system G – Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)	26
1 General	26
1.1 Scope	26
2 Terms and definitions	26
3 Conditions for operation in service	26
4 Classification	26
5 Characteristics of fuses	26
5.2 Rated voltage	27
5.3.1 Rated current of the fuse-link	27
5.3.2 Rated current of the fuse-holder	27
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	27
5.6.1 Time-current characteristics, time-current zones	27
5.6.2 Conventional times and currents	27
5.6.3 Gates	27
5.7.2 Rated breaking capacity	28
6 Markings	28
6.1 Markings of fuse-holders	28
6.2 Markings of fuse-links	28
7 Standard conditions for construction	28
7.1 Mechanical design	28
7.1.2 Connections including terminals	28
7.2 Insulating properties and suitability for insulation	29
7.7 I^2t characteristics	29
7.9 Protection against electric shock	29
8 Tests	29
8.3.3 Measurement of the power dissipation of the fuse-link	29
8.4.1 Arrangement of the fuse	30
8.5.1 Arrangement of the fuse	30
8.7.4 Verification of overcurrent discrimination	30
8.9 Verification of resistance to heat	30
8.10 Verification of non-deterioration of contacts	30
8.10.1 Arrangement of the fuse	30
8.10.2 Test method	31
8.10.3 Acceptability of test results	31
8.11 Mechanical and miscellaneous tests	31
FIGURE	32
Fuse system I – gU fuse-links with wedge tightening contacts	37
1 General	37
1.1 Scope	37
2 Terms and definitions	37
3 Conditions for operation in service	38
3.9 Discrimination of fuse-links	38
4 Classification	38

5	Characteristics of fuses	38
5.2	Rated voltage	38
5.3.1	Rated current of the fuse-link.....	38
5.5	Rated power dissipation of a fuse-link	38
5.6.1	Time-current characteristics, time-current zones	38
5.6.2	Conventional times and currents.....	39
5.6.3	Gates	39
5.7.2	Rated breaking capacity	39
5.8	Cut-off current and I^2t characteristics.....	39
6	Markings	39
6.1	Markings of fuse-holders	39
6.2	Markings of fuse-links.....	39
7	Standard conditions for construction.....	39
7.1	Mechanical design.....	39
7.2	Insulating properties and suitability for insulation	39
7.5	Breaking capacity.....	39
7.7	I^2t characteristics.....	40
7.8	Overcurrent discrimination of the fuse-links.....	40
8	Tests	40
8.1.1	Kind of tests	40
8.3.1	Arrangement of the fuse	40
8.3.3	Measurement of the power dissipation of the fuse-link.....	41
8.4.1	Arrangement of the fuse	41
8.5.1	Arrangement of the fuse	41
8.5.2	Characteristics of the test circuit.....	41
8.5.5	Test method	41
8.5.8	Acceptability of test results.....	41
8.7.3	Verification of compliance for fuse-links at 0,01 s	42
8.9	Verification of resistance to heat	42
8.11	Mechanical and miscellaneous tests.....	42
	FIGURES	43
	Bibliography.....	51
	Figure 501 – Fuse-link for bolted connection – Sizes A, B, C and D (1 of 2).....	17
	Figure 502 – Typical fuse-holder (1 of 2).....	19
	Figure 503 – Time-current zones for "gG" fuse-link.....	21
	Figure 504 – Time-current zones for "gG" fuse-link.....	22
	Figure 505 – Power dissipation test rig	23
	Figure 506 – Breaking capacity test rig for fuse-links for bolted connection (1 of 2)	24
	Figure 701 – Fuse-links having offset blade contacts, sizes E1, F1, F2 and F3.....	32
	Figure 702 – Typical fuse-holder.....	33
	Figure 703 – Time-current zones for "gG" fuse-links	34
	Figure 704 – Time-current zones for "gG" fuse-links	35
	Figure 705 – Power dissipation test rig	36

Figure 901 – Time-current zones for current ratings 100 A, 200 A, 355 A and 630 A.....	43
Figure 902 – Time-current zones for current ratings 160 A and 315 A.....	44
Figure 903 – Time-current zones for current ratings 250 A and 500 A.....	45
Figure 904 – Time-current zones for current ratings 200 A and 400 A.....	46
Figure 905 – Dimensions for fuse-links with L type and U type tags.....	47
Figure 906 – Power dissipation test rig.....	48
Figure 907 – Breaking capacity test rig (1 of 2).....	49
Table 501 – Conventional time and current for "gG" fuse-links.....	13
Table 502 – Gates for specified pre-arcing times of "gG" fuse-links.....	13
Table 701 – Conventional time and current for "gG" fuse-links.....	27
Table 702 – Gates for specified pre-arcing times of "gG" fuse-links.....	28
Table 703 – Sizes of copper conductors.....	29
Table 704 – Pre-arcing I^2t values at 0,01 s for "gG" fuse-links.....	29
Table 901 – Maximum power dissipation values.....	38
Table 902 – Pre-arcing I^2t values for gU fuse-links at 0,01 s.....	40
Table 903 – Cross-sectional area of conductors for power dissipation and temperature-rise tests.....	41

INTRODUCTION

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

- Part 1: General requirements
- Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K
- Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F
- Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices
- Part 5: Guidance for the application of low-voltage fuses
- Part 6: Supplementary requirements for fuse-links for the protection of solar photovoltaic energy systems

LOW-VOLTAGE FUSES –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

1 General scope

1.1 Scope

Fuses for use by authorized persons are generally designed to be used in installations where the fuse-links are accessible to, and may be replaced by, authorized persons only.

Fuses for use by authorized persons according to the following fuse systems also comply with the requirements of the corresponding subclauses of IEC 60269-1, unless otherwise defined in this standard.

This standard is divided into fuse systems, each dealing with a specific example of standardized fuses for use by authorized persons:

- Fuse system A: Fuses with fuse-links with blade contacts (NH fuse system)
- Fuse system B: Fuses with striker fuse-links with blade contacts (NH fuse system)
- Fuse system C: Fuse-rails (NH fuse system)
- Fuse system D: Fuse-bases for busbar mounting (NH fuse system)
- Fuse system E: Fuses with fuse-links for bolted connections (BS bolted fuse system)
- Fuse system F: Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)
- Fuse system G: Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)
- Fuse system H: Fuses with fuse-links having "gD" and "gN" characteristic (class J and class L A_1 and class T time delay and non time delay fuse types) A_1
- Fuse system I: gU fuse-links with wedge tightening contacts
- Fuse system J: Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types)
- Fuse system K: gK fuse-links with blade for bolted connections – High fuse-link ratings from 1 250 A up to 4 800 A (master fuse-links)

C The following fuse systems are standardized systems in respect to their safety aspects. The National Committees shall select at least one complete fuse system of this European Standard for their national standards. The time current characteristics "gD" and "gN" are only relevant for the fuse system H. C