



BSI Standards Publication

## Application of fire safety engineering principles to the design of buildings –

Part 2: Spread of smoke and toxic gases within and beyond the enclosure of origin (Sub-system 2)

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2019

Published by BSI Standards Limited 2019

ISBN 978 0 50 96777 1

ICS 3.22.20, 91.040.01

The following BSI references relate to the work on this document:

Committee reference FSH/24

Draft for comment 18/30379981 DC

**Amendments/corrigenda issued since publication**

Date	Text affected
------	---------------

---

## Contents

	Page
<b>Foreword</b>	<b>ii</b>
0 Introduction	1
1 Scope	1
2 Normative references	1
3 Terms, definitions and symbols	1
4 Design considerations	7
<i>Figure 1 — Stages for the analysis of smoke and toxic gases within and beyond the enclosure of origin</i>	8
5 Calculation procedures and the role of computer simulation modelling	14
6 Design procedure	15
7 Analysis	17
<i>Figure 2 — Schematic showing location of virtual source for calculation of smoke mass flow rate in "far field"</i>	19
<i>Figure 3 — Schematic showing smoke stratifying before reaching ceiling in an ambient environment where air temperature is elevated at ceiling level</i>	23
<i>Figure 4 — Flow from a room opening</i>	26
<i>Figure 5 — Entrainment between the fire compartment opening and the plume edge</i>	27
<i>Figure 6 — Three-dimensional adhered spill plume</i>	29
<i>Figure 7 — Three-dimensional channelled balcony spill plume</i>	32
<i>Figure 8 — Smoke contamination of upper balconies in atria</i>	34
8 Data	43
<i>Table 1 — Fraction of chemical heat release from some materials convected by plume in well-ventilated fires</i>	43
<i>Table 2 — Smoke mass conversion factor</i>	44
<i>Table 3 — Ranges of carbon monoxide yields, smoke particulate yields, smoke-specific extinction areas and mass optical densities for cellulose and plastic under well-ventilated and under ventilated flaming combustion</i>	45
<i>Table 4 — Carbon monoxide yields, smoke particulate yields, smoke-specific extinction areas and mass optical densities for well-ventilated combustion</i>	45
<b>Bibliography</b>	<b>46</b>

### Summary of pages

This document comprises a front cover, and inside front cover, pages i to iv, pages 1 to 50, an inside back cover and a back cover.

---

## Foreword

### Publishing information

This Published Document is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 31 March 2019. It was prepared by Technical Committee FSH/24, *Fire safety engineering*. A list of organizations represented on this committee can be obtained on request to its secretary.

### Supersession

This Published Document supersedes PD 7974-2:2002, which is withdrawn.

### Relationship with other publications

This Published Document is one of a series of documents published under the Fire Standards Policy Committee, and is a supporting document to BS 7974, *Application of fire safety engineering principles to the design of buildings — Code of practice*.

Other documents in the series are:

PD 7974-1: *Initiation and development of fire within the enclosure of origin*;

PD 7974-3: *Structural response to fire and fire spread beyond the enclosure of origin*;

PD 7974-4: *Detection of fire and activation of fire suppression systems*;

PD 7974-5: *Fire service intervention*;

PD 7974-6: *Evacuation*;

PD 7974-7: *Probabilistic risk assessment*;

Where appropriate, references to relevant standards are provided in order to assist the reader in understanding the design methodology presented and to compare different approaches or sources of data. It is therefore important that PD 7974-2 is not used in isolation and reference is made to the relevant standards, particularly in relation to additional notes and subclauses describing its application.

### Information about this document

This is a full revision of the document, and introduces the following principal changes:

- greater clarity regarding smoke control design principles, application and procedures;
- new information on the practical application of natural and mechanical smoke control, and the use of smoke barriers;
- rationalization of guidance on computer simulation modelling principles, as the intent of this guide is smoke control rather than computer fire modelling;
- where practicable, explicit acknowledgements of the inherent assumptions and limitations of underpinning design correlations;
- revised and new correlations with respect to spill plumes and the axisymmetric plume;
- new figures to aid the correct use of design correlations;
- calculation of smoke detection time for activating smoke control;
- greater clarity on design considerations for smoke reservoir size, and the interaction between sprinklers/smoke ventilation; and

- improved reference data for smoke and toxic gas yields.

### **Use of this document**

As a guide, this Published Document takes the form of guidance and recommendations. It should not be quoted as if it were a specification or a code of practice and claims of compliance cannot be made to it.

This publication is not to be regarded as a British Standard.

### **Presentational conventions**

The guidance in this Published Document is presented in roman (i.e. upright) type. Any recommendations are expressed in sentences in which the principal auxiliary verb is “should”.

*Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.*

### **Contractual and legal considerations**

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

**Compliance with a Published Document cannot confer immunity from legal obligations.**

Currently in preview, click buy full version

## 0 Introduction

This Published Document (PD) is one of a series of documents intended to support BS 7974. It provides a framework for developing a rational methodology for design using a fire safety engineering approach through the application of scientific and engineering principles to the protection of people, property and the environment from fire.

This PD contains guidance and information on how to undertake quantitative analysis for smoke control. This PD is a summary of the latest knowledge and techniques and it does not preclude the use of appropriate methods and data from other sources.

When used by suitably qualified persons, experienced in fire safety engineering, this PD provides a means of establishing acceptable levels of fire safety economically and without imposing unrealistic constraints on aspects of building design.

Sub-system 1 (see PD 7974-1) provides information on the rate of production of heat and combustion products from the fire source. The aim of sub-system 2 is to provide design approaches to estimate the spread of the combustion gases within and beyond the room of origin and to evaluate their properties, i.e. temperature, visibility and concentration of toxic products.

This PD forms part of a series of Sub-systems 1 to 6 (see PD 7974-1 to PD 7974-6), but may, in consultation with the appropriate references, be regarded as “stand-alone” guidance.

PD 7974-4 has now been withdrawn; it provided guidance on the detection of fire and activation of fire protection systems. This guidance is now included in the various parts of the PD 7974 series and other standards covering the subject. PD 7974-4 is referred to as part of the PD 7974 series for the sake of completeness but is no longer maintained as a current document.

## 1 Scope

This Published Document provides guidance on the application of fire safety engineering principles for the treatment of smoke movement, control and management problems. The guidance is intended primarily for professional engineers with a responsibility for the design or assessment of fire safety in buildings.

## 2 Normative references

There are no normative references in this document.

## 3 Terms, definitions and symbols

For the purpose of this part of PD 7974, the following terms and definitions apply.

### 3.1 Terms and definitions

#### 3.1.1 aerodynamic free area

product of the geometric area and the discharge coefficient

[SOURCE: BS 7346-4:2003, 3.1.2]

#### 3.1.2 air entrainment

mixing of ambient air into a jet or plume