



BSI Standards Publication

Application of fire safety engineering principles to the design of buildings –

Part 7: Probabilistic risk assessment

Publishing and copyright information

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2019

Published by BSI Standards Limited 2019

ISBN 978 0 50 98926 1

ICS 3.22.20, 91.040.01

The following BSI references relate to the work on this document:

Committee reference FSH/24

Draft for comment 18/30362215 DC

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

Contents

	Page
Foreword	ii
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Design approach	3
<i>Figure 1 — Flowchart for demonstrating adequate safety of a design</i>	5
<i>Figure 2 — General flowchart for design assessment using PRA methods</i>	6
<i>Figure 3 — Consolidated flowchart for a design through PRA</i>	8
5 Acceptance criteria	9
<i>Figure 4 — One-dimensional representation of generalized consequence-frequency (FC)</i>	9
<i>Figure 5 — Generalized consequence-frequency (FC) diagram with indication of tolerability limit and negligible limit</i>	11
<i>Figure 6 — Flowchart to determine the applicable PRA acceptance criteria for demonstrating adequate safety</i>	12
<i>Figure 7 — FN diagram (cumulative exceedance frequency versus number of casualties)</i>	13
6 Analysis methods	23
<i>Table 1 — Summary of discussed methods and main characteristics</i>	24
<i>Figure 8 — Event tree analysis</i>	26
<i>Figure 9 — Fault tree analysis</i>	26
<i>Figure 10 — Example of typical uncertainty distribution</i>	32
<i>Figure 11 — Example of Tornado Chart Showing Contribution to Variance</i>	33
7 Data collection for PRA	34
Annex A (informative) Acceptance and tolerability criteria	35
<i>Table A.1 — Individual risk limits</i>	35
<i>Table A.2 — Parameters and valuation of benchmark proportionality constant $SCCR_{11life}$</i>	35
Annex B (informative) Indicative probabilities	35
<i>Table B.1 — Sprinkler reliability by occupancy based on USA experience</i>	36
<i>Table B.2 — Sprinkler effectiveness by occupancy based on NZ experience</i>	36
<i>Table B.3 — Overall probability of fire starting in various types of occupancy</i>	36
<i>Table B.4 — Fire growth rate distributions</i>	37
<i>Table B.5 — Fire load energy density for various types of occupancy</i>	37
<i>Table B.6 — System effectiveness</i>	38
<i>Table B.7 — Extent of Damage in USA Fire Incidents, 1989-1994</i>	38
Annex C (informative) Commentary on acceptance criteria	39
<i>Figure C.1 — Acceptability criteria</i>	39
Bibliography	44

Summary of pages

This document comprises a front cover, and inside front cover, pages i to iv, pages 1 to 45, an inside back cover and a back cover.

Foreword

Publishing information

This Published Document is published by BSI Standards Limited, under licence from The British Standards Institution, and came into effect on 31 March 2019. It was prepared by Technical Committee FSH/24, *Fire safety engineering*. A list of organizations represented on this committee can be obtained on request to its secretary.

Supersession

This Published Document supersedes PD 7974-7:2003, which is withdrawn.

Relationship with other publications

This Published Document is one of a series of documents published under the Fire Standards Policy Committee, and is a supporting document to BS 7974, *Application of fire safety engineering principles to the design of buildings — Code of practice*.

Other documents in the series are:

PD 7974-1: *Initiation and development of fire within the enclosure of origin;*

PD 7974-2: *Spread of smoke and toxic gases within and beyond the enclosure of origin;*

PD 7974-3: *Structural response to fire and fire spread beyond the enclosure of origin ;*

PD 7974-4: *Detection of fire and activation of fire suppression systems;*

PD 7974-5: *Fire service intervention;*

PD 7974-6: *Evacuation;*

Where appropriate, references to relevant standards are provided in order to assist the reader in understanding the design methodology presented and to compare different approaches or sources of data. It is therefore important that PD 7974-7 is not used in isolation and reference is made to the relevant standards, particularly in relation to additional notes and subclauses describing its application.

Use of this document

As a guide, this Published Document takes the form of guidance and recommendations. It should not be quoted as if it were a specification or a code of practice and claims of compliance cannot be made to it.

It has been assumed in the preparation of this Published Document that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

This publication is not to be regarded as a British Standard.

Presentational conventions

The guidance in this Published Document is presented in roman (i.e. upright) type. Any recommendations are expressed in sentences in which the principal auxiliary verb is “should”.

Commentary, explanation and general informative material is presented in smaller italic type, and does not constitute a normative element.

Where words have alternative spellings, the preferred spelling of The Shorter Oxford English Dictionary is used (e.g. “organization” rather than “organisation”).

Contractual and legal considerations

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

Currently in preview, click buy full version

Currently in preview, click buy full version

1 Scope

This Published Document provides guidance on probabilistic risk analysis in support of BS 7974. It sets out the situations in which a probabilistic risk assessment can add value to traditional deterministic analyses and outlines acceptance criteria for the assessment. Furthermore, common analysis techniques of probabilistic risk assessment are summarily discussed.

This Published Document also includes data for probabilistic risk assessment based on fire statistics, building characteristics and reliability of fire protection systems.

This Published Document does not contain guidance on techniques for hazard identification or qualitative risk analysis.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this Published Document, the following terms and definitions apply.

3.1 As Low As Reasonably Practicable (ALARP)

where all reasonable measures are taken in respect of risks to reduce them further until the cost of further risk reduction is grossly disproportionate to the benefit

3.2 assessment

undertaking of an investigation in order to arrive at a judgement based on evidence

3.3 availability

ability of a system to be in a state to perform a required function under given conditions at a given instant of time or over a given time interval, assuming that the required external resources are provided

3.4 conditional probability

probability of an event given the occurrence of a preceding event

3.5 consequences

severity of the outcome of an event

3.6 deterministic

based on physical relationships derived from scientific theories and empirical results that, for a given set of initial conditions, always produce the same outcome

3.7 event

something happening or that has happened that can be made up of several but mutually exclusive occurrences

3.8 failure mode

predicted or observed results of a failure cause on a stated item in relation to the operating conditions at the time of the failure