



BSI Standards Publication

Test method to measure the efficiency of air filtration media against spherical nanomaterials

Part 2: Size range from 3 nm to 30 nm

National foreword

This Published Document is the UK implementation of CEN ISO/TS 21083-2:2019.

The UK participation in its preparation was entrusted to Technical Committee MCE/21, Filters for gases and liquids.

A list of organizations represented on this committee can be obtained on request to its secretary.

BSI, as a member of CEN, is obliged to publish CEN ISO/TS 21083-2:2019 as a Published Document. However, attention is drawn to the fact that during the development of this Technical Specification, the UK committee voted against its approval.

The UK committee raised concerns at the voting stage that there were a number of errors in the Technical Specification. The main concerns are as follows.

Figure 3 contains a labelling discrepancy (sheet number [labelled 1 in the key] should be between 2 and 3 in the diagram). Users are advised to refer to Figure E.3 of BS ISO 15900:2009 for clarification.

Table 11 uses the symbol Z for filtration efficiency; elsewhere in the document the symbol used is E.

The safety guidance in Annexes C and D is too brief.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 300 95178 7

ICS 91.10.30

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 September 2019.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

ICS 91.140.30

English Version

Test method to measure the efficiency of air filtration
media against spherical nanomaterials - Part 2: Size
range from 3 nm to 30 nm (ISO/TS 21083-2:2019)

Méthode d'essai pour mesurer l'efficacité des médias
de filtration d'air par rapport aux nanomatériaux

sphériques - Partie 2: Spectre granulométrique
de 3 nm à 30 nm (ISO/TS 21083-2:2019)

This Technical Specification (CEN/TS) was approved by CEN on 1 April 2019 for provisional application.

The period of validity of this CEN/TS is limited initially to three years. After two years, the members of CEN will be requested to submit their comments, particularly on the question whether the CEN/TS can be converted into a European Standard.

CEN members are required to announce the existence of this CEN/TS in the same way as for an EN and to make the CEN/TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force (in parallel to the CEN/TS) until the final decision about the possible conversion of the CEN/TS into an EN is reached.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

This document (CEN ISO/TS 21083-2:2019) has been prepared by Technical Committee ISO/TC 142 "Cleaning equipment for air and other gases" in collaboration with Technical Committee CEN/TC 195 "Air filters for general air cleaning" the secretariat of which is held by UNI.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this Technical Specification: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO/TS 21083-2:2019 has been approved by CEN as CEN ISO/TS 21083-2:2019 without any modification.

Contents

Page

Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms, definitions, symbols and abbreviated terms	1
3.1 Terms and definitions.....	1
3.2 Symbols and abbreviated terms.....	2
3.2.1 Symbols.....	2
3.2.2 Abbreviated terms.....	3
4 Principle	3
5 Test materials	4
5.1 General.....	4
5.2 Solid phase aerosol — Silver test aerosol as an example.....	4
5.3 Solid phase aerosol generation method.....	4
6 Test setup	5
6.1 General.....	5
6.2 Specifications of setup.....	7
6.2.1 Aerosol generation system.....	7
6.2.2 Tubing.....	7
6.2.3 DEMC.....	7
6.2.4 Equilibrium charge distribution and neutralization of aerosol particles.....	9
6.2.5 Neutralization of aerosol particles.....	10
6.2.6 Make-up air line.....	12
6.2.7 Test filter mounting assembly.....	12
6.2.8 CPC.....	13
6.2.9 Final filter.....	15
6.3 Detailed setup for test using silver nanoparticles.....	15
6.4 Determination of the filter medium velocity.....	16
7 Qualification of the test rig and apparatus	16
7.1 CPC tests.....	16
7.1.1 CPC — Air flow rate stability test.....	16
7.1.2 CPC — Zero test.....	17
7.1.3 CPC — Overload test.....	17
7.1.4 Counting accuracy calibration.....	18
7.2 DEMC tests.....	20
7.3 Qualification of aerosol neutralization.....	20
7.3.1 General.....	20
7.3.2 Qualification of neutralization by checking the multiple charge fraction on the particles passing through the neutralizer.....	20
7.3.3 Qualification of the aerosol neutralizer using corona discharge balanced output.....	21
7.3.4 Qualification of neutralization according to ISO/TS 19713-1.....	21
7.4 System leak checks.....	22
7.4.1 Air leakage tests.....	22
7.4.2 Visual detection by cold smoke.....	22
7.4.3 Pressurization of the test system.....	22
7.4.4 Use of high efficiency filter media.....	22
7.5 Uniformity of the test aerosol concentration.....	22
8 Test procedure	22
8.1 Determination of the correlation ratio.....	22
8.2 Protocol of filtration efficiency measurement.....	24

8.2.1	Preparatory checks	24
8.2.2	Equipment preparation	24
8.2.3	Aerosol generator	24
8.2.4	Aerosol generator — Neutralizer	25
8.2.5	Filter medium neutralization	26
8.2.6	Filter medium neutralization according to ISO 29461-1	26
8.2.7	Air flow measurement	28
8.2.8	Measurement of the pressure drop	29
8.2.9	Zero count test	29
8.2.10	Air leakage test	29
8.2.11	Loading effect test	29
8.2.12	Reported values	29
8.2.13	Measurement of filtration efficiency — Silver nanoparticles	29
8.3	Test evaluation	31
8.4	Measurement protocol for one sample — Summary	31
8.4.1	Using one CPC to measure the upstream and downstream particle concentrations	31
8.4.2	Using two CPCs to measure the upstream and downstream particle concentrations	32
9	Maintenance items	33
10	Measurement uncertainties	34
11	Reporting results	34
11.1	General	34
11.2	Required reporting elements	35
11.2.1	General	35
11.2.2	Report summary	35
11.2.3	Report details	36
Annex A (informative)	Instruments specifications	41
Annex B (informative)	Statistical analysis for precision of an experiment (according to ISO 5725-2)	44
Annex C (informative)	Safety use of IPA	49
Annex D (informative)	Safe handling of radioactive devices	50
Bibliography		51

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 195, *Air filters for general cleaning*, in collaboration with ISO Technical Committee TC 142, *Cleaning equipment for air and other gases*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

A list of all parts in the ISO 21083 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Nano-objects are discrete piece of material with one, two or three external dimensions in the nanoscale (see ISO/TS 80004-2) and are building blocks of nanomaterials. Nanoparticles, referring to particles with at least one dimension below 100 nm, generally have a higher mobility than larger particles. Because of their higher mobility and larger specific surface area, available for surface chemical reactions, they can pose a more serious health risk than larger particles. Thus, particulate air pollution with large concentrations of nanoparticles can result in an increased adverse effect on human health and an increased mortality (see Reference [15]).

With the increased focus on nanomaterials and nanoparticles, the filtration of airborne nanoparticles is also subject to growing attention. Aerosol filtration can be used in diverse applications, such as air pollution control, emission reduction, respiratory protection for human and processing of hazardous materials. The filter efficiency can be determined by measuring the testing particle concentrations upstream and downstream of the filter. The particle concentration may be based on mass, surface area or number. Among these, the number concentration is the most sensitive parameter for nanoparticles measurement. State-of-the-art instruments enable accurate measurement of the particle number concentration in air and therefore precise fractional filtration efficiency. Understanding filtration efficiency for nanoparticles is crucial in schemes to remove nanoparticles, and thus, in a wider context, improve the general quality of the environment, including the working environment.

Filtration testing for nanoparticles, especially those down to single-digit nanometres, is a challenging task which necessitates generation of a large amount of extremely small particles, and accurate sizing and quantification of such particles. The thermal rebound remains a question for particles down to 1 nm to 2 nm (see Reference [11]). The accuracy of particle size classification is complicated by very strong diffusion of particles below 10 nm (see References [7] and [10]). The state-of-the-art commercial condensation particle counters for general purposes can detect particles down to 1 nm to 2 nm.

A large number of standards for testing air filters exist such as the ISO 29463 and ISO 16890 series. The test particle range in the ISO 29463 series is between 0,04 µm and 0,8 µm, and the focus is on measurement of the minimum efficiency at the most penetrating particle size (MPPS). The test particle range in the ISO 16890 series is between 0,3 µm and 10 µm. The ISO 21083 series aims to standardize the methods of determining the efficiencies of filter media, of all classes, used in most common air filtration products and it focuses on filtration efficiency of airborne nanoparticles, especially for particle size down to single-digit nanometres.

Advances in aerosol instruments and studies on nanoparticle filtration in the recent years provide a solid base for development of a new method to determine effectiveness of filtration media against airborne nanoparticles down to 5 nm range.

Test method to measure the efficiency of air filtration media against spherical nanomaterials —

Part 2: Size range from 3 nm to 30 nm

1 Scope

This document specifies the testing instruments and procedure for determining the filtration efficiencies of flat sheet filter media against airborne nanoparticles in the range of 3 nm to 30 nm. The testing methods in this document are limited to spherical or nearly-spherical particles to avoid uncertainties due to the particle shape.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5167 (all parts), *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full*

ISO 5725-1, *Accuracy (trueness and precision) of measurement methods and results — Part 1: General principles and definitions*

ISO 5725-2, *Accuracy (trueness and precision) of measurement methods and results — Part 2: Basic method for the determination of repeatability and reproducibility of a standard measurement method*

ISO 15900, *Determination of particle size distribution — Differential electrical mobility analysis for aerosol particles*

ISO 27891, *Aerosol particle number concentration — Calibration of condensation particle counters*

ISO 29464, *Cleaning of air and other gases — Terminology*

3 Terms, definitions, symbols and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 5167-1, ISO 5725-1, ISO 5725-2, ISO 15900, ISO 27891, and ISO 29464 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>