



BSI Standards Publication

Information technology — Data centre facilities and infrastructures

Part 99-1: Recommended practices for energy management

National foreword

This Published Document is the UK implementation of CLC/TR 50600-99-1:2021. It supersedes PD CLC/TR 50600-99-1:2020, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee TCT/7, Telecommunications - Installation requirements.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 399 17219 5

ICS 27.015; 35.020; 35.110; 35.160

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 August 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

TECHNICAL REPORT

CLC/TR 50600-99-1

RAPPORT TECHNIQUE

TECHNISCHER BERICHT

August 2021

ICS 35.020; 35.110; 35.160

Supersedes CLC/TR 50600-99-1:2020

English Version

Information technology - Data centre facilities and infrastructures - Part 99-1: Recommended practices for energy management

Technologies de l'information - Installation et
infrastructures des centres de traitement de données -
Partie 99-1: Pratiques recommandées relatives à la gestion
énergétique

Informationstechnik - Einrichtungen und Infrastrukturen von
Rechenzentren - Teil 99-1: Empfehlungen für die Praktiken für das
Energiemanagement

This Technical Report was approved by CENELEC on 2021-07-26.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	4
Introduction.....	5
1 Scope.....	9
2 Normative references.....	9
3 Terms, definitions and abbreviations.....	9
3.1 Terms and definitions.....	9
3.2 Abbreviations.....	12
4 Principles.....	13
4.1 General.....	13
4.2 Data centre utilization, management and planning.....	14
4.3 Data centre ICT equipment and services.....	14
4.4 Data centre cooling equipment.....	15
4.5 Data centre power equipment.....	16
4.6 Other data centre equipment.....	16
4.7 Data centre building.....	16
4.8 Data centre monitoring.....	17
5 Expected practices.....	18
5.1 Existing data centres.....	18
5.2 ICT equipment (new or replacement).....	24
5.3 Software install or upgrade (Reserved for future new expected Practices).....	28
5.4 New build or refurbishment of data centres.....	28
5.5 Data Centre Monitoring, Energy consumption and environmental measurement.....	35
5.6 Reserved for future new expected Practices from 2022 onwards.....	35
6 Optional and alternative Practices.....	36
6.1 Existing data centres.....	36
6.2 ICT equipment (new or replacement).....	40
6.3 Software install or upgrade.....	42
6.4 New build or refurbishment of data centres.....	43
6.5 PUE calculation and reporting.....	46
6.6 Reserved for future new optional and alternative practices from 2022 onwards.....	47
7 Practices under consideration.....	47
7.1 Practices expected to be included in Clause 5 in due course.....	47
7.1.1 Existing data centres.....	47
7.1.2 ICT equipment (new or replacement).....	47
7.1.3 Software install or upgrade.....	47
7.1.4 New build or refurbishment of data centres (any data centre built or undergoing a significant refit of the mechanical and electrical equipment from 2015 onwards).....	47
7.2 Practices expected to be included in Clause 6 in due course.....	47
7.2.1 Existing data centres.....	47

7.2.2	ICT equipment (new or replacement).....	47
7.2.3	Software install or upgrade.....	48
7.2.4	New build or refurbishment of data centres (any data centre built or undergoing a significant refit of the mechanical and electrical equipment from 2015 onwards)	48
Annex A (informative) Environmental classifications		49
A.1 ASHRAE classifications		49
A.2 ETSI EN 300 019-1-3 classifications		49
Bibliography		51

Currently in preview, click buy full version

European foreword

This document (CLC/TR 50600-99-1:2021) has been prepared by CLC/TC 215 “Electrotechnical aspects of telecommunication equipment” in conjunction with the Directorate-General Joint Research Centre (DG JRC) of the European Commission (EC).

This document supersedes CLC/TR 50600-99-1:2020.

CLC/TR 50600-99-1:2021 includes the following significant technical changes with respect to CLC/TR 50600-99-1:2020:

- update to recently agreed energy management practices and align with the 2021 edition of the *EU Code of Conduct for data centres Best Practices* document;
- new practices added in 5.5, 6.5, 7.2.2, 7.2.3 and 7.2.4;
- re-arrangement of some practices and editorial improvements;
- the practices on “Smart Grid” and “Capture Ready infrastructure” have been re-located to CLC/TR 50600-99-2:2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a Standardization Request given to CENELEC by the European Commission and the European Free Trade Association.

This document aligns with the Best Practices document on the Code of Conduct for Data Centre Energy Efficiency (CoC) scheme operated by the DG JRC and continues to be prepared by data centre experts from operators, vendors, consultants, academics, professional and national bodies.

The publication of this document is intended to integrate recommended practices of energy management into the EN 50600 series developed by CLC/TC 215.

Regarding the structure of the EN 50600 series, see the Introduction.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Introduction

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of environmental footprint) and with respect to economical considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting, or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control, telecommunications cabling and physical security as well as the operation of the data centre. Effective management and operational information is important in order to monitor achievement of the defined needs and objectives.

Recognizing the substantial resource consumption, particularly of energy, of larger data centres, it is also important to provide tools for the assessment of that consumption both in terms of overall value and of source mix and to provide Key Performance Indicators (KPIs) to evaluate trends and drive performance improvements.

At the time of publication of this document, the EN 50600 series is designed as a framework of standards, technical specifications and technical reports covering the design, the operation and management, the key performance indicators for energy efficient operation of the data centre as well as a data centre maturity model.

The EN 50600-2 series defines the requirements for the data centre design.

The EN 50600-3 series defines the requirements for the operation and the management of the data centre.

The EN 50600-4 series defines the key performance indicators for the data centre.

The CLC/TR 50600-5 series defines the data centre maturity model requirements and recommendations.

The CLC/TR 50600-99-X Technical Reports cover recommended practices and guidance for specific topics around data centre operation and design.

This series of documents specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, operators, facility managers, ICT managers, project managers, main contractors;
- 2) consulting engineers, architects, building designers and builders, system and installation designers, auditors, test and commissioning agents;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

At the time of publication of this document, the EN 50600 series will comprise the following standards and documents:

EN 50600-1, *Information technology — Data centre facilities and infrastructures — Part 1: General concepts*

EN 50600-2-1, *Information technology — Data centre facilities and infrastructures — Part 2-1: Building construction*

EN 50600-2-2, *Information technology — Data centre facilities and infrastructures — Part 2-2: Power supply and distribution*

EN 50600-2-3, *Information technology — Data centre facilities and infrastructures — Part 2-3: Environmental control*

EN 50600-2-4, *Information technology — Data centre facilities and infrastructures — Part 2-4: Telecommunications cabling infrastructure*

EN 50600-2-5, *Information technology — Data centre facilities and infrastructures — Part 2-5: Security systems*

EN 50600-3-1, *Information technology — Data centre facilities and infrastructures — Part 3-1: Management and operational information*

EN 50600-4-1, *Information technology — Data centre facilities and infrastructures — Part 4-1: Overview of and general requirements for key performance indicators*

EN 50600-4-2, *Information technology — Data centre facilities and infrastructures — Part 4-2: Power Usage Effectiveness*

EN 50600-4-3, *Information technology — Data centre facilities and infrastructures — Part 4-3: Renewable Energy Factor*

EN 50600-4-6, *Information technology — Data centre facilities and infrastructures — Part 4-6: Energy Reuse Factor*

EN 50600-4-7, *Information technology — Data centre facilities and infrastructures — Part 4-7: Cooling Efficiency Ratio*

CLC/TS 50600-2-10: *Information technology — Data centre facilities and infrastructures — Part 2-10: Earthquake risk and impact analysis*

CLC/TR 50600-99-1, *Information technology — Data centre facilities and infrastructures — Part 99-1: Recommended practices for energy management*

CLC/TR 50600-99-2, *Information technology — Data centre facilities and infrastructures — Part 99-2: Recommended practices for environmental sustainability*

CLC/TR 50600-99-3, *Information technology — Data centre facilities and infrastructures — Part 99-3: Guidance to the application of EN 50600 series.*

The inter-relationship of the documents within the EN 50600 series is shown in Figure 1.




Figure 1 — Schematic relationship between the EN 50600 series of documents

EN 50600-2-X documents specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

The Directorate-General Joint Research Centre (DG JRC) of the European Commission operates a Code of Conduct for Data Centre Energy Efficiency (CoC) scheme. In support of the scheme, a “best practices” document has been established by DG JRC. To enhance the visibility, these Best Practices have been converted in this document to create recommended Practices for improving the energy management (i.e. reduction of energy consumption and/or increases in energy efficiency) of data centres.

The areas addressed are:

- physical building;
- mechanical and electrical equipment;
- computer room;
- cabinets/racks;
- ICT equipment;
- operating systems;
- virtualization;
- software;
- business practices.

The Practices are separated into Expected Practices as referenced in the CoC (see Clause 5) and other Practices which can be employed as optional or alternative solutions in particular cases (see Clause 6). Practices under consideration for the next or future revision/amendment of this document are included in Clause 7. During the maintenance of this document, the Practices of Clauses 6 and 7 might be augmented and others might migrate into Clause 5.

The Practices listed in Clauses 5, 6 and 7 are referenced as x.yyy where x is the clause number and yyy is a sequential number starting within each (sub-)clause.

Customers or suppliers of information and communication technology (ICT) services might also find it useful to request or provide a list of the Practices of this document that are implemented in a data centre to assist in procurement of services that meet their environmental or sustainability standards.

This document also:

- acts as an education and reference document to assist data centre operators in identifying and implementing measures to improve the energy management of their data centres;
- provides a common terminology and frame of reference for describing an energy management practice, avoiding doubt or confusion over terminology.

1 Scope

This document is a compilation of recommended Practices for improving the energy management (i.e. reduction of energy consumption and/or increases in energy efficiency) of data centres.

NOTE It is historically aligned with the EU Code of Conduct for Data Centre Energy Efficiency (CoC) scheme operated by the Directorate-General Joint Research Centre (DG JRC) of the European Commission (EC), however contains additional practices.

It is recognized that the Practices included might not be universally applicable to all scales and business models of data centres or be undertaken by all parties involved in data centre operation, ownership or use.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14511 series, *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors*

EN 50600-1:2019, *Information technology - Data centre facilities and infrastructures - Part 1: General concepts*

EN 50600 series, *Information technology — Data centre facilities and infrastructures*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions in the EN 50600 series and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.1.1

airflow pathway

route taken by air to reach a specific point

3.1.2

albedo

diffuse reflectivity or reflecting power of a surface

3.1.3

availability

ability of an item to be in a state to perform a required function under given conditions at a given instant of time or over a given time interval, assuming that the required external resources are provided

[SOURCE: EN 50600-1:2019, 3.1.1]