



BSI Standards Publication

Alarm systems — Intrusion systems

Part 5-1: Interconnections — Requirements for wired Interconnection for I&HAS equipments located in supervised premises

National foreword

This Published Document is the UK implementation of CLC/TS 50131-5-1:2021.

The UK participation in its preparation was entrusted to Technical Committee GW/1/1, Alarm components.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 539 12233 6

ICS 13.320

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 March 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

ICS 13.320

English Version

**Alarm systems - Intrusion systems - Part 5-1: Interconnections -
Requirements for wired Interconnection for I&HAS equipment
located in supervised premises**

Alarmanlagen - Einbruch- und Überfallmeldeanlagen - Teil
5-1: Verbindungen - Anforderungen an leitungsgebundene
Verbindungen für EMA/ÜMA Einrichtungen in überwachten
Objekten

Alarmanlagen - Einbruch- und Überfallmeldeanlagen - Teil
5-1: Verbindungen - Anforderungen an leitungsgebundene
Verbindungen für EMA/ÜMA Einrichtungen in überwachten
Objekten

This Technical Specification was approved by CENELEC on 2021-01-11.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

European foreword	5
Introduction	6
1 Scope	7
2 Normative references	7
3 Terms, definitions and abbreviations	7
3.1 Terms and definitions	7
3.2 Abbreviations	8
4 Requirements	8
4.1 General	8
4.1.1 Introduction	8
4.1.2 Interconnection Integrity	9
4.1.3 Availability	10
4.1.4 Verification of communications	11
4.1.5 Message/signal Integrity	12
4.2 Response to monitoring	12
4.3 Systems using more than one type of interconnection	13
4.4 Supplementary components of I&HAS	13
4.5 Supplementary functions of I&HAS	13
5 Tests	13
5.1 General	13
5.1.1 Tests for Interconnections	13
5.1.2 Standard laboratory conditions for testing	14
5.1.3 General testing environment and procedure	14
5.1.4 Test procedures defined within component standards	15
5.2 Verification of normal communication test	15
5.2.1 Principle	15
5.2.2 Test conditions	15
5.2.3 Mounting	15
5.2.4 Procedure	15
5.2.5 Pass/Fail criteria	15
5.3 Cutting of all cores (signal based)	15
5.3.1 Principle	15
5.3.2 Test conditions	15
5.3.3 Mounting	15
5.3.4 Procedure	16
5.3.5 Pass/Fail criteria	16
5.4 Cut of any one core (signal based)	16
5.4.1 Principle	16
5.4.2 Test conditions	16
5.4.3 Mounting	16
5.4.4 Procedure	16
5.4.5 Pass/Fail criteria	17
5.5 Short all cores (signal based)	17
5.5.1 Principle	17
5.5.2 Test conditions	17
5.5.3 Mounting	17
5.5.4 Procedure	17

5.5.5	Pass/Fail criteria	17
5.6	Short any pair of cores (signal based)	17
5.6.1	Principle	17
5.6.2	Test conditions	17
5.6.3	Mounting	18
5.6.4	Procedure	18
5.6.5	Pass/Fail criteria	18
5.7	Cutting of all cores (message based – specific)	18
5.7.1	Principle	18
5.7.2	Test conditions	18
5.7.3	Mounting	18
5.7.4	Procedure	18
5.7.5	Pass/Fail criteria	19
5.8	Cut of any one core (message based – specific)	19
5.8.1	Principle	19
5.8.2	Test conditions	19
5.8.3	Mounting	19
5.8.4	Procedure	19
5.8.5	Pass/Fail criteria	19
5.9	Short all cores (message based – specific)	19
5.9.1	Principle	19
5.9.2	Test conditions	19
5.9.3	Mounting	19
5.9.4	Procedure	20
5.9.5	Pass/Fail criteria	20
5.10	Short any pair of cores (message based – specific)	20
5.10.1	Principle	20
5.10.2	Test conditions	20
5.10.3	Mounting	20
5.10.4	Procedure	20
5.10.5	Pass/Fail criteria	20
5.11	Availability monitoring (signal based – non-specific)	21
5.11.1	Principle	21
5.11.2	Test conditions	21
5.11.3	Mounting	21
5.11.4	Procedure	21
5.11.5	Pass/Fail criteria	21
5.12	Availability monitoring (message based – non-specific)	21
5.12.1	Principle	21
5.12.2	Test conditions	21
5.12.3	Mounting	21
5.12.4	Procedure	21
5.12.5	Pass/Fail criteria	22
5.13	Interconnection degradation (signal based)	22
5.13.1	Principle	22
5.13.2	Test conditions	22
5.13.3	Mounting	22
5.13.4	Procedure	22
5.13.5	Pass/Fail criteria	22
5.14	Maximum permitted intervals between periodic communications (message based)	22
5.14.1	Principle	22
5.14.2	Test conditions	23
5.14.3	Mounting	23
5.14.4	Procedure	23
5.14.5	Pass/Fail criteria	23
5.15	Modification of signal (signal based)	23
5.15.1	Principle	23

5.15.2	Test conditions	23
5.15.3	Mounting	23
5.15.4	Procedure	23
5.15.5	Pass/Fail criteria	24
5.16	Modification of message (message based)	24
5.16.1	Principle	24
5.16.2	Test conditions	24
5.16.3	Mounting	24
5.16.4	Procedure	24
5.16.5	Pass/Fail criteria	24
Annex A (informative) Summary of requirements by interconnection type		25
Bibliography		26

Currently in preview, click buy full version.

European foreword

This document (CLC/TS 50131-5-1:2021) has been prepared by CLC/TC 79 "Alarm systems".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Currently in preview, click buy full version

Introduction

The wired interconnection forms the link between I&HAS components to transfer information and, where appropriate, power, as required for reliable system operation.

The transfer of information may be by means of signals or messages as appropriate to the I&HAS and its security grade.

Selection of the type of interconnection media and its installation can affect the reliability and grade of the I&HAS.

Interconnections may be dedicated to a single I&HAS (specific interconnections) or shared with one or more alarm or other systems (non-specific interconnections). The relative priorities of the different systems are determined according to EN 50398-1.

Currently in preview, click buy full version.

1 Scope

This document applies to interconnections between intrusion and hold-up alarm system components using specific or non-specific wired interconnections (e.g. between SPT and CIE). The interconnected components are located within the supervised premises, or mounted on the outside of the supervised premises (e.g. external warning devices).

This document does not apply to interconnections between components located within the same enclosure, or to interconnections between parts of an I&HAS component if covered by the relevant product standard. This document does not define the physical requirements of the interconnection media.

This document is expected to be used in conjunction with the other parts of the EN 50131 series that define the functional requirements of the equipment regardless of the interconnection technique used.

Where monitoring of the functionality of the interconnections is undertaken by an interconnected component, this is defined in the relevant product standard in the EN 50131 series. If a component standard indicates that an interconnection will be monitored, then this document determines the monitored conditions applicable to the interconnection.

NOTE 1 For example, if there is no requirement in a detector standard to monitor a remote indication of detection input, this document does not apply to that particular interconnection.

Requirements for the monitoring of the functionality of power connections between I&HAS components are defined in the relevant product standard and are not included within this document.

This document defines the terms used in the field of intrusion and hold-up alarm equipment using such interconnections and includes the requirements relevant to the equipment interfaces.

Wired interconnection media can include metallic single stranded insulated cable, metallic multi-stranded insulated cable, and fibre optic cable. These cables can comprise single or multiple cores.

NOTE 2 Interconnections using RF techniques (i.e. wire free interconnections) are dealt with by EN 50131-5-3.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50131-1, *Alarm systems - Intrusion and hold-up systems - Part 1: System requirements*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 50131-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at <https://www.iso.org/obp>

— IEC Electropedia: available at <http://www.electropedia.org/>

3.1.1 core

physical element within the wired interconnection media that carries the signal, message or power

Note 1 to entry: There is no requirement that a core should consist of a metallic element.