



BSI Standards Publication

Electromagnetic characteristics of linear cable management systems (CMS)

National foreword

This Published Document is the UK implementation of CLC/TS 50659:2022. It supersedes PD CLC/TR 50659:2017, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PEL/213, Cable management.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 55 15197 8

ICS 29.20.10

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 28 February 2023.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

CLC/TS 50659

December 2022

ICS 29.120.10

Supersedes CLC/TR 50659:2017

English Version

**Electromagnetic characteristics of linear cable management
systems (CMS)**

Caractéristiques électromagnétiques des systèmes
linéaires de câblage

Elektromagnetische Eigenschaften von linearen
Kabelführungssystemen

This Technical Specification was approved by CENELEC on 2022-11-21.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	3
1 Scope	4
2 Normative references	4
3 Terms and definitions.....	4
4 Shielding effectiveness of magnetic field	6
5 Transfer impedance.....	16
Annex A (informative) Example of calculation of the reduction of distance required between parallel power cables and signal cables provided by a cable management system	24
Bibliography	27

European foreword

This document (CLC/TS 50659:2022) has been prepared by CLC/TC 213, "Cable management systems".

This document supersedes CLC/TR 50659:2017.

This is a European Technical Specification for cable management products used for electro-technical purposes. It relates to the Council Directives on the approximation of laws, regulations and administrative provisions of the Member States relating to Low Voltage Directive 2014/35/EU through consideration of the essential requirements of this Directive.

This document is supported by separate standards to which references are made.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

Currently in preview, click buy full version

1 Scope

This document provides test methods for the measurement of the following electromagnetic characteristics of lengthwise cable management systems like conduit systems according to the EN 61386 series, cable trunking systems and cable ducting systems (CTS/CDS) according to the EN 50085 series and cable tray and cable ladder systems according to EN 61537:

- shielding effectiveness of magnetic field,
- transfer impedance.

This document also provides guidance on how these characteristics can be declared and may be used.

Powertrack systems covered by the EN 61534 series are not covered by this edition of the document and can be considered in a new edition.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 61000-4-5, *Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test (IEC 61000-4-5)*

EN 61000-5-7, *Electromagnetic compatibility (EMC) - Part 5-7: Installation and mitigation guidelines - Degrees of protection by enclosures against electromagnetic disturbance (EM code)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>.

3.1

shielding effectiveness

SE

ability of a cable management system to attenuate an electromagnetic signal as it enters or exits the CMS, quantified as the ratio of a signal received (from a transmitter) without the shield, to the signal received with the shield in place

3.2

magnetic field

constituent of an electromagnetic field which is characterized by the magnetic field strength H together with the magnetic flux density B

Note to entry: In French, the term "champ magnétique" is also used for the quantity magnetic field strength.

[SOURCE: IECV 121-11-69]