



BSI Standards Publication

Electromagnetic compatibility

Part 2-15: Description of the characteristics of networks with high penetration of power electronic converters

National foreword

This Published Document is the UK implementation of IEC TR 61000-2-15:2023.

The UK participation in its preparation was entrusted to Technical Committee GEL/210, EMC - Policy committee.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 55 21316 4

ICS 29.240.01; 33.100.01

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 March 2023.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



IEC TR 61000-2-15

Edition 1.0 2023-02

TECHNICAL REPORT



**Electromagnetic compatibility –
Part 2-15: Description of the characteristics of networks with high penetration of
power electronic converters**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01; 33.100.01

ISBN 978-2-8322-6550-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
2 Normative references.....	11
3 Terms and definitions.....	11
4 Resonance phenomena with network and power electronics equipment based on actual cases.....	12
4.1 Operation of overvoltage protection of earth leakage circuit breaker in Japanese LV systems.....	12
4.1.1 General.....	12
4.1.2 Circuit modelling.....	13
4.1.3 Measurements on site.....	14
4.1.4 Technical or regulatory aspects.....	16
4.2 Analysis and modelling of an EV charging hub with PV production.....	17
4.3 Impact of power electronic household equipment on the impedance characteristics in residential networks.....	21
4.4 Harmonic resonance in an urban, residential low voltage grid.....	25
4.5 Harmonic distortion and impedance characteristics in an islanded microgrid.....	28
5 Impact of modern power electronics on the propagation and amplification of voltage distortion.....	31
5.1 Harmonic propagation in a residential LV network.....	31
5.1.1 General.....	31
5.1.2 Measurements.....	31
5.1.3 Modelling issues.....	33
5.2 Supraharmonic amplification in a residential LV network with a fast charging station.....	34
5.2.1 Measurement procedures.....	34
5.2.2 Measurement results.....	36
5.2.3 Simulation results.....	39
5.3 Supraharmonic amplification in a residential low voltage network with PV converters.....	41
5.4 Generic supraharmonic emission models for PWM based converters.....	42
5.5 Assessment of optimal impedance angles for power electronic devices to minimize risk of amplification.....	43
6 Cases of a large amount of converters.....	47
6.1 General.....	47
6.2 Large PV installations.....	48
6.3 Industrial grids.....	53
6.4 Multiple EV chargers in a central charging infrastructure.....	57
6.4.1 General.....	57
6.4.2 Measurements.....	58
6.4.3 Modelling of interactions between N similar single-phase power converters.....	59
7 Impact of grid conditions on the operation of converters.....	66
7.1 Analysis of a single-phase inverter model with an LCL filter using the Nyquist criterion.....	66
7.2 Probabilistic stability analysis for commercial low power inverters based on measured grid impedances.....	74

7.3	Description of electric vehicles connected to a weak network.....	77
7.3.1	General	77
7.3.2	Modeling of the equipment involved	77
7.3.3	Determination of the voltage at the entrance of the charger, for different impedance values of the upstream network	79
7.3.4	Measurements performed at the manufacturer's laboratory	81
7.4	Other interactions between the grid and power converters	82
7.4.1	PV connected to a weak network	82
7.4.2	Windfarms connected to a grid	88
7.4.3	Microgrid during the islanding phase.....	89
7.4.4	Impact of the operating conditions	93
8	Harmonic emission characteristics of power electronic equipment for the mass-market	94
9	Conclusion and perspectives	97
9.1	General.....	97
9.2	Challenges.....	97
9.3	Main findings	98
9.4	Consequences	98
9.5	Recommendations	99
9.6	Future work.....	99
	Bibliography.....	100
	Figure 1 – Schematic illustration of a harmonic resonance issue in a LV system.....	12
	Figure 2 – Waveform of the overvoltage at the neighbour side	13
	Figure 3 – Description of an equivalent circuit modelling for harmonic resonances.....	13
	Figure 4 – Electrical circuit used in simulations, and results of resonance magnification factors (RMFs).....	14
	Figure 5 – Description of the experimental test configuration	14
	Figure 6 – Measurement performed during the experimental tests	15
	Figure 7 – Resonance magnification factors (RMFs) using measurement and simulation	15
	Figure 8 – Flowchart to assess an appliance's compliance with JIS TS C 0058 [2].....	16
	Figure 9 – Harmonic current limits for measurement assessment.....	17
	Figure 10 – Trends on the number of inquiries regarding current emission limits in Japan	17
	Figure 11 – Block scheme of the measured EV charging hub with PV production.....	18
	Figure 12 – Power line impedance magnitude (top) and phase (bottom) measured at the point of common connecting (PCC) of an EV charger hub with PV production	19
	Figure 13 – Resulting simplified model of the charging hub with distribution lines and feeder	19
	Figure 14 – Impact of a super-fast EV charger on grid impedance	20
	Figure 15 – Impedance characteristics of an urban LV network,	24
	Figure 16 – Schema of the network.....	25
	Figure 17 – Network harmonic impedance measured at different locations (L1-N).....	26
	Figure 18 – Simulated network harmonic impedance at different locations (L1-N) using default element representations	26
	Figure 19 – Equivalent impedance model of a domestic customer.....	27

Figure 20 – Measured and simulated network harmonic impedance at different locations (L1-N) using the developed customer impedance model..... 27

Figure 21 – Schematic representation of system under test 28

Figure 22 – Impedance characteristics (magnitude and phase angle)..... 29

Figure 23 – Voltage harmonic levels in ICM (a) and ISM (b)..... 30

Figure 24 – Simplified line diagram of the grid with marked measuring points 31

Figure 25 – Connection of a PQ measuring device..... 32

Figure 26 – Measured 15th current and voltage harmonic on phase L1 during operation of the heat pumps at the heat pumps’ point of connection without active filter 32

Figure 27 – Measured voltage amplitudes of the 15th harmonic for each phase L1 to L3 during three different operating states without active filter 33

Figure 28 – Comparison of measured and simulated voltage levels (15th harmonic voltage) at each measuring point 33

Figure 29 – Modelled voltage vectors of the 15th harmonic at on- and off-state of the large heat pump without active filtering 34

Figure 30 – Spectrogram of the voltage at the point of injection of supraharmonic currents in a residential low voltage network..... 35

Figure 31 – Single-line diagram of relevant parts of the low voltage network..... 36

Figure 32 – Transfer ratio of supraharmonic voltage along the low voltage cable for phase L1 in case of single-phase injection at the transformer busbar BB 37

Figure 33 – Crosstalk ratio of supraharmonic voltage between phase L1 (phase of injection) and phase L2 at the junction box JB 38

Figure 34 – Measured impedance (magnitude and phase) of the DC charger in idle mode 38

Figure 35 – Transfer ratio along the cable for all three phases in case of three-phase injection at the transformer busbar BB 39

Figure 36 – Fully coupled three-phase simulation model..... 39

Figure 37 – Simplified simulation model for supraharmonic transmission along a low voltage cable 40

Figure 38 – Comparison of measured and simulated transfer ratios along a low voltage cable..... 40

Figure 39 – Transfer ratios of supraharmonic voltages along a low voltage cable of varying length..... 41

Figure 40 – Single-line diagram of the analysed low voltage network, two routes, and measurement locations on each route in red, green and blue..... 41

Figure 41 – Transfer ratios along two routes in a low voltage network with residential customers, upstream direction as circles, downstream direction as crosses..... 42

Figure 42 – Equivalent circuit (model) for the supraharmonic emission of single-phase voltage source power converters for the m^{th} emission band..... 43

Figure 43 – RMS voltage spectrum U_S at the output terminals of a single-phase power converter H-bridge using unipolar PWM..... 43

Figure 44 – Amplification and damping of supraharmonic emission at the POC relatively to the source voltage depending on the network to source impedance 45

Figure 45 – Circles of constant POC voltage in the dominant emission band of two photovoltaic inverters [29]..... 46

Figure 46 – Prevailing phase angle of 187 measured network loop impedances [34]between 2 kHz and 150 kHz, phase angle of the line impedance stabilization network from CISPR 16-1-2 46

Figure 47 – Cumulative distribution function (CDF) of non-intentional emissions due to distributed energy sources at two different frequencies (45,7 kHz and 118,4 kHz) and noise present in the electrical grid (122,9 kHz)	47
Figure 48 – Identification of the frequencies in the frequency response.....	47
Figure 49 – Identification of the frequencies in the spectrogram of the measurements (see case study [23])	48
Figure 50 – Parallel-connect configuration in large photovoltaic (PV) farm	49
Figure 51 – Simplified parallel of two converters featuring LCL filter and capacitor on common bus for reactive compensation in the grid (see Table 7)	49
Figure 52 – Frequency domain results of parallel LCL filter system with reactive power compensation capacitor represented in two frequency ranges.....	50
Figure 53 – N parallel connected equivalent inverter models equipped with LCL filter interfaces connected to common grid impedance Z_g as parallel connection of Thévenin's equivalent voltage sources and equivalent impedances	51
Figure 54 – Change in Bode plot of i_{sg}/i_{s11} (ratio of grid and inverter side currents respectively) or LCL-filter topology when the number of parallel connected inverters n increases from 2 to 8 with increments of 2	51
Figure 55 – Time domain simulations of parallel LCL system without reactive power compensation capacitor dependent on (in dependency of) a small sinusoidal disturbance term added in the control loop – Duty cycle.....	51
Figure 56 – Power line impedance in lower frequency range measured with 0 to 59 inverters activated in a 2,1 MW PV plant.....	52
Figure 57 – Power line impedance measured with 0 to 59 inverters activated in a 2,1 MW PV plant.....	53
Figure 58 – Configuration of an industrial grid.....	54
Figure 59 – Interaction between two converters, which can lead to resonances and generate non-intentional emissions in the 2 kHz to 150 kHz frequency range.....	54
Figure 60 – Modeling of a simple configuration of noise source and noise sink, where the EMI filter of the sink converter can be of 2 nd , 3 rd or 4 th order [25]	55
Figure 61 – Impedance into the noise sink converter Z_{sink} with different EMI filter types with simple choke interface only and different EMI filter configurations	55
Figure 62 – Impedance into the noise sink converter Z_{sink} with different EMI filter types with LCL interface and different EMI filter configurations	56
Figure 63 – Ratio of voltage and current in phase 1 with a third-order EMI filter and different cables with a) DM excitation and b) CM excitation.....	57
Figure 64 – Voltage at 10 kHz of one to four BEVs charging at a common POC, time varying values as solid line (20 ms measurement windows), overall RMS as dotted line	58
Figure 65 – Supraharmonic voltages and currents at the POC of multiple AC charging points, first emission band (800 Hz) centred around 10 kHz.....	59
Figure 66 – Single-line diagram of an arbitrary number N of power converters operating in parallel on a single network phase	60
Figure 67 – Supraharmonic emission model for an arbitrary number N of power converters operating in parallel.....	60
Figure 68 – Simulation of supraharmonic beating using summation of rotating phasors, for one up to three sources with different frequencies and magnitudes of contribution, first emission band.....	61
Figure 69 – Exemplary assessment of the supraharmonic emission of two photovoltaic inverters using the criteria in Formula (19) to Formula (21), and photovoltaic inverters from [15].....	64

Figure 70 – Dependency of the POC voltage on the number of sources N for different magnitude ratios of source impedance to network impedance assuming phase angles of source impedance and network impedance are equal 65

Figure 71 – Single phase inverter with an LCL filter and corresponding state variables 66

Figure 72 – Block scheme equivalent to the formula system of Figure 71 67

Figure 73 – Linearized control loop for the in-feed converter and transfer functions for feed forward and current measurement filter 68

Figure 74 – Norton equivalent circuit of the single-phase inverter 69

Figure 75 – Nyquist stability analysis of the control loop with parameters listed in Table 8 70

Figure 76 – PLECS model of the single-phase inverter with LCL filter 71

Figure 77 – PLECS model of the single-phase inverter controller with Feedforward of the connecting point voltage 71

Figure 78 – Simulation result of a current reference step of 0 A to 10 A for the converter 72

Figure 79 – Impedance magnitude (a) and phase angle characteristic (b) of commercially available single-phase inverter (black), network impedance with inductance of 2,3 mH (blue) and 3,2 mH (red) 73

Figure 80 – Grid-side current measurements for LR -equivalent network impedance with inductance values of 2,3 mH (a) and 3,2 mH (b) 74

Figure 81 – Small signal model of an inverter and the low voltage network 74

Figure 82 – Magnitude (a) and phase angle of low voltage network impedance measurements at 120 measurement sites 75

Figure 83 – Magnitude (a) and phase angle of the impedance of six commercially available inverters 75

Figure 84 – Critical frequency regions of commercially available inverters (a) and measurement sites in LV networks (b) 76

Figure 85 – Electrical network including the network and four electrical vehicles connected (described in the EMTP program) 77

Figure 86 – Description of the different elements considered 78

Figure 87 – Description of the filter connecting the boost to the electrical network 78

Figure 88 – Description of the low frequency filter 78

Figure 89 – Description of the converter of the boost PFC converter, including its AC/DC rectifier 79

Figure 90 – Current flowing in the electronic components (diodes, IGBTs) versus positive values of the applied voltage V_d 79

Figure 91 – Voltage V_c at the entrance of the charger, obtained by simulations, for different values of the upstream network 80

Figure 92 – Description of the phase-space diagram corresponding to the main state-variables of the system 80

Figure 93 – Current crossing an IGBT obtained by simulations, with an inductance value of 600 μH for the upstream network 81

Figure 94 – Voltage $V_{c\text{meas}}$ at the entrance of the charger, measured at the manufacturer’s laboratory, for a value of 750 μH for the inductance of the upstream network 81

Figure 95 – Description of the circuit including a solar PV–micro turbine based power system with battery backup 83

Figure 96 – PCC (grid) voltage with linear and non-linear loads in the absence of any VSI (voltage source inverter) 83

Figure 97 – Grid working and VSI switched on at $t = 0,5 \text{ s}$ 84

Figure 98 – Grid working and VSI switched on at $t = 0,5$ s	85
Figure 99 – Frequency characteristic of the 3 kW PV system with L-C-L filter in the following grid conditions: A) 0,1 mH, B) 3 mH, C) 0,1 mH, 100 μ F and D) 3 mH, 100 μ F	85
Figure 100 – Resonance frequency variation in per cent of the rated resonance frequency as a function of grid inductance in per cent.....	86
Figure 101 – Illustration of a quasi-periodic route to chaos in a buck-boost converter, with the input voltage as a bifurcation parameter	87
Figure 102 – Experimental illustration of period doubling route to chaos in buck-boost converter	87
Figure 103 – Grid-connected DFIG WT system	88
Figure 104 – DFIG PQ limitation due to SCR and X/R variation	88
Figure 105 – System response to different network strength	89
Figure 106 – Structure of a hybrid system proposed for a microgrid application	90
Figure 107 – Control for a hybrid PV-battery system	90
Figure 108 – Variation of the voltage at the PV terminals and current in the battery	90
Figure 109 – Regulation of the voltage when the load is changing	91
Figure 110 – Current in the battery during variation of the voltage at the PV terminals during the change of load	91
Figure 111 – Microgrid system configuration and main features	92
Figure 112 – Designed PV microgrid system (left) and control setup of the PV microgrid at the Griffith University, Australia (right)	92
Figure 113 – Disturbance rejection response comparison in the intentional islanding scenario.....	93
Figure 114 – Description of a “test bench” at the laboratory	93
Figure 115 – Evolution of the measured current as a function of the charging setpoint.....	94
Figure 116 – Normalized input AC current waveforms of typical electronic appliances for sinusoidal (left) and flat-top (right) input voltage waveforms	95
Figure 117 – Impact of voltage magnitude on harmonic current emission for different topology categories (sinusoidal waveform).....	96
Figure 118 – Impact of flat top voltage waveform on harmonic current emission for different topology categories (nominal RMS voltage).....	96
Table 1 – Relation between measured current and respective impedance for each feeder	21
Table 2 – Device and topologies used in the different evolution stages	22
Table 3 – Load scenarios depending on the evolution stages and loading conditions	22
Table 4 – Equivalent $R_{L1}L_1 R_{L2}L_2C_2$ parameter values.....	23
Table 5 – Ratio between network harmonic impedance and extrapolated impedance for various cases	24
Table 6 – Load scenarios	29
Table 7 – Values of the system parameters [23].....	49
Table 8 – Example of system parameters and components for the Nyquist stability analysis	71
Table 9 – Grid-compatibility index of commercially available single-phase inverters.....	76

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY –

**Part 2-15: Description of the characteristics of networks
with high penetration of power electronic converters**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. For this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publications"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as far as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 61000-2-15 has been prepared by subcommittee 77A: EMC – Low frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility. It is a Technical Report.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
77A/1153A/DTR	77A/1159/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 61000 series, published under the general title *Electromagnetic compatibility*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (insofar as these limits do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as international standards or as technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and a second number identifying the subdivision (example: IEC 61000-6-1).

This part of IEC 61000-2 describes the main phenomena which affect the power quality of modern distribution systems with high penetration of power electronics converters.

It focuses on the following main aspects: resonances in LV network, impact of increased number of power electronic converters, instability issues for the equipment to be connected to the LV networks.

Those new aspects, organized and described in this document, can lead to new IEC specifications; that is why a state of the art on this topic is necessary.

ELECTROMAGNETIC COMPATIBILITY –

Part 2-15: Description of the characteristics of networks with high penetration of power electronic converters

1 Scope

This part of IEC 61000, which is a Technical Report, addresses in particular the following main phenomena, which affect the power quality in modern distribution systems with high penetration of power electronics converters. As some aspects of the subject have already been addressed in the past, considering the evolution of the LV and MV networks, this document focuses on the following aspects:

- resonances in the network, modelling and on-site validation;
- supraharmonics and measurements issues;
- impact of increased number of power electronic converters;
- stability and instability issues for the equipment to be connected

The target phenomena and conditions of this document are the following:

- frequency: ≤ 2 kHz, 2 kHz to 9 kHz, ≥ 9 kHz;
- voltage levels: LV, MV;
- harmonic sources: all types of converters (EV battery chargers, appliances, etc....).

Some of these frequency ranges have already been standardized in some countries (Japan, Germany, Switzerland, etc.), but the resulting phenomena developed will benefit being described in more details, with a focus on the interaction between the converters and the electrical networks. The case of the presence of a large number of converters is also at stake. Some complex phenomena can also arise when the full system is not stable anymore.

NOTE Whereas it is expected that the models and derived calculations from this document can be applied to the Americas electrical systems its formal validation studies are still pending.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>