



BSI Standards Publication

Guidelines for the use of monitor systems for lead-acid traction batteries

National foreword

This Published Document is the UK implementation of IEC TR 61431:2020.

The UK participation in its preparation was entrusted to Technical Committee PEL/21, Secondary cells and batteries.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2020
Published by BSI Standards Limited 2020

ISBN 978 0 539 03362 5

ICS 29.220.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 September 2020.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



TECHNICAL REPORT

Guidelines for the use of monitor systems for lead-acid traction batteries

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.220.20

ISBN 978-2-8322-8854-2

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD 4

1 Scope 6

2 Normative references 6

3 Terms and definitions 6

4 Desirable characteristics and features 6

 4.1 General 6

 4.2 Physical location of the monitoring device 6

 4.3 State of charge indication or "fuel gauge" 7

 4.4 Battery temperature information 7

 4.5 High battery temperature warning 7

 4.6 Low temperature warning 7

 4.7 Electrolyte level indication 7

 4.8 Electrolyte level maintenance log 7

 4.9 Uniformity of cell properties in a battery 8

 4.10 Battery commissioning date 8

 4.11 Battery configuration 8

5 Evaluation and analysis 8

 5.1 State of charge indication or "fuel gauge" 8

 5.2 Battery temperature information 8

 5.3 Water consumption 9

 5.4 Uniformity of cell properties 10

 5.5 Electrolyte density 10

 5.6 Capacity throughput 11

 5.7 Battery age 11

 5.8 Battery data sheet 11

 5.9 Communication interfaces 12

 5.10 Ground faults 12

 5.11 Human factors 12

6 Data monitoring – Recommended list of parameters to be monitored 13

7 Analysis and evaluation of gathered battery data 14

 7.1 Data flow 14

 7.2 Prediction of residual operational life 14

Annex A (informative) Example determination of the residual service life of lead-acid traction batteries 15

 A.1 General 15

 A.2 Lost capacity due to stress factors 15

 A.2.1 Evaluation of the impact of a deep discharge 15

 A.2.2 Evaluation of impact of the battery temperature 16

 A.2.3 Evaluation of the impact of very high discharge currents 17

 A.2.4 Evaluation of the impact of the battery being in idle state 17

 A.2.5 Calculation of the residual capacity 17

 A.2.6 Residual number of cycles 18

Figure 1 – Potential data flow in a monitor system 14

Figure A.1 – Example of interrelation between discharge voltages and discharge currents indicating a deep discharge condition 16

Table 1 – Residence times and related temperature ranges	9
Table 2 – Temperature warning levels	9
Table 3 – Units and value resolution of measured characteristics	13
Table A.1 – Derating factor due to ageing on standby and idling	17

Currently in preview, click buy full version

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**GUIDELINES FOR THE USE OF MONITOR SYSTEMS
FOR LEAD-ACID TRACTION BATTERIES**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61431, which is a Technical Report, has been prepared by IEC technical committee 21: Secondary cells and batteries.

This second edition cancels and replaces the first edition, published in 1995. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) The guidelines have been streamlined in terms of technical content and focussed for automatic monitoring systems.

The text of this Technical Report is based on the following documents:

Enquiry draft	Report on voting
21/1044/DTR	21/1053A/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

GUIDELINES FOR THE USE OF MONITOR SYSTEMS FOR LEAD-ACID TRACTION BATTERIES

1 Scope

This document is an informative document relating to aspects of automatic monitor systems as utilized in lead-acid traction battery applications. It lists the characteristics and features that need to be monitored and evaluated to properly assess the operative status of a traction battery. Guidance concerning the accuracy and reliability of the generated information is also provided.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Desirable characteristics and features

4.1 General

This Clause 4 lists relevant characteristics and features, which, if measured or implemented, would contribute information towards the assessment of the operational condition of a lead acid traction battery. The characteristics are not listed in any order of priority.

The battery monitoring system (BMOS) described in this document is a device solely collecting and reporting data and should not be confused with a battery management system (BMS) actively controlling the battery.

4.2 Physical location of the monitoring device

The device may be installed in one of the following locations:

- a) directly on the battery,
- b) on the charger,
- c) on the vehicle.

Location a) is the preferred option as it provides continuous and continued monitoring. Option b) and c) require additional methods to properly identify which battery is currently being monitored. This requires a unique battery ID to be made available for battery recognition. Such an ID could be stored for example on an RFID tag, a 2D QR code, NFC device or similar information depositories.