



BSI Standards Publication

## Overhead electrical conductors – Calculation methods for stranded bare conductors

---

## National foreword

This Published Document is the UK implementation of IEC TR 61597:2021.

The UK participation in its preparation was entrusted to Technical Committee GEL/7, Overhead electrical conductors.

A list of organizations represented on this committee can be obtained on request to its committee manager.

### Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2021  
Published by BSI Standards Limited 2021

ISBN 978 0 560 51505 7

ICS 29.240.20

**Compliance with a Published Document cannot confer immunity from legal obligations.**

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 August 2021.

### Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

---



# TECHNICAL REPORT

---

**Overhead electrical conductors – Calculation methods for stranded bare conductors**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.240.20

ISBN 978-2-8322-9938-8

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references .....	6
3 Terms and definitions .....	6
4 Symbols, units and abbreviated terms .....	7
4.1 Symbols and units.....	7
4.2 Abbreviated terms.....	8
5 Current carrying capacity.....	8
5.1 General.....	8
5.2 Heat balance equation .....	8
5.3 Calculation method .....	9
5.4 Joule effect .....	9
5.5 Solar heat gain .....	9
5.6 Radiated heat loss .....	9
5.7 Convection heat loss.....	10
5.8 Method to calculate current carrying capacity (CCC).....	10
5.9 Determination of the maximum permissible aluminium temperature.....	10
5.10 Calculated values of current carrying capacity .....	11
6 Alternating current resistance, Inductive and capacitive reactances.....	11
6.1 General.....	11
6.2 Alternating current (AC) resistance .....	11
6.3 Inductive reactance.....	12
6.4 Capacitive reactance .....	14
7 Elongation of stranded conductors.....	14
7.1 General.....	14
7.2 Thermal elongation .....	15
7.3 Stress-strain properties .....	18
7.4 Assessment of final dynamic modulus.....	20
8 Conductor creep.....	22
8.1 General.....	22
8.2 Creep of single wires .....	23
8.3 Total conductor creep .....	24
8.4 Prediction of conductor creep .....	24
8.5 Creep values .....	24
9 Loss of strength.....	25
Annex A (informative) A practical example of CCC calculation .....	27
A.1 Basic Assumptions.....	27
A.2 CCC calculation .....	27
Annex B (informative) Indicative conditions for CCC calculation.....	29
Bibliography.....	30
Figure 1 – Typical creep curve .....	23
Figure 2 – Loss of strength of aluminium A1 as a function of temperature.....	26
Figure 3 – Loss of strength of aluminium A2 .....	26

Table 1 – Values of $K_g$ for inductive reactance calculations .....	13
Table 2 – Coefficient of linear expansion $\beta$ of inhomogeneous conductors designated Ax/Sxy .....	17
Table 3 – Coefficient of linear expansion $\beta$ of inhomogeneous conductors designated Ax/20SA .....	18
Table 4 – Typical stress-strain data of stranded conductors based on published test results .....	21
Table 5 – Final modulus of elasticity calculated with $E_a= 55000$ MPa and $E_s= 190000$ MPa .....	22
Table 6 – Final modulus of elasticity calculated with $E_a= 55000$ MPa and $E_s= 159000$ MPa (20SA).....	22
Table 7 – Indicative creep values of stranded conductors(25 %RTS, 20 °C) .....	25
Table B.1 – Indicative conditions for CCC calculation .....	29

Currently in preview, click buy full version

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**OVERHEAD ELECTRICAL CONDUCTORS – CALCULATION  
METHODS FOR STRANDED BARE CONDUCTORS**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 61597 has been prepared by IEC technical committee 7: Overhead electrical conductors. It is a Technical Report.

This second edition cancels and replaces the first edition published in 1995. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Addition of Clause 2 and Clause 3 since the "Normative references" and "Terms and definitions" clauses are mandatory elements of the text according to the new IEC template.
- b) In Clause 6, addition of new kinds of aluminium alloy and aluminium clad steel and their values of temperature coefficients of resistance.
- c) In Clause 6, addition of guidelines for the calculation of AC resistance taken into account hysteresis and eddy current losses.

- d) In Clause 7, addition of the values of coefficient of linear expansion of aluminium alloy conductor aluminium-clad steel reinforced series.
- e) Deletion of Clause 8 “Calculation of maximum conductor length on drums” in the last version.
- f) Annex A, replaced by “A practical example of CCC calculation”.
- g) Annex B, replaced by “Indicative conditions for CCC calculation”.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
7/704/DTR	7/707/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/standardsdev/publications](http://www.iec.ch/standardsdev/publications).

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## OVERHEAD ELECTRICAL CONDUCTORS – CALCULATION METHODS FOR STRANDED BARE CONDUCTORS

### 1 Scope

This document, which is a Technical Report, provides information with regard to conductors specified in IEC 61089 and other aluminium and aluminium steel conductors. Such information includes properties of conductors and useful methods of calculation. The following chapters are included in this document.

- current carrying capacity of conductors: Calculation method and typical example
- alternating current resistance, inductive and capacitive reactances
- elongation of conductors: Thermal and stress-strain data
- conductor creep
- loss of strength of aluminium wires due to high temperatures

It is noted that this document does not discuss all theories and available methods for calculating conductor properties, but provides users with simple methods that provide acceptable accuracies.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TR 60943:1998, *Guidance concerning the permissible temperature rise for parts of electrical equipment, in particular for terminals*  
IEC TR 60943:1998/AMD1:2008

IEC 61089:1991, *Round wire concentric lay overhead electrical stranded conductors*  
IEC 61089:1991/AMD1:1999

IEC 60104:1987, *Aluminium-magnesium-silicon alloy wire for overhead line conductors*

IEC 60889:1987, *Hard-drawn aluminium wire for overhead line conductors*

IEC 61232:1993, *Aluminium-clad steel wires for electrical purposes*

IEC 6139:1998, *Overhead electrical conductors – Creep test procedures for stranded conductors*

IEC 62004:2007, *Thermal-resistant aluminium alloy wire for overhead line conductor*

### 3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses: