



BSI Standards Publication

Intelligent device management

Part 1: Concepts and terminology

National foreword

This Published Document is the UK implementation of IEC TR 63082-1:2020.

The UK participation in its preparation was entrusted to Technical Committee GEL/65/3, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2020
Published by BSI Standards Limited 2020

ISBN 978 0 580 96657 6

ICS 25.040.40

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 July 2020.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



IEC TR 63082-1

Edition 1.0 2020-02

TECHNICAL REPORT



**Intelligent device management –
Part 1: Concepts and terminology**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40

ISBN 978-2-8322-7855-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms, definitions and abbreviated terms	9
3.1 Terms and definitions.....	9
3.2 Abbreviated terms.....	17
4 Background and motivation of intelligent device management.....	18
4.1 General.....	18
4.2 Established business practices	18
4.3 Objectives of IDM	19
4.4 Conditions for achieving IDM	20
4.5 Benefits and justification of IDM.....	20
4.6 Challenges for implementing IDM.....	21
4.7 Relationship of IDM to asset management	21
5 Structure of IDM	22
5.1 Overview.....	22
5.2 Organizational structure.....	22
5.2.1 Overview	22
5.2.2 Structure of IDM activities.....	23
5.3 Relationship between IDM program and work processes.....	24
5.4 IDM programs	26
5.4.1 Overview	26
5.4.2 Relational structure of IDM program documents.....	26
5.5 IDM work processes.....	27
5.5.1 Overview	27
5.5.2 IDM work processes specification	27
5.6 Procedures	28
5.6.1 Overview	28
5.6.2 Procedure specification	28
5.7 Tasks.....	29
5.7.1 Overview	29
5.7.2 Task specification	29
6 Lifecycles	30
6.1 Overview.....	30
6.1.1 Lifecycle relationships	30
6.1.2 Relationship between lifecycles	31
6.2 IDM program lifecycle	32
6.2.1 Overview	32
6.2.2 IDM program development.....	32
6.2.3 IDM program management and design.....	36
6.2.4 IDM program operation	37
6.2.5 Facility level IDM program activities.....	38
6.3 Device technology lifecycle	39
6.4 Device lifecycle.....	39

6.5	Facility lifecycle	41
6.5.1	General	41
6.5.2	Scope development	42
6.5.3	Design and engineering	45
6.5.4	Construction and commissioning	47
6.5.5	Operation and maintenance	49
6.5.6	Turnaround	51
6.5.7	Decommissioning	53
7	Maintenance processes	54
7.1	Overview	54
7.2	Types and relationship of maintenance processes	55
7.2.1	General	55
7.2.2	Run to failure	56
7.2.3	Diagnostic or condition based maintenance	57
7.2.4	Automated fault handling	58
7.2.5	Scheduled inspection and testing	58
7.3	Other aspects of maintenance	59
7.3.1	Use of maintenance history	59
7.3.2	Root cause analysis	59
7.3.3	Effects of maintenance processes	60
7.4	Relationship of problem detection methods and maintenance strategies	60
7.4.1	Problem detection optimization	60
7.4.2	States and transitions	61
7.5	Factors for selection of maintenance processes	62
7.5.1	IDM criticality determination	62
7.5.2	Failure consequences	63
7.5.3	Types of fault	63
8	IDM notification management and utilization	64
8.1	Notification management	64
8.2	Notification from intelligent device	64
8.2.1	Overview	64
8.2.2	Notification types	65
8.2.3	Notification sources	66
8.3	Notification delivery mechanism	66
8.3.1	Overview	66
8.3.2	Device alert	67
8.3.3	Process value (PV) status	67
8.3.4	Operation (control) mode	67
8.4	Action responding to notification	68
8.4.1	Overview	68
8.4.2	Real time automated responses	68
8.4.3	Real time operator responses	68
8.4.4	Semi real time responses	69
8.4.5	Longer term planned responses	69
9	Configuration management	70
9.1	Overview	70
9.2	Device templates for device configuration	70
9.3	Toolkits	71

9.4	Configuring intelligent devices	71
9.4.1	Overview	71
9.4.2	Bulk building.....	71
9.4.3	Individual building.....	72
9.5	Maintenance of device configuration data	72
Annex A	(informative) Standard diagrams used in IEC 63082 (all parts).....	73
A.1	Overview.....	73
A.2	Class diagram.....	73
A.3	Activity diagram (swimlanes).....	75
A.3.1	Overview	75
A.3.2	Activity diagram	75
A.3.3	Swimlane chart.....	77
Annex B	(informative) Equivalent UML diagrams for Figures 1, 3, 4, 5, 6, 7, 8	79
Annex C	(informative) Summary of IDM objectives and associated work processes	83
Annex D	(informative) Example of criticality ranking.....	84
D.1	Overview.....	84
D.2	Definitions.....	84
D.3	Criticality ranking.....	85
Bibliography	90
Figure 1	– IDM and intelligent device in the context of asset management.....	22
Figure 2	– Positioning of IDM program	23
Figure 3	– Structure of IDM activities	24
Figure 4	– Structure of IDM program	25
Figure 5	– Structure of IDM program for an enterprise	27
Figure 6	– IDM work process	28
Figure 7	– Procedure	29
Figure 8	– Task.....	30
Figure 9	– Timing relationship between lifecycles	31
Figure 10	– IDM program lifecycle phases	33
Figure 11	– IDM program functional structure	36
Figure 12	– Timing relationship between IDM device lifecycles	40
Figure 13	– Facility lifecycle phases for IDM	42
Figure 14	– Criticality usage in a facility.....	45
Figure 15	– Turnaround process	52
Figure 16	– Overview of maintenance process	56
Figure 17	– State diagram for IDM	61
Figure 18	– State diagram for IDM diagnostics based maintenance processes.....	62
Figure 19	– Notifications routing for IDM	67
Figure 20	– Relationship between real time, semi real time, and planned activities	68
Figure A.1	– Position of class diagram and activity diagram in UML	73
Figure A.2	– Example of class diagram	75
Figure A.3	– Example of activity diagram	77
Figure A.4	– Example of swimlane chart	78
Figure B.1	– IDM and intelligent device in the context of asset management.....	79

Figure B.2 – Structure of IDM activities	79
Figure B.3 – Structure of IDM program.....	80
Figure B.4 – Structure of IDM program and the enterprise	80
Figure B.5 – IDM work process	81
Figure B.6 – Procedure	81
Figure B.7 – Task	82
Table 1 – IDM documents	25
Table 2 – Benefits of IDM related to device supply chain management	41
Table 3 – Verification and testing of configuration	7
Table 4 – Failure consequence for non-SIS devices.....	60
Table 5 – Notification type	64
Table 6 – IDM benefits from real time automated responses	68
Table 7 – IDM benefits from real time operator responses	69
Table 8 – IDM benefits from semi real time responses	69
Table 9 – IDM benefits from longer term planned responses	70
Table A.1 – Notation of UML class diagram	74
Table A.2 – Model elements of activity diagram	76
Table C.1 – Severity categories	83
Table D.1 – Severity categories	86
Table D.2 – Probability levels	87
Table D.3 – Risk assessment matrix – Modified/industry normal	88

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INTELLIGENT DEVICE MANAGEMENT –**Part 1: Concepts and terminology****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publications"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 63082-1, which is a Technical Report, has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this Technical Report is based on the following documents:

Draft TR	Report on voting
65E/653/DTR	65E/677/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 63082 series, published under the general title *Intelligent device management*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The purpose of the IEC 63082 series is to define an environment that enables the effective use of industrial intelligent devices (IID). The documents provide common concepts, terminology, and management activities.

Intelligent device management (IDM) represents activities for managing intelligent devices through the facility lifecycle and does not imply a particular asset management tool or set of those tools. Hardware and software tools are necessary to support work processes and procedures, but specification of the tools is not a part of the IEC 63082 series. IDM can be one of many enterprise programs. IDM activities optimize the value from intelligent devices and supports the concepts of integration of data from the production level with business systems. IDM is consistent with smart manufacturing initiatives.

The IEC 63082 series is not intended to replace or contradict other standards, for example IEC 61511 (all parts) for safety instrumented systems and IEC 62443 (all parts) for cybersecurity.

While the work processes and implementation practices specified in the IEC 63082 series might be used for non-automation equipment with some diagnostic capability, the IEC 63082 series does not cover these equipment types.

The IEC 63082 series will consist of the following parts:

- IEC TR 63082-1: Concepts and terminology (informative);
- IEC 63082-2: Work process requirements (normative).

IEC 63082-1 describes intelligent device management concepts and terminology necessary for in-depth understanding and effective communication. It gives the basic concepts of how intelligent devices can be managed and an overview of how this device management works throughout the facility lifecycle. IEC 63082-1 provides basic knowledge to understand the concepts of intelligent device management necessary to implement an IDM program.

IEC 63082-2 will provide normative requirements for IDM.

INTELLIGENT DEVICE MANAGEMENT –

Part 1: Concepts and terminology

1 Scope

This part of IEC 63082 describes concepts and terminology necessary to understand and communicate effectively about IDM. This document explains the relationship between IDM and other existing asset management standards.

Additionally, this document provides activity structures and concepts associated with IDM programs. This document also introduces the concept of IDM programs for coordination of multiple stakeholders.

2 Normative references

There are no normative references in this document.

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1.1 activity

set of actions that consume time and resources and whose performance is necessary to achieve, or contribute to, the realization of one or more objectives

Note 1 to entry: Includes work processes, procedures, and tasks.

[SOURCE: ISO/IEC TR 24766:2009, 3.1, modified – "outcomes" was replaced with "objectives" and the note has been added.]

3.1.2 alarm

notification to the operator of an equipment malfunction, process deviation, or abnormal condition requiring a unique, timely, and documented (predetermined) response from the operator

[SOURCE: IEC 62682:2014, 3.1.7, modified – "an audible and/or visible means of indicating" was replaced with "notification", "timely response" was replaced with "unique, timely, and documented (predetermined) response from the operator".]