



BSI Standards Publication

Managing fire risk related to photovoltaic (PV) systems on buildings

National foreword

This Published Document is the UK implementation of IEC TR 63226:2021.

The UK participation in its preparation was entrusted to Technical Committee GEL/82, Photovoltaic Energy Systems.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 55 02929 1

ICS 27.160

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 August 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



TECHNICAL REPORT



Managing fire risk related to photovoltaic (PV) systems on buildings

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.160

ISBN 978-2-8322-9395-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD..... 4

INTRODUCTION..... 6

1 Scope..... 7

2 Normative references 7

3 Terms and definitions 7

4 Risk evaluation 7

 4.1 General..... 7

 4.2 Site selection 7

 4.3 Aspects for building risk evaluation 7

 4.3.1 Roofing materials..... 7

 4.3.2 Building construction 8

 4.3.3 Building contents 8

 4.3.4 Use of building..... 9

 4.3.5 Building type considerations regarding financial risks 9

 4.4 Measures for supporting firefighter and rescue service operations 9

 4.4.1 General 9

 4.4.2 Response times of emergency responders and available apparatus..... 10

 4.4.3 Geometry, height, accessibility of building 10

 4.4.4 Coordination with fire alarm systems 11

 4.5 Other organizational aspects..... 11

 4.5.1 Briefing fire services in on-site specific aspects 11

 4.5.2 Harmonize measures with fire protection measures of building 12

 4.5.3 Harmonize measures with owner, user and building and inventory insurance..... 12

5 Technical PV system design measures for fire prevention 12

 5.1 General..... 12

 5.2 Initial PV system design considerations to minimize risk 12

 5.2.1 General 12

 5.2.2 Ventilation 12

 5.2.3 Accumulation of flammable material..... 13

 5.2.4 Cabling 13

 5.3 Arc-fault detection..... 13

 5.4 Earth fault detection..... 14

 5.5 Automatic shutdown after first fault 14

 5.6 Coverboard 14

6 Technical PV system design measures for supporting firefighter and rescue service operations 15

 6.1 General..... 15

 6.2 Initial PV system design considerations to minimize risk 15

 6.2.1 General 15

 6.2.2 DC cable lengths and routing..... 15

 6.2.3 DC cabling marking 15

 6.2.4 Access pathways and escape routes 15

 6.2.5 Caution board..... 15

 6.3 Generator/string-level shutdown 15

 6.4 Module-level control, ELV-systems, distributed array protection..... 16

 6.5 Cable routing measures 17

6.6	Fire-resistant cable raceways.....	17
7	Installation and commissioning	17
7.1	General.....	17
7.2	Important installation requirements impacting risk	17
7.3	Commissioning procedures	18
7.4	Documentation – clear installation, owners, fire services and maintenance manuals for PV equipment	18
8	Operation and maintenance.....	18
8.1	General.....	18
8.2	Inspection of electric system	18
8.3	Inspection of mounting structure and building influence	19
8.4	Inspection of pathways	19
8.5	Cleaning	19
8.6	Thermography.....	19
8.7	Recommendations for empty buildings or systems not under supervision.....	19
9	Corrective measures after fire	19
9.1	General.....	19
9.2	Measures to avoid safety risks or further damage	19
9.3	Safety inspection	20
9.4	Measures to bring PV system into a safe state.....	20
Annex A (informative)	Analysis from fire incidents in PV systems.....	21
A.1	General.....	21
A.2	Component where fire started	22
A.3	Cause of incident.....	23
A.4	When did incidents occur?	25
	Bibliography.....	26
	Figure 1 – Cable routing related to pathways	11
	Figure A.1 – Number of identified incidents and severity of effect on surroundings for a total of about 400 fire reports	21
	Figure A.2 – Distribution of fire reports depending on mounting type.....	21
	Figure A.3 – For cases of damaged buildings only: distribution of fire reports depending on mounting type	22
	Figure A.4 – Counts of system section where fire started	22
	Figure A.5 – Counts of component where fire started.....	23
	Figure A.6 – Distribution of identified causes of fire incidents	23
	Figure A.7 – Number of incidents over operation system age.....	25
	Table A.1 – Number of incidents with a certain damage	21

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MANAGING FIRE RISK RELATED TO PHOTOVOLTAIC (PV)
SYSTEMS ON BUILDINGS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"); the preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 63226, which is a Technical Report, has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

The text of this Technical Report is based on the following documents:

Draft TR	Report on voting
82/1500/DTR	82/1553A/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

PV systems provide electric energy in an environmentally beneficial way. They work silently, without pollution or other emissions and can be mounted nearly anywhere in close proximity to where people use electricity including living, working and sleeping facilities. However, since they contain electrical equipment, they share a similar risk of causing damage on both the DC side and on the AC side of an installation as any electric or electronic equipment.

This document is about fire prevention measures and additional measures for supporting firefighters. In general, PV systems are considered safe when relevant product and installation standards are applied. But even for PV systems installed according to relevant safety standards, there is a remaining risk that a fire is caused by the PV system. Additional measures are considered to further improve the situation at special locations, independent of whether the PV or an external event is the source of a fire. Also the restrictions to firefighters facing damaged PV systems in case of fire are considered in general.

At some locations or buildings there are greater needs due to higher risks. For such locations additional requirements often apply. This is why building and fire codes often vary based upon risks to safety. Also in the installation standards there are additional requirements for fire safety, for example IEC 60364-4-42 or IEC 60364-5-51. In case of higher risks regarding fire, people's safety, and financial risks, additional measures are reasonable depending on the building itself. This document is designed to assist PV designers and insurance companies to select suitable measures to address the on-site specific needs of special locations. This document contains measures for reducing risks in general and depending on the on-site conditions.

General information is provided to further reduce fire risks of PV systems. Also, information is given how to handle PV systems after a fire.

MANAGING FIRE RISK RELATED TO PHOTOVOLTAIC (PV) SYSTEMS ON BUILDINGS

1 Scope

This document, which is a Technical Report, is intended for use as guidance for reducing fire risks in general and for site-specific needs for buildings with PV systems. In addition to the general recommendations, technical, installation, and maintenance measures can be selected to reach the intended safety level of the PV system and building, depending on the results of a risk assessment. This document contains general information about building related risks and includes measures for reducing those risks. These measures are not general requirements or recommendations. They are explained as a guide for selecting suitable measures depending on the on-site needs.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

4 Risk evaluation

4.1 General

It is recommended to perform a risk evaluation, to identify, if additional measures are needed and which measures are reasonable in order to reach the intended safety level. Such a site-specific evaluation can help the needs of all stakeholders to be covered without putting unnecessary requirements on all PV systems.

4.2 Site selection

The selection of the site can have a major impact on the recommended measures. The designer should evaluate if the proposed building or part of the building is the best choice for a PV installation. Shifting to another part of the building, to another building or to a ground installation can be a reasonable step to avoid additional measures.

The fire zones and the position of fire protection walls should be evaluated. The PV array should not provide a fire path (bridge) between adjacent fire zones.

4.3 Aspects for building risk evaluation

4.3.1 Roofing materials

Roofing materials have an impact on how much damage an exterior fire will cause to a building. In some countries, for example USA, building codes require fire ratings of roofing systems