



BSI Standards Publication

**High voltage direct current (HVDC)  
substation audible noise**

---

## National foreword

This Published Document is the UK implementation of IEC TS 61973:2012+A1:2019. It supersedes PD IEC/TS 61973:2012, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee PEL/22, Power electronics.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019  
Published by BSI Standards Limited 2019

ISBN 978 0 580 97755 8

ICS 29.240.99; 29.240.10

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 April 2012.

### Amendments/corrigenda issued since publication

Date	Text affected
31 May 2019	Implementation of IEC amendment A1:2019



# IEC/TS 61973

Edition 1.0 2012-04

## TECHNICAL SPECIFICATION



---

**High voltage direct current (HVDC) substation audible noise**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE **XC**

ICS 29.240.10; 29.240.99

ISBN 978-2-8322-0077-3

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	7
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions.....	10
3.1 Sound and noise terms.....	10
3.2 Sound radiation terms.....	14
3.3 Acoustic fields.....	16
4 Environmental influences.....	16
4.1 General.....	16
4.2 Directivity of sound radiation.....	16
4.3 Background noise.....	17
4.4 Topography.....	19
4.5 Meteorological conditions.....	20
5 Noise level limits.....	21
5.1 General.....	21
5.2 Regulations.....	22
5.2.1 Noise level limits.....	22
5.2.2 Noise level measurement.....	22
5.3 Land-use classifications.....	22
5.4 Location of required performance limits.....	23
5.4.1 General.....	23
5.4.2 At the fence surrounding the HVDC substation or at the border of the substation owner's property.....	23
5.4.3 At the given contour away from the HVDC substation (e.g. on a circle perimeter or beyond a property border line).....	23
5.4.4 At the border of a nearby property.....	23
5.5 Relationship of performance limits to time duration.....	24
5.6 Typical noise performance limits.....	24
5.6.1 General.....	24
5.6.2 Specific A-weighted sound pressure levels.....	24
5.6.3 Maximum allowable increase over background noise levels.....	24
6 Sound emitting sources.....	25
6.1 General.....	25
6.2 Converter transformer.....	25
6.2.1 Noise sources in a converter transformer.....	25
6.2.2 Comparison with a.c. power transformers.....	26
6.2.3 Special features of HVDC converter transformers.....	26
6.2.4 Transformer winding noise.....	27
6.3 Reactors.....	28
6.3.1 Type and design of HVDC reactors.....	28
6.3.2 Mechanism of sound generation.....	28
6.3.3 AC filter reactors.....	33
6.3.4 HVDC smoothing reactors.....	34
6.3.5 Self-tuned filter reactors.....	35
6.4 Capacitors.....	36
6.4.1 Type and design of capacitors.....	36

6.4.2	Mechanism of sound generation .....	36
6.5	Cooling fans .....	39
6.6	Other sound-emitting sources .....	40
6.6.1	Switching devices .....	40
6.6.2	Synchronous compensators .....	41
6.6.3	Diesel generators .....	41
6.6.4	Air conditioning plant .....	41
6.6.5	Cooling circuit pumps .....	41
6.6.6	Converter valves .....	41
6.6.7	Air compressors .....	42
6.6.8	Corona sources .....	42
6.7	Typical sound power levels of sound emitting sources .....	42
7	Sound reduction measures .....	42
7.1	General .....	42
7.2	Substation layout .....	43
7.2.1	General .....	43
7.2.2	Transformers and tanked reactors .....	43
7.2.3	Air-cored reactors .....	43
7.2.4	Capacitors .....	44
7.2.5	Cooling fans .....	44
7.2.6	Diesel generators .....	44
7.2.7	Switching devices .....	44
7.2.8	Air conditioning plant .....	44
7.2.9	Corona sources .....	44
7.2.10	Synchronous compensators .....	44
7.3	Component design .....	45
7.3.1	General .....	45
7.3.2	Transformers and tanked reactors .....	45
7.3.3	Air-cored reactor .....	45
7.3.4	Capacitors .....	45
7.3.5	Cooling fans .....	46
7.3.6	Pumps and diesel generators .....	46
7.3.7	Switching devices .....	46
7.3.8	Air conditioning plant .....	46
7.3.9	High voltage connections .....	46
7.4	Sound enclosures .....	46
7.4.1	General .....	46
7.4.2	Transformers and tanked-reactors .....	46
7.4.3	Air-cored reactors .....	47
7.4.4	Capacitors .....	47
7.5	Retrofitable techniques .....	48
7.5.1	Enclosures .....	48
7.5.2	Damping .....	48
7.5.3	Active noise and vibration mitigation .....	48
8	Operating conditions .....	48
8.1	General .....	48
8.2	Normal operating conditions .....	49
8.3	Exceptional operating conditions .....	50
8.4	Operating conditions specified for verification .....	51

9	Sound level prediction .....	51
9.1	General .....	51
9.2	Modelling of plant .....	52
9.2.1	General .....	52
9.2.2	Layout .....	52
9.2.3	Source .....	52
9.2.4	Transmission path .....	52
9.3	Calculation procedure .....	53
9.3.1	Sequence of calculation .....	53
9.3.2	Calculation of attenuation terms .....	55
9.3.3	Results presentation .....	59
10	Verification of component sound power .....	61
10.1	General .....	61
10.2	Calculation .....	61
10.2.1	General .....	61
10.2.2	Calculation of force spectrum .....	62
10.2.3	Transfer function calculation .....	62
10.2.4	Sound power calculation .....	63
10.3	Measurement .....	64
10.3.1	General aspects on sound power determination .....	64
10.3.2	Sound pressure measurement .....	66
10.3.3	Corrections for background noise .....	67
10.3.4	Sound intensity measurement .....	67
10.4	Combination of calculation and measurement .....	69
10.4.1	General .....	69
10.4.2	Verification of key components .....	69
10.4.3	Verification of key components at site .....	69
11	Verification of sound levels from the HVDC substation .....	70
11.1	General .....	70
11.2	Acoustic environment .....	71
11.3	Conditions for verification .....	71
11.4	Calculation .....	71
11.5	Measurement .....	72
11.6	Combination of calculation and measurement .....	72
12	Parameters to be specified .....	74
12.1	General .....	74
12.2	Noise level measurement .....	74
12.3	Data to be presented by customers, or to be investigated by contractors .....	74
12.3.1	Land-use classification, noise regulation and limits .....	74
12.3.2	Environmental condition .....	75
12.3.3	Operation condition of HVDC substation .....	77
12.4	Data to be clarified by contractors .....	77
12.4.1	Noise of components .....	77
12.4.2	Noise prediction of the HVDC substation .....	77
12.4.3	Noise measurement on the site .....	78
Annex A (normative) Procedure to correct for background noise in HVDC and SVC plants .....		79
Bibliography .....		84

Figure 1 – Spherical spreading in a free-field from a point source .....	17
Figure 2 – Hemispherical spreading from a point source .....	18
Figure 3 – Quarter-spherical spreading from a point source .....	18
Figure 4 – Explanation of specific and background noise .....	19
Figure 5 – Example of reflecting hill and low ground .....	19
Figure 6 – Example of sound refraction with the shown wind gradient .....	20
Figure 7 – Sound travels faster near the ground .....	21
Figure 8 – Sound travels slower near the ground .....	21
Figure 9 – Dry-type air-core reactor .....	22
Figure 10 – Magnetic field of an air-core reactor winding .....	30
Figure 11 – Simplified shape of the symmetrical breathing mode of a reactor winding .....	31
Figure 12 – Example of flexural modes (bending modes) for a simply supported winding layer without axial constraint .....	32
Figure 13 – Example of spectrum of currents through a.c. filter reactor .....	33
Figure 14 – Example of spectrum of forces acting on the reactor winding .....	34
Figure 15 – Example of spectrum of currents through an HVDC smoothing reactor .....	34
Figure 16 – Example of spectrum of forces acting on the reactor winding .....	35
Figure 17 – Reactor for self-tuned filter applications .....	35
Figure 18 – Capacitor element package with capacitor elements .....	36
Figure 19 – Forces in a capacitor element .....	37
Figure 20 – Example of spectrum of voltages across the capacitor .....	38
Figure 21 – Example of spectrum of electrostatic forces in a capacitor .....	39
Figure 22 – Explanation of AC network harmonics and converter harmonics .....	50
Figure 23 – Examples of transmission paths from source to receiver .....	53
Figure 24 – Grouping of point sources to one equivalent source if the measurement distance ( $r$ ) is larger than $2a$ .....	54
Figure 25 – Definition of geometrical parameters used for calculation of screening .....	56
Figure 26 – Reflecting obstacles are treated by mirror sources .....	57
Figure 27 – Definition of parts for calculation of ground attenuation .....	57
Figure 28 – Definition of parameters used in Equation 38 .....	59
Figure 29 – Example of graphical presentation of sound pressure level calculation .....	60
Figure 30 – Three steps to determine the sound power of HVDC components .....	62
Figure 31 – Linear transfer function between e.g. force and vibration velocity for a 1-DOF system with the resonance frequency 500 Hz .....	63
Figure 32 – Definitions of the parameters used in Equation (42) .....	67
Figure 33 – Combination of calculation and measurement in determining the sound pressure level .....	72
Figure 34 – Example of layout of noise sources of an HVDC substation .....	73
Figure 35 – HVDC substation and example of microphone positions for determination of sound power levels .....	73
Figure A.1 – Example of a background correction at 1/24 octave band resolution .....	80
Table 1 – Examples of component sound power level .....	42
Table 2 – Normal operating conditions .....	50

Table 3 – Exceptional operating conditions .....	51
Table 4 – Examples of atmospheric attenuation coefficients .....	56
Table 5 – Examples of attenuation coefficient values for octave bands .....	59
Table 6 – Groups of noise sources .....	60
Table 7 – Ranking of noise sources .....	61
Table 8 – Vibration force frequency spectrum resulting from the electrical fundamental frequency 50 Hz and its 11 <sup>th</sup> harmonic .....	62
Table 9 – Summary of different methods for sound power determination .....	69
Table 10 – Land use classification .....	74
Table 11 – Existence different noise limits at different times .....	75
Table 12 – Existence of noise limits due to further regulation .....	75
Table 13 – Definition of noise limits at different locations .....	75
Table 14 – Existence of background noise limits at different locations and different times .....	75
Table 15 – Compilation of relevant topographical features .....	76
Table 16 – Compilation of relevant meteorological conditions .....	76
Table 17 – Compilation of further noise related weather conditions .....	76
Table 18 – Existence of additional locations with relevant noise limits .....	76
Table 19 – Possibility of future development .....	76
Table 20 – Other sources of audible noise .....	76
Table 21 – Definition of operating condition during audible noise measurement .....	77
Table 22 – Further conditions relevant for audible noise measurement .....	77
Table 23 – List of audible noise sources to be installed .....	77
Table 24 – Contents of an audible noise prediction report .....	78
Table 25 – Contents of an audible noise measurement report .....	78
Table A.1 – Total sound level for the PVC example .....	81

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**HIGH VOLTAGE DIRECT CURRENT (HVDC)  
SUBSTATION AUDIBLE NOISE**
**FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the prospect but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 61973, which is a technical specification, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment, with the participation of IEC technical committee 115: High voltage direct current (HVDC) transmission for DC voltages above 100 kV.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
22F/243/DTS	22F/260/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## HIGH VOLTAGE DIRECT CURRENT (HVDC) SUBSTATION AUDIBLE NOISE

### 1 Scope

This technical specification applies to the specification and evaluation of outdoor audible noise from high voltage direct current (HVDC) substations. It is intended to be primarily for the use of the utilities and consultants who are responsible for issuing technical specifications for new HVDC projects with and evaluating designs proposed by prospective contractors. It is primarily intended for HVDC projects with line-commutated converters. Part of this technical specification can also be used for the same purpose for HVDC projects using voltage sourced converters, and for flexible a.c. transmission systems (FACTS) devices such as static Var compensators (SVCs) and static synchronous compensators (STATCOMs).

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

- A1 IEC 60076-10, *Power transformers – Part 10: Determination of sound levels* A1
- A1 IEC 60076-10-1, *Power transformers – Part-10-1: Determination of sound levels – Application guide* A1
- IEC 61672-1, *Electroacoustics – Sound level meters – Part 1: Specifications*
- IEC 61672-2, *Electroacoustics – Sound level meters – Part 2: Pattern evaluation tests*
- ISO 1996-2, *Acoustics – Description, assessment and measurement of environmental noise – Part 2: Determination of environmental noise levels*
- ISO 266:1997, *Acoustics – Preferred frequencies*
- ISO 3740, *Acoustics – Determination of sound power levels of noise sources – Guidelines for the use of basic standards*
- ISO 3743-2, *Acoustics – Determination of sound power levels of noise sources; engineering methods for small, movable sources in reverberant fields – Part 2: Methods for special reverberation test rooms*
- ISO 3744, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Engineering methods for an essentially free field over a reflecting plane*
- ISO 3745, *Acoustics – Determination of sound power levels of noise sources using sound pressure – Precision methods for anechoic and hemi-anechoic rooms*
- ISO 3746, *Acoustics – Determination of sound power levels and sound energy levels of noise sources using sound pressure – Survey method using an enveloping measurement surface over a reflecting plane*
- ISO 8297, *Acoustics – Determination of sound power levels of multisource industrial plants for evaluation of sound pressure levels in the environment – Engineering method*
- ISO 9613-1, *Acoustics – Attenuation of sound during propagation outdoors – Part 1: Calculation of the absorption of sound by the atmosphere*