



BSI Standards Publication

Microgrids

Part 3-2: Technical requirements — Energy management systems

National foreword

This Published Document is the UK implementation of IEC TS 62898-3-2:2024.

The UK participation in its preparation was entrusted to Technical Committee GEL/8, Systems Aspects for Electrical Energy Supply.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2024
Published by BSI Standards Limited 2024

ISBN 978 0 55 00401 4

ICS 29.240.01

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 January 2024.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



IEC TS 62898-3-2

Edition 1.0 2024-01

TECHNICAL SPECIFICATION



**Microgrids –
Part 3-2: Technical requirements – Energy management systems**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01

ISBN 978-2-8322-8075-1

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD..... 6

INTRODUCTION..... 8

1 Scope..... 9

2 Normative references 10

3 Terms, definitions and abbreviated terms 11

 3.1 Terms and definitions..... 11

 3.2 Abbreviated terms..... 12

4 General 12

 4.1 System architecture and functional mapping 13

 4.2 Stand-alone MEMS 14

 4.3 Integrated MEMS 14

 4.4 Communication protocols and cyber security 14

 4.4.1 Basic principle 14

 4.4.2 Recommended methods 14

 4.4.3 Cyber security 16

 4.5 Overview of MEMS function requirement..... 16

5 Functional requirements 18

 5.1 Dispatch optimization..... 18

 5.1.1 Dispatch and scheduling models..... 18

 5.1.2 Dispatch optimization modes and objective functions..... 19

 5.1.3 Management of technical constraint conditions 20

 5.1.4 Optimization types and approaches 21

 5.2 Forecast function 22

 5.2.1 General 22

 5.2.2 Forecasting requirements and time dimension 22

 5.2.3 Renewable power generation forecast 23

 5.2.4 Load forecast..... 23

 5.2.5 Electricity price forecast 23

 5.2.6 Input values of forecast 23

 5.3 Demand side integration 24

 5.3.1 General 24

 5.3.2 Demand side management 24

 5.3.3 Demand side response 24

 5.3.4 Energy optimisation 25

 5.3.5 Power and energy exchange with upstream grid 25

 5.4 Flexible resource management 25

 5.4.1 General 25

 5.4.2 Controllable load management 26

 5.4.3 Energy management..... 26

 5.5 Data archiving, trending and reporting 26

 5.6 Market trading module (ancillary services) and market data 26

Annex A (informative) Examples of actual microgrid application cases integrated with associated functions of MEMS 27

 A.1 General..... 27

 A.2 Application CN1: Obtaining lower energy cost, lower pollution emission, and higher penetration level of renewable energy 27

 A.2.1 Overview 27

A.2.2	System structure.....	27
A.2.3	Energy management system.....	28
A.2.4	Energy management system operation	28
A.3	Application CN2: Enhancing local power supply reliability for critical loads with AC/DC hybrid microgrid	29
A.3.1	Overview	29
A.3.2	System structure.....	30
A.3.3	Energy management strategy	30
A.3.4	Operation modes	31
A.3.5	Black start	31
A.3.6	Energy management strategy	32
A.3.7	Operation modes	32
A.3.8	Black start	33
A.4	Application DE1: Intelligent, data-driven, and grid stabilizing energy management platform – Developing a pilot for industrial diesel application	33
A.4.1	Overview	33
A.4.2	System structure – IDGE Platform	34
A.4.3	Energy management strategy	36
A.4.4	Demonstrator and evaluation	39
A.5	Application CN4: Electrifying islands with wind-PV diesel-energy storage and hybrid microgrids.....	41
A.5.1	Overview	41
A.5.2	Purpose.....	42
A.5.3	Main functions of MEMS	42
A.5.4	Applications.....	42
A.6	Application CN5: Optimizing local energy resources with demand side integrated microgrid including PV and energy storage.....	43
A.6.1	Overview	43
A.6.2	Purpose.....	43
A.6.3	Main functions of MEMS	43
A.6.4	Applications.....	44
A.7	Application JP1: Local independent grid supplied by an energy production system of combining biomass, biogas, wood chip co-firing, photovoltaic and small wind power: the Hachinohe demonstration project from Japan	45
A.7.1	Overview	45
A.7.2	Purpose.....	46
A.7.3	Main functions of the control system	46
A.7.4	Applications.....	47
A.8	Application JP2: Islanding operation of microgrid with only converter connected resources and no-rotating machine: the 2005 World Exposition, Aichi, from Japan	49
A.8.1	Overview	49
A.8.2	Purpose.....	50
A.8.3	Main functions of the control system	51
A.8.4	Applications.....	52
A.9	Application JP3: Grasping the impact of mass solar power generation on the actual power system and empirical research on system stabilization measures using storage batteries: Miyakojima Mega Solar Demonstration Research	53
A.9.1	Overview	53
A.9.2	Purpose.....	56

A.9.3	Main functions of the control system	56
A.9.4	Applications	56
A.10	Application IN1: Microgrid dedicated for energy communities on a public distribution grid: Shakti demonstration in H2020 IElectrix project	59
A.10.1	Overview	59
A.10.2	Purpose	60
A.10.3	Main functions of the MEMS	60
A.10.4	Cybersecurity	62
A.10.5	Additional applications	62
A.11	Application QAT1: Desert microgrid, research microgrid in desert environment, education city Doha, Qatar	63
A.11.1	Overview	63
A.11.2	System description	63
A.11.3	Energy management system (EMS)	64
A.11.4	Operational modes	64
Annex B (informative)	Communication and data exchange	66
B.1	Information exchange and MEMS	66
B.2	EMS-API reference model (IEC 61970-1)	66
B.3	Architecture of the communication system	67
Bibliography	69
Figure 1	– Conceptual map of a power system consisting of a microgrid	13
Figure 2	– Functional mapping for operation and control of microgrids	13
Figure 3	– Typical three-layer communication for structure 1	15
Figure 4	– Typical two-layer communication for structure 2	16
Figure 5	– Microgrid energy management system functional architecture	17
Figure A.1	– The main single diagram of on wind microgrid	28
Figure A.2	– Application of EES for wind generation and load matching	29
Figure A.3	– Electric network topology of Shangyu AC/DC microgrid	30
Figure A.4	– Basic structure of the EDGE Platform	34
Figure A.5	– Functional requirements	35
Figure A.6	– Interplay of Layer 1 and Layer 2	36
Figure A.7	– Model reaction	37
Figure A.8	– Technical platform layout	39
Figure A.9	– Dong'ao Island microgrid network topology	41
Figure A.10	– Guishan Island Microgrid network topology	42
Figure A.11	– Snapshot of active power and reactive power sharing among diesel generator	43
Figure A.12	– Solar power and load forecasting in Foshan industrial microgrid	44
Figure A.13	– Example of power generation and consumption detailed on a particular day in Foshan industrial microgrid	44
Figure A.14	– Air conditioner power consumption and space temperature for a particular user in Guangzhou residential microgrid	45
Figure A.15	– Overview of Hachinohe demonstration project	46
Figure A.16	– Hierarchical structure of the energy management system	47
Figure A.17	– Performances for grid connected operation: deviation from planned flow	47
Figure A.18	– Obtained success rate of maintaining frequency and voltage	48

Figure A.19 – Overall performance under different battery operation modes	49
Figure A.20 – Overview of equipment configuration	50
Figure A.21 – Appearance of equipment	50
Figure A.22 – PAFC system configuration	51
Figure A.23 – Block diagram for isolated operation	52
Figure A.24 – Power quality (voltage and frequency on Oct. 11 th)	53
Figure A.25 – Overview of the Miyakojima island power system	54
Figure A.26 – Overview of the demonstration research facility	55
Figure A.27 – Picture of the demonstration research facility	56
Figure A.28 – Result of the PV + NaS storage long term operation	57
Figure A.29 – NaS storage operation for short term power fluctuation levelling	57
Figure A.30 – Example of output fluctuation suppression effect	58
Figure A.31 – Image of frequency fluctuation suppression effect	59
Figure A.32 – SHAKTI pilot architecture	60
Figure A.33 – Microgrid SCADA example	61
Figure A.34 – Example of PV monitoring in the EMS	61
Figure A.35 – Example of off-grid mode preparation	62
Figure A.36 – Electric network topology of the Desert- μ Grid	63
Figure A.37 – Energy management system of the Desert- μ Grid	64
Figure B.1 – EMS-API reference model	67
Figure B.2 – Reference architecture based on IEC TR 62357-1	68
Table A.1 – Operation modes	32
Table A.2 – Description of the microgrid	43
Table A.3 – Description of the microgrids	48
Table A.4 – Outline of the facility	54
Table B.1 – Examples of information exchange	66

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MICROGRIDS –

Part 3-2: Technical requirements –
Energy management systems

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publications"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62898-3-2 has been prepared by subcommittee 8B: Decentralized electrical energy systems, of IEC technical committee TC 8: System aspects of electrical energy supply. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
8B/153/DTS	8B/177/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62898 series, published under the general title *Microgrids*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Microgrids can serve various purposes depending on the primary objectives of their applications. They are usually seen as a technical means to manage reliability of supply and to facilitate local optimization of energy supply by controlling distributed energy resources (DER). Microgrids also present a way to provide electricity supply in remote areas, to use renewable energy as a systematic approach for rural electrification and to increase resiliency and security of supply to end users.

IEC TS 62898 series is intended to provide general guidelines and technical requirements for microgrid projects.

IEC TS 62898-1 mainly covers the following issues:

- determination of microgrid purposes and application,
- preliminary study necessary for microgrid planning, including resource analysis, load forecast, DER planning and power system planning,
- principles of microgrid technical requirements that should be specified during planning stage,
- Microgrid evaluation to select an optimal microgrid planning scheme

IEC TS 62898-2 mainly covers the following issues:

- operation requirements and control targets of microgrids under various operation modes,
- the basic control strategies and methods under various operation modes,
- the requirements of electrical energy storage (EES), relay protection, monitoring and communication under various operation modes
- power quality.

IEC TS 62898-3-XX subseries technical specifications deal with the technical requirements of microgrids.

IEC TS 62898-3-1 covers the protection and dynamic control of microgrids.

The present document covers microgrid energy management systems (MEMS).

MICROGRIDS –

Part 3-2: Technical requirements – Energy management systems

1 Scope

The purpose of this part of IEC 62898 is to provide technical requirements for the operation of energy management systems of microgrids. This document applies to utility-interconnected or islanded microgrids. This document describes specific recommendations for low-voltage (LV) and medium-voltage (MV) systems.

This document focuses on developing standards of energy management systems aimed for microgrids integrated in decentralized energy systems or public distribution grids. It concerns some particularities that are not totally covered by the existing conventional energy system. The microgrid energy management systems are being studied by various actors (utilities, manufacturers, and energy providers) on actual demonstration projects and application use case. The aims of this document are to make the state of the art of existing energy management systems used in actual microgrids projects, to classify the relevant functions which can be accomplished by microgrid energy management systems, and to recommend necessary technical requirements for energy management systems of future microgrids.

This document includes the following items:

- main performances of key components of microgrid: decentralized energy resources, energy storages and controllable loads),
- description of main functions and topological blocks of microgrid energy management systems (MEMS),
- specification of information exchange protocol between main function blocks, linked to microgrid monitoring and control systems (MMCS).

Main functions of MEMS:

- power and energy management among different resources within microgrid including active and reactive power flows with different time scales,
- power and energy forecasts of microgrid,
- energy balancing between upstream grid and microgrid energy resources according to power and energy forecast and upstream and local constraints,
- economic and environmental optimization,
- possible service capacities such as capacity market auctions and resiliency anticipation: new business models,
- data archiving, trending, reporting and evaluation of operation capacities in various operation modes.

MEMS can have some other additional functions according to microgrid size and actual application cases:

- tariff and market trading management,
- utility ancillary services such as frequency regulation, voltage regulation, power quality and reliability improvement, demand response possibilities, change of operation modes linked to MMCS.