



BSI Standards Publication

UHV AC transmission systems

Part 202: UHV AC Transmission line design

National foreword

This Published Document is the UK implementation of IEC TS 63042-202:2021.

The UK participation in its preparation was entrusted to Technical Committee GEL/8, Systems Aspects for Electrical Energy Supply.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2021
Published by BSI Standards Limited 2021

ISBN 978 0 55 05445 3

ICS 29.240.20

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 November 2021.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



IEC TS 63042-202

Edition 1.0 2021-10

TECHNICAL SPECIFICATION



**UHV AC transmission systems –
Part 202: UHV AC Transmission line design**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.20

ISBN 978-2-8322-1035-7

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	10
1 Scope.....	12
2 Normative references	12
3 Terms and definitions	13
4 Symbols and abbreviations.....	13
5 UHV AC transmission line requirements	14
5.1 General requirements	14
5.2 Reliability requirements.....	14
5.3 Electrical requirements	14
5.4 Security requirements.....	14
5.5 Safety requirements.....	14
5.6 Environmental impact.....	14
5.7 Economy.....	14
6 Selection of clearance	15
6.1 General.....	15
6.2 Air gap, tower clearances (strike distance).....	15
6.2.1 Power frequency voltage	15
6.2.2 Switching overvoltage.....	15
6.2.3 Lightning overvoltage	15
6.3 Phase to phase spacing (Horizontal, Vertical).....	16
6.4 Ground clearances – Statutory requirements, electric and magnetic field limits.....	16
6.5 Conductor-earth wire spacing, shielding angle – Lightning performance criteria.....	16
7 Insulation coordination, insulator and insulator string design	17
7.1 General.....	17
7.2 Insulation requirements – electrical design considerations	17
7.3 Insulating materials, type of insulators	17
7.4 Insulator string configurations for disc type insulators	18
7.5 Mechanical design criteria of insulator strings and associated hardware fittings.....	19
8 Bundle-conductor selection.....	19
8.1 General.....	19
8.2 Conductor types.....	19
8.3 Bundle conductor configurations	20
8.3.1 Number of sub-conductors.....	20
8.3.2 Bundle spacing.....	20
8.4 Conductor bundle selection process.....	20
8.4.1 Cross-section of conductor	20
8.4.2 Conductor ampacity.....	20
8.4.3 Requirements for electromagnetic environment	21
8.4.4 Capital cost and loss evaluation	21
8.5 Mechanical strength.....	21
8.6 Conductor accessories.....	22
8.6.1 General requirements for fittings.....	22
8.6.2 Type and design features of link fittings, vibration dampers, spacers.....	22
9 Earth wire/OPGW selection	23

9.1	General.....	23
9.2	Type of earth wire/OPGW	23
9.3	Design Criteria/Requirements Specific to UHV Lines.....	23
9.4	Induced voltages on earth wire	23
10	Tower and foundation design.....	24
10.1	General.....	24
10.2	Tower classification	24
10.2.1	General	24
10.2.2	Conductor configuration.....	24
10.2.3	Constructional features.....	29
10.2.4	Line deviation angle.....	29
10.2.5	Tower extensions	30
10.2.6	Specific requirements	30
10.3	Tower design	30
10.3.1	General	30
10.3.2	Selection of tower geometry based on electrical clearances	30
10.3.3	Calculation of loads on tower.....	31
10.3.4	Analysis using software	31
10.3.5	Full scale tower testing	32
10.3.6	Tower design methodology	32
10.4	Foundation design	33
10.4.1	General	33
10.4.2	Open cast type foundations	34
10.4.3	Raft type foundations.....	34
10.4.4	Deep foundations (Pile/Well/Pier/Steel Anchor type).....	35
11	Environmental considerations.....	35
11.1	General.....	35
11.2	Electric field	35
11.2.1	General	35
11.2.2	Reference level of electric field.....	35
11.2.3	Prediction of electric field	36
11.2.4	Mitigation measures of electric field	36
11.3	Magnetic field	36
11.3.1	General	36
11.3.2	Reference level of magnetic field	36
11.3.3	Prediction of magnetic field.....	36
11.3.4	Mitigation measures of magnetic field	37
11.4	Corona noise (audible noise with corona discharge)	37
11.4.1	General	37
11.4.2	Characteristics of corona noise.....	37
11.4.3	Reference level of corona noise.....	37
11.4.4	Prediction of corona noise	38
11.4.5	Mitigation measures of corona noise.....	38
11.5	Radio interference with corona discharge	38
11.5.1	General	38
11.5.2	Characteristics of radio interference	38
11.5.3	Reference level of radio interference	39
11.5.4	Prediction of radio interference	39
11.5.5	Mitigation measures of radio interference	39

11.6	Wind noise.....	39
Annex A (informative) Experimental results and considerations on environmental performance of UHV AC transmission lines in different countries		
A.1	General.....	40
A.2	Experimental results and considerations on environmental performance of UHV AC transmission lines in China	40
A.2.1	Radio interference	40
A.2.2	Audible noise.....	40
A.2.3	Electric field.....	41
A.3	Experimental results and considerations on environmental performance of UHV AC transmission lines in India.....	41
A.3.1	Electrical Clearances from buildings, structures, etc.	41
A.3.2	Electric field.....	41
A.3.3	Radio interference	41
A.3.4	Audible noise.....	41
A.4	Experimental results and considerations on environmental performance of UHV AC transmission lines in Japan	42
A.4.1	General	42
A.4.2	AN (audible noise).....	42
A.4.3	RI (Radio Interference)	43
A.4.4	EMF (Electromagnetic field).....	43
A.4.5	Electromagnetic induction interference, Electrostatic induction interference	45
A.4.6	Wind noise from conductor	45
A.4.7	Ice and snow falling from conductor	46
A.4.8	Landscape impact.....	47
A.4.9	Nature conservation.....	48
Annex B (informative) Design practice of UHV AC transmission lines in different countries.....		
B.1	General.....	50
B.2	Design practice in China	50
B.2.1	General	50
B.2.2	Conductor and earth wire.....	50
B.2.3	Electrical clearances.....	52
B.2.4	Insulation coordination.....	53
B.2.5	Tower and foundation	56
B.3	Design practice in India.....	58
B.3.1	General	58
B.3.2	Challenges in development and solutions	58
B.3.3	Conductor selection	58
B.3.4	Electrical clearances.....	60
B.3.5	Insulation requirements	61
B.3.6	1 200 kV test line.....	62
B.3.7	400 kV double circuit (upgradable to 1 200 kV single circuit) line.....	63
B.4	Design practice in Japan.....	65
B.4.1	General	65
B.4.2	Conductor and earth wire.....	66
B.4.3	Insulation coordination.....	67
B.4.4	Wind noise	70
B.4.5	Tower and foundation	71

Annex C (informative) Construction practice of UHV AC transmission lines in different countries.....	74
C.1 General.....	74
C.2 Construction practice in China	74
C.3 Construction practice in India.....	75
C.4 Construction practice in Japan	75
Annex D (informative) Flashover voltage test result for air clearances in different countries.....	77
D.1 General.....	77
D.2 Flashover voltage test result for air clearances in China	77
D.2.1 50 % Power frequency flashover voltage test results for air clearances of transmission line structures	77
D.2.2 50 % Switching impulse flashover voltage test results for air clearances of transmission line structures	80
D.2.3 50 % Lightning impulse flashover voltage test results for air clearances of transmission line structures	89
D.2.4 Effects of switching overvoltage time to peak on flashover voltage	92
D.2.5 Tower width correction approaches for air clearances of transmission line structures.....	93
D.3 Flashover voltage test result for air clearances in India.....	95
D.4 Flashover voltage test result for air clearances in Japan	95
D.4.1 50 % Power frequency flashover voltage test results of transmission line structures	95
D.4.2 50 % Switching impulse flashover voltage test results for air clearances of transmission line structures	96
D.4.3 50 % lightning impulse flashover voltage test results for air clearances of transmission line structures	100
Annex E (informative) Restrictions on electromagnetic environment of UHV AC transmission lines in different countries	102
E.1 General.....	102
E.2 Restrictions in China.....	102
E.3 Restrictions in India	102
E.4 Restrictions in Japan	103
E.4.1 General	103
E.4.2 RI (Radio Interference).....	103
E.4.3 AN (Audible Noise)	103
E.4.4 Electric field.....	103
E.4.5 Magnetic field	104
E.4.6 Communication failure due to electromagnetic induction or electrostatic induction.....	104
E.4.7 Overvoltage due to electromagnetic induction.....	104
Annex F (informative) Anti-vibration measures for conductors and earth wires in different countries.....	105
F.1 General.....	105
F.2 Anti-vibration measures in China	105
F.3 Anti-vibration measures in India	106
F.4 Anti-vibration measures in Japan	106
F.4.1 Conductor.....	106
F.4.2 Earth wire	106
Annex G (informative) Earth wire regulations in different countries	108
G.1 General.....	108

G.2	Earth wires regulations in China.....	108
G.3	Earth wires regulations in India.....	108
G.4	Earth wires regulations in Japan.....	108
	Bibliography.....	110
Figure 1	– Typical single circuit vertical configuration tower.....	25
Figure 2	– Typical double circuit vertical configuration tower.....	25
Figure 3	– Typical single circuit horizontal configuration tower.....	26
Figure 4	– Typical single circuit delta configuration tower.....	26
Figure 5	– Typical single circuit H-type tower.....	27
Figure 6	– Typical double circuit danube configuration tower.....	27
Figure 7	– 1 200 kV single circuit vertical configuration tower.....	28
Figure 8	– 1 200 kV single circuit horizontal configuration tower.....	28
Figure 9	– 1 200 kV double circuit vertical Configuration tower.....	28
Figure 10	– 1 200 kV single circuit H-type tower (for gantry).....	29
Figure 11	– Tower design methodology.....	33
Figure A.1	– Results of sensing tests under transmission lines.....	44
Figure A.2	– Symbols related to wind noise prediction formula.....	46
Figure B.1	– Composite insulator profiles.....	53
Figure B.2	– 1 200 kV insulator profile.....	55
Figure B.3	– 1 200 kV air-gap experimental tests.....	60
Figure B.4	– 1 200 kV single circuit test line.....	62
Figure B.5	– 1 200 kV double circuit test line.....	63
Figure B.6	– 1 200 kV upgradable line –Suspension tower.....	64
Figure B.7	– 1 200 kV upgradable line –Tension tower.....	64
Figure B.8	– 1 200 kV Tower Prototype Testing.....	65
Figure B.9	– UHV AC transmission lines in Japan.....	66
Figure B.10	– Shape of conductor.....	67
Figure B.11	– Shape of CPW.....	67
Figure B.12	– Foundation type.....	73
Figure C.1	– Machine for foundation construction.....	74
Figure D.1	– The arrangement of power frequency flashover voltage test for side-phase air clearances of 1 000 kV cat-head type towers.....	77
Figure D.2	– The 50 % power frequency flashover voltage characteristic for air clearance from side-phase conductor to tower body for 1 000 kV cat-head type towers.....	77
Figure D.3	– The arrangement of power frequency flashover voltage test for side-phase air clearances of 1 000 kV cup type towers.....	78
Figure D.4	– The 50 % power frequency flashover voltage characteristic for air clearance from side-phase conductor to tower body for 1 000 kV cup type towers.....	78
Figure D.5	– The arrangement of power frequency flashover voltage test for air clearances of 1 000 kV double-circuit lines.....	79
Figure D.6	– The 50 % power frequency flashover voltage characteristic for air clearance from middle-phase conductor with I-type string to tower body for 1 000 kV double-circuit lines.....	79

Figure D.7 – The arrangement of the power frequency flashover voltage test for air clearances of bottom-phase with I-type string of 1 000 kV double-circuit lines.....	80
Figure D.8 – The power frequency flashover voltage characteristic of air clearance from bottom-phase conductor (with I-type string) to tower body of 1 000 kV double-circuit lines	80
Figure D.9 – The arrangement of switching impulse flashover voltage test for side-phase air clearances of 1 000 kV cat-head type towers.....	81
Figure D.10 – The 50 % switching impulse flashover voltage characteristic for air clearances from conductor to tower body of 1 000 kV lines (with a time to peak of 250 μ s)	81
Figure D.11 – The arrangement of switching impulse flashover voltage test for middle-phase air clearances of 1 000 kV cat-head type towers.....	82
Figure D.12 – The arrangement of switching impulse flashover voltage test for side-phase air clearances of 1 000 kV cup type towers.....	82
Figure D.13 – The 50 % switching impulse flashover voltage characteristic for air clearances from conductor to tower body of 1 000 kV lines (with a time to peak of 250 μ s)	83
Figure D.14 – The arrangement of switching impulse flashover voltage test for middle-phase air clearances of 1 000 kV cup type towers.....	83
Figure D.15 – The arrangement of switching impulse flashover voltage test at long time to peak for middle-phase air clearances (with I-type string) of 1 000 kV double-circuit lines	84
Figure D.16 – The 50 % switching impulse (1 000 μ s) flashover voltage characteristic for air clearances from conductor to bottom crossarm of 1 000 kV double-circuit lines (a distance of 9,0 m between conductor and middle crossarm)	84
Figure D.17 – The arrangement of switching impulse flashover voltage test for air clearances from middle-phase conductor (with V-type string) to bottom crossarm of 1 000 kV double-circuit lines	85
Figure D.18 – The 50 % switching impulse (1 000 μ s) flashover voltage characteristic of air clearances from conductor to bottom crossarm of 1 000 kV double-circuit lines	85
Figure D.19 – The arrangement of switching impulse flashover test for air clearances from middle-phase conductor (with V-type string) to tower body of 1 000 kV double-circuit lines	86
Figure D.20 – The 50 % switching impulse (1 000 μ s) flashover voltage characteristic for air clearances from conductor to tower body of 1 000 kV double-circuit lines	86
Figure D.21 – The arrangement of switching impulse flashover voltage test for air clearances from middle-phase conductor (with V-type string) to middle crossarm of 1 000 kV double-circuit lines	87
Figure D.22 – The 50 % switching impulse (1 000 μ s) flashover voltage characteristic for air clearances from conductor to middle crossarm of 1 000 kV double-circuit lines.....	87
Figure D.23 – The arrangement of switching impulse flashover voltage test for air clearances from bottom-phase conductor (with V-type string) to crossarm of 1 000 kV double-circuit lines.....	88
Figure D.24 – The 50 % switching impulse (1 000 μ s) flashover voltage characteristic for air clearances from conductor to crossarm of 1 000 kV double-circuit lines.....	88
Figure D.25 – The arrangement of switching impulse flashover voltage test for air clearances from bottom-phase conductor (with V-type string) to tower body of 1 000 kV double-circuit lines.....	89
Figure D.26 – The 50 % switching impulse (1 000 μ s) flashover voltage characteristic for air clearances from conductor to tower body of 1 000 kV double-circuit lines	89
Figure D.27 – The 50 % lightning impulse flashover voltage characteristic for air clearances from side-phase conductor to tower body of 1 000 kV single-circuit lines	90

Figure D.28 – The arrangement of lightning impulse flashover voltage test for air clearances from middle-phase conductor (with I-type string) to bottom crossarm of 1 000 kV double-circuit lines	90
Figure D.29 – The 50 % lightning impulse flashover voltage characteristic for air clearances from conductor to lower crossarm of 1 000 kV double-circuit lines.....	91
Figure D.30 – The arrangement of lightning impulse flashover voltage test for air clearances from middle-phase conductor (with V-type string) to bottom crossarm of 1 000 kV double-circuit lines	91
Figure D.31 – The 50 % positive and negative lightning impulse flashover voltage characteristic for air clearances from conductor to lower crossarm of 1 000 kV double-circuit lines	92
Figure D.32 – Curve of the 50 % switching impulse flashover voltage as a function of the time to peak for the air clearance from conductor to tower leg of 5 m.....	92
Figure D.33 – Tower-width voltage correction factor	94
Figure D.34 – Tower-width spacing correction factor.....	94
Figure D.35 – Effects of tower leg width on switching impulse flashover voltage (with a time to peak of 720 µs)	95
Figure D.36 – The 50 % power frequency flashover voltage characteristic for air clearance for 1 000 kV	96
Figure D.37 – The arrangement of switching impulse flashover voltage test for air clearances of 1 000 kV tension type towers	97
Figure D.38 – The 50 % switching impulse flashover voltage characteristic for air clearances of 1 000 kV tension type towers	98
Figure D.39 – The arrangement of switching impulse flashover voltage test for air clearances of 1 000 kV suspension I type towers	98
Figure D.40 – The 50 % switching impulse flashover voltage characteristic for air clearances from conductor to tower body of 1 000 kV suspension I type towers	99
Figure D.41 – The arrangement of switching impulse flashover voltage test for air clearances of 1 000 kV suspension V type towers	99
Figure D.42 – The 50 % switching impulse flashover voltage characteristic for air clearances of 1 000 kV suspension V type towers	100
Figure D.43 – The 50 % Lightning impulse flashover voltage characteristic for air clearance for 1 000 kV	101
Figure F.1 – Resonance frequency type vibration damper	105
Figure F.2 – Shape of distributed damper	107
Table A.1 – Design limits for radio interference in China	40
Table A.2 – Criteria for environmental noises in the five categories of areas in cities (dB (A))	40
Table B.1 – Reference level of electric field and ground height of conductor	44
Table B.1 – Conductor type selection.....	50
Table B.2 – Conductor characteristics.....	51
Table B.3 – Coefficient k_j	52
Table B.4 – Recommended configuration of tension insulator string in light and medium ice zone	54
Table B.5 – Recommended configuration of tension insulator string in substation outlet span	54
Table B.6 – Recommended value of single circuit line air gap	55
Table B.7 – Recommended value of double circuit line air gap.....	55

Table B.8 – Conductor capacity	59
Table B.9 – Conductor surface gradient	59
Table B.10 – Conductor radio interference	59
Table B.11 – Conductor audible noise.....	59
Table B.12 – Conductor electric field	60
Table B.13 – Salient results of the experimental tests	61
Table B.14 – Salient features of the 1 200 kV test lines	63
Table B.15 – Salient features of 1 200 kV upgraded transmission line	65
Table B.16 – UHV AC transmission lines in Japan	66
Table B.17 – Conductor configuration and AN.....	66
Table B.18 – Specifications of insulator	68
Table B.19 – Withstand voltage of single insulator in pollution [kV/unit]	68
Table B.20 – Withstand voltage of single insulator under snow [kV/unit]	68
Table B.21 – Altitude correction factor K_1	69
Table B.22 – Loads for tower design	72
Table D.1 – Switching impulse flashover voltages of side-phase air clearances of 1 000 kV cat-head type towers with different test time to peak.....	81
Table D.2 – The switching impulse flashover voltage of air clearances from middle-phase conductor to tower for 1 000 kV full-scale towers.....	82
Table D.3 – The switching impulse flashover voltage for air clearance from the middle-phase conductor to tower window in the arrangement shown in Figure D.14 a) and Figure D.14 b).....	83
Table D.4 – Altitude correction factor K_1	96
Table D.5 – Gap coefficient k.....	96
Table D.6 – Altitude correction factor K_1	97
Table D.7 – Gap coefficient k.....	100
Table E.1 – Radio interference.....	102
Table E.2 – Audible noise	102
Table E.3 – Electric field	103
Table E.4 – Specific limits for noise of environmental regulation [dB(A)]	103
Table F.1 – Upper limit of everyday tension and anti-vibration measures for galvanized steel strand or aluminium clad steel strand	106

INTERNATIONAL ELECTROTECHNICAL COMMISSION

UHV AC TRANSMISSION SYSTEMS –**Part 202: UHV AC Transmission line design**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 63042-202 has been prepared by IEC technical committee 122: UHV AC transmission systems. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
122/113/DTS	122/116/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement,

available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

A list of all parts in the IEC 63042 series, published under the general title *UHV AC transmission systems*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

UHV AC TRANSMISSION SYSTEMS –

Part 202: UHV AC Transmission line design

1 Scope

This part of IEC 63042 provides common rules for the design of overhead transmission lines with the highest voltages of AC transmission systems exceeding 800 kV, so as to provide safety and proper functioning for the intended use.

This technical specification aims to give the main principles for the design of UHV AC overhead transmission lines, mainly including selection of clearance, insulation coordination and insulator strings design, bundle-conductor selection, earth wire/optical ground wires selection, tower and foundation design, environmental consideration. The design criteria apply to new construction, reconstruction and expansion of UHV AC overhead transmission line.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60826, *Design criteria of overhead transmission lines*

IEC 61284, *Overhead lines – Requirements and tests for fittings*

IEC 61854, *Overhead lines – Requirements and tests for spacers*

IEC 61897:2020, *Overhead lines – Requirements and tests for Stockbridge type aeolian vibration dampers*

IEC 60794-4-10, *Optical fiber cables – Part 4-10: Family specification – Optical ground wires (OPGW) along electrical power lines*

IEC TS 62993, *Guidance for determination of clearances, creepage distances and requirements for solid insulation for equipment with a rated voltage above 1 000 V AC and 1 500 V DC, and up to 2 000 V AC and 3 000 V DC*

IEC 62110, *Electric and magnetic field levels generated by AC power systems – Measurement procedures with regard to public exposure*

CISPR TR 18-1:2017, *Radio interference characteristics of overhead power lines and high-voltage equipment – Part 1: Description of phenomena*

CISPR TR 18-2:2017, *Radio interference characteristics of overhead power lines and high-voltage equipment – Part 2: Methods of measurement and procedure for determining limits*

CISPR TR 18-3:2017, *Radio interference characteristics of overhead power lines and high-voltage equipment – Part 3: Code of practice for minimizing the generation of radio noise*