



BSI Standards Publication

Effects of current on human beings and livestock

Part 2: Special aspects

National foreword

This Published Document is the UK implementation of IEC TS 60479-2:2017.

The UK participation in its preparation was entrusted to Technical Committee JPEL/64, Electrical Installations of Buildings – Joint Committee.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2017
Published by BSI Standards Limited 2017

ISBN 978 0 580 90940 5

ICS 13.200; 29.020

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 December 2017.

Amendments/corrigenda issued since publication

Date	Text affected
------	---------------



IEC TS 60479-2

Edition 4.0 2017-10

TECHNICAL SPECIFICATION



BASIC SAFETY PUBLICATION

**Effects of current on human beings and livestock –
Part 2: Special aspects**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 13.200; 29.020

ISBN 978-2-8322-4845-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	5
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Effects of alternating currents with frequencies above 100 Hz	10
4.1 General.....	10
4.2 Effects of alternating current in the frequency range above 100 Hz up to and including 1 000 Hz	11
4.2.1 Threshold of perception	11
4.2.2 Threshold of let-go	11
4.2.3 Threshold of ventricular fibrillation	12
4.3 Effects of alternating current in the frequency range above 1 000 Hz up to and including 10 000 Hz.....	13
4.3.1 Threshold of perception	13
4.3.2 Threshold of let-go	13
4.3.3 Threshold of ventricular fibrillation	14
4.4 Effects of alternating current in the frequency range above 10 000 Hz	14
4.4.1 General	14
4.4.2 Threshold of perception	14
4.4.3 Threshold of let-go	14
4.4.4 Threshold of ventricular fibrillation	14
4.4.5 Other effects.....	15
5 Effects of special waveforms of current	15
5.1 General.....	15
5.2 Equivalent magnitude, frequency, and threshold	16
5.3 Effects of alternating current with DC components	16
5.3.1 Waveforms and frequencies and current thresholds	16
5.3.2 Threshold of startle reaction	17
5.3.3 Threshold of let-go	18
5.3.4 Threshold of ventricular fibrillation	19
6 Effects of alternating current with phase control	22
6.1 Waveforms and frequencies and current thresholds	22
6.2 Threshold of startle reaction and threshold of let-go.....	23
6.3 Threshold of ventricular fibrillation	24
6.3.1 General	24
6.3.2 Symmetrical control	24
6.3.3 Asymmetrical control	24
7 Effects of alternating current with multicyle control	24
7.1 Waveforms and frequencies	24
7.2 Threshold of startle reaction and threshold of let-go.....	25
7.3 Threshold of ventricular fibrillation	25
7.3.1 General	25
7.3.2 Shock durations longer than 1,5 times the period of the cardiac cycle	26
7.3.3 Shock durations less than 0,75 times the period of the cardiac cycle	26
8 Estimation of the equivalent current threshold for mixed frequencies	26

8.1	Threshold of perception and let-go	26
8.2	Threshold of ventricular fibrillation	26
9	Effects of current pulse bursts and random complex irregular waveforms	27
9.1	Ventricular fibrillation threshold of multiple pulses of current separated by 300 ms or more	27
9.2	Ventricular fibrillation threshold of multiple pulses of current separated by less than 300 ms	27
9.2.1	General	27
9.2.2	Examples	28
9.2.3	Random complex irregular waveforms	30
10	Effects of electric current through the immersed human body	32
10.1	General	32
10.2	Resistivity of water solutions and of the human body	32
10.3	Conducted current through immersed body	33
10.4	Physiological effects of current through the immersed body	34
10.5	Threshold values of current	35
10.6	Intrinsically “safe” voltage values	35
11	Effects of unidirectional single impulse currents of short duration	35
11.1	General	35
11.2	Effects of unidirectional impulse currents of short duration	36
11.2.1	Waveforms	36
11.2.2	Determination of specific fibrillating energy	37
11.3	Threshold of perception and threshold of pain for capacitor discharge	38
11.4	Threshold of ventricular fibrillation	39
11.4.1	General	39
11.4.2	Examples	40
Annex A (informative)	Random complex irregular waveform analysis	43
A.1	General	43
A.2	Formal theoretical statement of the method	43
A.3	Demonstration of the calculation	44
A.3.1	General	44
A.3.2	Choice of unidirectional current	46
A.3.3	Choice of sampling step size	46
A.4	Examples 1 and 2	47
Bibliography	50
Figure 1	– Variation of the threshold of perception within the frequency range 50/60 Hz to 1 000 Hz	11
Figure 2	– Variation of the threshold of let-go within the frequency range 50/60 Hz to 1 000 Hz	12
Figure 3	– Variation of the threshold of ventricular fibrillation within the frequency range 50/60 Hz to 1 000 Hz, shock durations longer than one heart period and longitudinal current paths through the trunk of the body	12
Figure 4	– Variation of the threshold of perception within the frequency range 1 000 Hz to 10 000 Hz	13
Figure 5	– Variation of the threshold of let-go within the frequency range 1 000 Hz to 10 000 Hz	13
Figure 6	– Variation of the threshold of ventricular fibrillation for continuous sinusoidal current for use from 1 000 Hz to a maximum of 150 kHz	15
Figure 7	– Waveforms of currents	17

Figure 8 – Let-go thresholds for men, women and children 18

Figure 9 – 99,5 percentile let-go threshold for combinations of 50/60 Hz sinusoidal alternating current and direct current 19

Figure 10 – Composite alternating and direct current with equivalent likelihood of ventricular fibrillation..... 20

Figure 11 – Waveforms of rectified alternating currents 21

Figure 12 – Waveforms of alternating currents with phase control..... 23

Figure 13 – Waveforms of alternating currents with multicycle control..... 25

Figure 14 – Threshold of ventricular fibrillation (average value) for alternating current with multicycle control for various degrees of controls (results of experiments with young pigs)..... 26

Figure 15 – Series of four rectangular pulses of unidirectional current 28

Figure 16 – Series of four rectangular pulses of unidirectional current 29

Figure 17 – Series of four rectangular pulses of unidirectional current 29

Figure 18 – Example of current versus elapsed time over a contaminated insulator 30

Figure 19 – PC plotted on the AC time current curves (Figure 20 of IEC TS 60479-1:2005)..... 31

Figure 20 – Forms of current for rectangular impulses, sinusoidal impulses and for capacitor discharges 37

Figure 21 – Rectangular impulse, sinusoidal impulse and capacitor discharge having the same specific fibrillating energy and the same shock-duration 38

Figure 22 – Threshold of perception and threshold of pain for the current resulting from the discharge of a capacitor (dry hands, large contact area) 39

Figure 23 – Probability of fibrillation risks for current flowing in the path left hand to feet 40

Figure A.1 – Definition of a segment of a random complex waveform..... 43

Figure A.2 – Definition of a duration within a sample..... 43

Figure A.3 – PC for demonstration example of the random complex waveform method plotted against time-current curves for RMS AC..... 46

Figure A.4 – Random complex waveform typical of those used in Example 1 47

Figure A.5 – Random complex waveform typical of those used in Example 2 48

Figure A.6 – PC for Examples 1 and 2 of the random complex waveform method plotted against time-current curves for RMS AC..... 49

Table 1 – Example of estimate for ventricular fibrillation threshold after each burst of current in a series of pulses each of which excited the heart tissue..... 28

Table 2 – Resistivity of water solutions [24], [25] 32

Table 3 – Resistivity of human body tissues..... 33

Table 4 – Relative interaction between the resistivity of water solution and the impedance characteristic of the electrical source 34

Table 5 – Effects of shocks..... 41

Table 6 – Effects of shocks..... 42

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EFFECTS OF CURRENT ON HUMAN BEINGS AND LIVESTOCK –**Part 2: Special aspects****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 60479-2, which is a Technical Specification, has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This fourth edition cancels and replaces the third edition, published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- Changes reflecting the change in applicability of frequency from 1 kHz to 150 kHz have been added.
- The examination of random complex irregular waveforms has been added.
- The handling of successive DC pulses has been clarified.

The text of this Technical Specification is based on the following documents:

Draft TS	Report on voting
64/2143/DTS	64/2166/RVDTS

Full information on the voting for the approval of this Technical Specification can be found in the report on voting indicated in the above table.

This Technical Specification has the status of a basic safety publication in accordance with IEC Guide 104.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60479 series, published under the general title *Effects of current on human beings and livestock*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under <http://webstore.iec.ch> in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

EFFECTS OF CURRENT ON HUMAN BEINGS AND LIVESTOCK –

Part 2: Special aspects

1 Scope

This part of IEC 60479 describes the effects on the human body when a sinusoidal alternating current in the frequency range above 100 Hz passes through it.

The effects of current passing through the human body for:

- alternating sinusoidal current with DC components;
- alternating sinusoidal current with phase control;
- alternating sinusoidal current with multicycle control

are given but are only deemed applicable for alternating current frequencies from 15 Hz up to 100 Hz.

Means of extending the frequency of applicability of pure sinusoids to a frequency of 150 kHz are given, supplementing the data in IEC TS 60479-1.

Means of examining random complex irregular waveforms are given.

This document describes the effects of current passing through the human body in the form of single and multiple successive unidirectional rectangular impulses, sinusoidal impulses and impulses resulting from capacitor discharges.

The values specified are deemed to be applicable for impulse durations from 0,1 ms up to and including 10 ms.

This document only considers conducted current resulting from the direct application of a source of current to the body, as does IEC TS 60479-1 and IEC TS 60479-3. It does not consider current induced within the body caused by its exposure to an external electromagnetic field.

This basic safety publication is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 5. It is not intended for use by manufacturers or certification bodies.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications. The requirements, test methods or test conditions of this basic safety publication will not apply unless specifically referred to or included in the relevant publications.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.