



BSI Standards Publication

## Solar thermal electric plants

---

Part 1-2: General - Creation of annual solar radiation data set for solar thermal electric (STE) plant simulation

## National foreword

This Published Document is the UK implementation of IEC/TS 62862-1-2:2017.

The UK participation in its preparation was entrusted to Technical Committee RHE/25, Solar Heating.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2017  
Published by BSI Standards Limited 2017

ISBN 978 0 580 95476 4

ICS 27.160

**Compliance with a British Standard cannot confer immunity from legal obligations.**

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 December 2017.

### Amendments/corrigenda issued since publication

Date	Text affected
------	---------------

---



# IEC TS 62862-1-2

Edition 1.0 2017-11

## TECHNICAL SPECIFICATION



---

**Solar thermal electric plants –  
Part 1-2: General – Creation of annual solar radiation data set for solar thermal  
electric (STE) plant simulation**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

ICS 27.160

ISBN 978-2-8322-4978-9

**Warning! Make sure that you obtained this publication from an authorized distributor.**

CONTENTS

FOREWORD..... 4

INTRODUCTION..... 6

1 Scope..... 8

2 Normative references ..... 8

3 Terms and definitions ..... 8

4 Elements forming the ASR data set ..... 9

    4.1 Geographic and time identification ..... 9

        4.1.1 Geographic identification ..... 9

        4.1.2 Time reference ..... 9

        4.1.3 Time frequency..... 10

    4.2 Variables ..... 10

        4.2.1 General ..... 10

        4.2.2 Mandatory variable ..... 10

        4.2.3 Other variables ..... 10

    4.3 Format..... 11

5 Procedures and methodology for ASR generation..... 11

    5.1 General..... 11

    5.2 Measurement campaign ..... 12

        5.2.1 General ..... 12

        5.2.2 Quality control ..... 12

        5.2.3 Validation and gap filling..... 12

    5.3 Study of the representative long-term value ..... 13

        5.3.1 General ..... 13

        5.3.2 One source..... 13

        5.3.3 Several sources..... 15

    5.4 Generation of the representative series..... 17

        5.4.1 General ..... 17

        5.4.2 Procedure based on estimates..... 17

        5.4.3 Procedure based on measurement campaign ..... 17

6 Report ..... 18

Annex A (informative) Expression and relationships between formats of types of time ..... 20

Annex B (informative) General recommendations for measurement stations ..... 22

Annex C (informative) Equivalence of measurement station locations ..... 23

Annex D (informative) Quality control of measured data..... 24

    D.1 General..... 24

    D.2 Procedure 1: checking for physically possible values ..... 24

    D.3 Procedure 2: checking for extremely rare values ..... 25

    D.4 Procedure 3: checking for coherence of radiation variables..... 25

Bibliography..... 26

Figure 1 – Sections of ASR generation procedure..... 12

Table 1 – Direct solar irradiance place label values ..... 11

Table 2 – Table format for the estimation of a representative long-term value based on one data source ..... 14

Table 3 – Table format for estimating the representative long-term value from several different data sources .....	16
Table D.1 – Quality control procedure 1 – Physically possible values.....	24
Table D.2 – Quality control procedure 2 – Extremely rare values .....	25
Table D.3 – Quality control procedure 3 – Coherence of variables .....	25

Currently in preview, click buy full vers.

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SOLAR THERMAL ELECTRIC PLANTS –****Part 1-2: General – Creation of annual solar radiation data set  
for solar thermal electric (STE) plant simulation**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use, and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, accept to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62862-1-2, which is a Technical Specification, has been prepared by IEC technical committee 117: Solar thermal electric plants.

The text of this Technical Specification is based on the following documents:

Enquiry draft	Report on voting
117/67/DTS	117/77/RVDTS

Full information on the voting for the approval of this Technical Specification can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62862 series, published under the general title *Solar thermal electric plants*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

During the various stages of planning, design and start-up of a solar thermal electricity (STE) plant, engineering and economic studies often require the simulation of plant power production, and an analysis of the response of its various components and systems. All these simulation studies use precise, organized and standardized information of the solar resource and other meteorological variables.

As a one-year period includes the most important meteorological cycle, the response of a power plant is simulated for a complete year, and attempts to achieve results that can be extrapolated to the long term. The need therefore arises for a complete year of data for the meteorological variables that influence plant operation and provide a response to solar thermal power plant simulation studies. This standard year of data, which is known as the typical meteorological year (TMY), serves for both annual plant electricity production studies and engineering studies associated with a solar thermal power plant project, as well as for studies on extreme events.

The meteorological information for a specific place, especially knowledge of the solar resource, is always subject to uncertainty. Furthermore, this information comes from quite different sources and its availability is very irregular. Therefore, in order to generate a typical meteorological year, a standard, characteristic methodology is used which ensures its operability in the framework of solar thermal power plant projects, and offers adequate support for decision-making in this type of project.

This functional typical meteorological year as defined by this document is hereinafter called the annual solar radiation (ASR) data set.

Precise knowledge of the solar resource available is important for the design and development of any system that intends to make use of the energy from the sun. The large non-determining component of solar radiation<sup>1</sup> and the need to simulate the response of a solar system in the long term have led to the development of a methodology for generating a reference year that includes information on diurnal and seasonal variations in the meteorological variables involved as well as their long-term averages.

The typical meteorological year that has made this name best known was developed at Sandia National Laboratories [4] and employed part of the SOLMET/ERSATZ (1951-1976) database [5] made up of 240 stations of which 26 provide solar radiation measurements and the rest estimated data, for the US and adjacent territories. This TMY was built up from the concatenation of typical months to form a year with 8 760 hourly records. Each month was selected by evaluating nine variables: the mean, maximum and minimum temperature and dew point temperature, maximum and mean wind speed and global horizontal radiation. A weighted sum of the Finkenstein-Schafer statistic [5] [6] was used, resulting in the selection of five months. The final choice of the typical month considered the long-term persistence of climate pattern.

Although various authors have proposed slight variations in the Sandia methodology, in essence it remains practically unaltered in the generation known as TMY2 and TMY3 [5] [7].

TMY version 2 employs data from the National Solar Radiation Database (NSRDB) from 1961 to 1990, with 93 % of the data estimated by models and 7 % from data measured for 239 locations. The records include measurements of associated meteorological variables

---

<sup>1</sup> In this document, the term solar radiation is used as a generic reference to the "radiation emitted by the Sun" (as is defined in ISO 9488:1999, 3.13), and irradiance and irradiation are used as the physical magnitudes defined in ISO 9488:1999, 3.4 and 3.5 respectively]. On the other hand, these references notwithstanding, in this document, it has been agreed to express irradiance in  $W/m^2$  and irradiation in  $Wh/m^2$ .

such as temperature, humidity, cloud cover and visibility. The solar radiation measurement is present at 52 NSRDB stations, but the measurement period is short.

The TMY version 3 was produced using hourly solar radiation data and meteorological data from 1 454 stations, from NSRDB database time series (1961-1990) and its update, consisting of NSRDB station time series (1 %) and a dataset estimated using the State University of New York (SUNY) model based on geostationary operational environmental satellite (GOES) images for an eight-year recording period (1998-2005).

Finally, it should be mentioned that there are other methodological proposals that differ somewhat more from the National Renewable Energy Laboratory (NREL) TMYs, involving other variables, with a variety of statistics and even proposing the collection of typical meteorological data for only a few days a month instead of a whole year.

As the data necessary for generating the TMYs mentioned above are not available at the locations of most STE plant projects, a procedure is defined for the creation of an annual solar radiation data set for the plant simulation that standardizes the procedures currently used for this.

In this document, a set of procedures are presented. Only the minimal requirements of these procedures are described even when there may be additional considerations that will be more than welcome during the application of the procedures, but there may be times that they will not be available and the inclusion in this document will block the option of following it.

It is important that all the proposed methodologies use a measurement campaign with well-defined quality characteristics during a whole year and at least containing direct solar irradiance ( $G_b$ ) measurements in the expected location.

Two options are proposed to generate the annual solar radiation data set depending on the data availability. One only uses measurements of  $G_b$  but in addition uses high quality  $G_b$  estimations during more than 10 years. This methodology is very similar to the classic TMY but with a preliminary assessment of coherence with the local measurements. In this methodology, the ASR could be formed by the estimations selected in the process, by  $G_b$  measurements or by simultaneous measurements of GHI and  $G_b$ .

The other option uses  $G_b$  measurements as well as global horizontal irradiance (GHI); and uses a methodology for GHI long-term estimation based on additional sources of information (aimed low quality GHI estimations). In this second methodology, the ASR will always be formed by simultaneous measurements of GHI and  $G_b$ .

Recent works, such as the creation of multiple annual solar radiation (MASR) data sets for the simulation of a STE plant, are out of the scope of this document even when their use could be better than the use of a unique annual data set of data for the prefeasibility assessment of a STE plant project. At the moment of the elaboration of this document, there is not a consensus or a relation of procedures for MASR creation.

MASR creation as well as annual solar radiation data sets referred to an annual percentile (commonly the 10th percentile 10 of the estimated annual values distribution) could be covered in future projects.

This document is related to works developed in the context of the International Energy Agency SolarPACES and Solar Heating and Cooling agreements as a liaison organization of experts in solar radiation for energy applications. Coordination with subcommittee 1 of ISO technical committee 180 is also considered.

## SOLAR THERMAL ELECTRIC PLANTS –

### Part 1-2: General – Creation of annual solar radiation data set for solar thermal electric (STE) plant simulation

#### 1 Scope

This part of IEC 62862 defines the procedures for the creation of annual solar radiation data sets (ASR) for solar thermal electricity (STE) plant simulation.

In addition to the definition of procedures needed for the ASR construction, its components and parameters will be also described.

The scope of application of this document refers to the needs associated with solar thermal power plant projects and mainly related to the simulation of an annual period with a solar radiation sum close to a normal annual value (from among an estimation of all possible annual values).

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 9488:1999, *Solar energy – Vocabulary*

#### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

##### 3.1

##### annual solar radiation data set

##### ASR

complete standardized set of solar irradiance data, which may be accompanied by other meteorological variables considered of interest, and which attempts to establish a reference for radiometric evolution in a specific place during the year

Note 1 to entry: This data set shall have a solar radiation sum close to a normal annual value (among an estimation of all possible annual values).

##### 3.2

##### direct measurement

value of a certain variable found with a measurement instrument on the surface at the specific site