PD ISO/TR 16730-4:2013

BSI Standards Publication

Fire safety engineering — Assessment, verification and validation of calculation methods

Part 4: Example of a structural model

bsi.

...making excellence a habit.™

National foreword

This Published Document is the UK implementation of ISO/TR 16730-4:2013.

The UK participation in its preparation was entrusted to Technical Committee FSH/24, Fire safety engineering.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

ISBN 978 0 580 74864 6

ICS 13.220.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 28 February 2014.

Amendments issued since publication

Date	Text affected

PD ISO/TR 16730-4:2013

TECHNICAL REPORT

ISO/TR 16730-4

First edition
2013-11-01

Fire safety engineering — Assessment, verification and validation of calculation methods —

Part 4: Example of a structural model

Ingénierie de la sécurité incendie — Évaluation, vérification et validation des méthodes de calcul —

Partie 4: Exemple d'un modèle structural

Reference number
ISO/TR 16730-4:2013(E)

COPYRIGHT PROTECTED DOCUMENT

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2. www.iso.org/directives

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received. www.iso.org/patents

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: Foreword - Supplementary information

The committee responsible for this document is ISO/TC 92, *Fire safety*, Subcommittee SC 4, *Fire safety engineering*.

ISO 16730 consists of the following parts, under the general title *Fire safety engineering — Assessment, verification and validation of calculation methods*:

— *Part 2: Example of a fire zone model* [Technical Report]

— *Part 3: Example of a CFD model* [Technical Report]

— *Part 4: Example of a structural model* [Technical Report]

— *Part 5: Example of an Egress model* [Technical Report]

The following parts are under preparation:

— *Part 1: General* (revision of ISO 16730:2008)

Introduction

Certain commercial entities, equipment, products, or materials are identified in this document in order to describe a procedure or concept adequately or to trace the history of the procedures and practices used. Such identification is not intended to imply recommendation, endorsement, or implication that the entities, products, materials, or equipment are necessarily the best available for the purpose. Nor does such identification imply a finding of fault or negligence by the International Standards Organization.

For the particular case of the example application of ISO 16730-1 described in this document, ISO takes no responsibility for the correctness of the code used or the validity of the verification or the validation statements for this example. By publishing the example, ISO does not endorse the use of the software or the model assumptions described therein and states that there are other calculation methods available.

TECHNICAL REPORT ISO/TR 16730-4:2013(E)

Fire safety engineering — Assessment, verification and validation of calculation methods —

Part 4: Example of a structural model

1 Scope

This part of ISO 16730 shows how ISO 16730-1 is applied to a calculation method for a specific example. It demonstrates how technical and users' aspects of the method are properly described in order to enable the assessment of the method in view of verification and validation.

The example in this part of ISO 16730 describes the application of procedures given in ISO 16730-1 for a structural fire resistance model.

The main objective of the specific model treated here is the simulation of the heat transfer and structural responses of wall assemblies.

2 General information on the structural model

An analytical model for predicting the fire resistance of load bearing, gypsum protected, wood-stud wall assemblies is presented. The model couples a heat transfer sub-model and a structural sub-model. The heat transfer sub-model predicts the temperature profile inside the wood-stud wall and the time to insulation failure. The structural sub-model, based on the elastic buckling-load, uses the temperature profile to calculate the deflection of the wood studs and the time to structural failure of the assembly.

3 Methodology used in this Technical Report

For the calculation method considered, checks based on ISO 16730-1 and as outlined in this Technical Report are applied. This Technical Report lists in Annexes A and B the important issues to be checked in the left-hand column of a two-column table. The issues addressed are then described in detail, and it is shown how these were dealt with during the development of the calculation method in the right-hand column of the Annexes A and B cited above, where Annex A covers the description of the calculation method and Annex B covers the complete description of the assessment (verification and validation) of the particular calculation method. The Bibliography includes a worked example and user manual.