

CGA G-19.4—2020
GUIDELINE FOR
DETERMINING THE LIMITS OF
LIQUEFIED NATURAL GAS SPILLS
FIRST EDITION

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA. Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 18-113
Natural Gas Technology Committee

NOTE—Appendix A (Informative) are for information only.

FIRST EDITION: 2020

© 2020 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 14501 George Carter Way, Suite 103, Chantilly VA 20151. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
3 Definitions.....	1
4 Spill description	2
4.1 Mass flowrate	2
4.2 Flash loss	3
4.3 Aerosol losses	3
4.4 Rainout	3
4.5 Splashing.....	3
4.6 Boiling.....	4
4.7 Fill level.....	4
5 Health hazards	4
5.1 Assumptions.....	4
5.2 Limits for use	5
6 Calculation for simplified approach	5
6.1 Maximum spill radius.....	5
6.2 Free area.....	5
6.3 Non-circular spill areas.....	6
6.4 Determining the depth of an accumulated LNG spill	6
7 References	6
Figure	
Figure 1—Design spill constituents.....	3
Appendix	
Appendix A—Calculation of depth of impoundment example (Informative).....	8

1 Introduction

Impoundment areas are required for liquefied natural gas (LNG) installations in accordance with CGA G-19.1, *Standard for Natural Gas Supply Systems*, NFPA 59A, *Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)*, and per CSA Z276, *Liquefied natural gas (LNG) – Production, storage, and handling* [1, 2, 3].¹ Furthermore, impoundment areas are required for LNG storage at pipeline facilities in accordance with Title 49 of the U.S. *Code of Federal Regulations* (49 CFR) Part 193.2181 [5]. The intent of requiring containment or impounding systems is to ensure any LNG spillage remains on the owner's property.

Historically these requirements have been for the impoundment to have the capacity for full volumetric containment, 110%, of the maximum liquid capacity of the largest single container. These requirements were applied to large atmospheric pressure tanks (API 625, *Tank Systems for Refrigerated Liquefied Gas Storage*) with large (greater than 6 in [152 mm] Nominal Pipe Size [NPS]) piping penetrations [6]. In the event of a piping breach, such loss of containment could result in appreciable rainout and accumulation of LNG. Before LNG can accumulate, the surface must be sufficiently cooled.

There are also American Society of Mechanical Engineers (ASME) containers with relatively small liquid penetrations (up to and including 6 in [150 mm] NPS). The scope of ASME containers include pressures greater than 15 psi (103 kPa).² For ASME containers, higher pressure discharge from smaller pipe ruptures will mostly result in no accumulation of LNG by the time the container empties. The LNG is vaporized via aerosol, splashing, or boiling of the LNG at the impoundment surface.

The standards mentioned in this section permit calculation to size impoundments to contain the amount of the spill that can accumulate. This publication provides a method to size these LNG impoundments.

2 Scope

This publication provides technical guidance and the equations used to determine the maximum impoundment volume required for North American LNG facilities governed by CGA G-19.1, NFPA 59A, or CSA Z276 [1, 2, 3]. This publication applies to bulk cryogenic storage systems with LNG. The credible releases and potential spills come from piping. Accordingly, this publication is based on piping releases, up to and including 6 in (150 mm) NPS. The simplified approach presented in Section 6 is specific to pressure vessels. For pipeline facilities, see 49 CFR Part 193 [5]. This publication is intended for ASME vessels of 15 psi (103 kPa) maximum allowable working pressure (MAWP) or greater.

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.

² kPa shall indicate gauge pressure unless otherwise noted as (kPa, abs) for absolute pressure or (kPa, differential) for differential pressure. All kPa values are rounded off per CGA P-11, *Guideline for Metric Practice in the Compressed Gas Industry* [4].