

CGA G-4.6—2014

**OXYGEN COMPRESSOR  
INSTALLATION AND  
OPERATION GUIDE**

**FOURTH EDITION**

**CGA**

**Compressed Gas Association**

*The Standard For Safety Since 1913*

**PLEASE NOTE:**

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, [www.cganet.com](http://www.cganet.com).

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at [www.cganet.com](http://www.cganet.com). For more information contact CGA. Phone: 703-788-2700, ext. 799. E-mail: [customerservice@cganet.com](mailto:customerservice@cganet.com).

Work Item 11-045  
Atmospheric Gases and Equipment Committee

NOTE—Technical changes from the previous edition are underlined

FOURTH EDITION: 2014  
THIRD EDITION: 2008  
SECOND EDITION: 2001  
FIRST EDITION: 1992

© 2014 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 14501 George Carter Way, Suite 103, Chantilly VA 20151. You may not alter or remove any trademark, copyright or other notice from this work.

<b>Contents</b>	<b>Page</b>
1 Introduction.....	1
2 Scope and purpose .....	1
2.1 Scope .....	1
2.2 Purpose .....	1
3 Compression system design .....	1
3.1 General.....	1
3.2 Design considerations .....	1
4 Location of oxygen compressors.....	2
4.1 Personnel safety.....	2
4.2 Indoor installation .....	3
4.3 Outdoor installation.....	3
5 Hazard area.....	3
5.1 Definition.....	3
5.2 Description.....	4
5.3 Enclosure of the hazard area by a safety barrier .....	4
5.4 Access to the hazard area.....	4
5.5 Equipment location .....	4
5.6 Piping.....	5
6 Barrier design for oxygen compressors.....	6
6.1 Purpose .....	6
6.2 Design forces.....	6
6.3 Barrier materials .....	6
6.4 Centrifugal compressors.....	9
6.5 Reciprocating compressors .....	10
7 Operating procedures.....	10
7.1 Purpose .....	10
7.2 General.....	10
7.3 System cleanliness.....	10
7.4 Equipment operation .....	11
7.5 Startup.....	12
7.6 Shutdown.....	14
7.7 Maintenance .....	14
8 Fire protection .....	15
8.1 Housekeeping.....	15
8.2 Emergency plan .....	15
8.3 Firefighting equipment.....	15
9 References .....	15
10 Additional references.....	16
<b>Figure</b>	
Figure 1—Centrifugal oxygen compressor impact force distribution on barrier .....	7
Figure 2—Reciprocating oxygen compressor impact force distribution on barrier.....	8

This page is intentionally blank.

Currently in preview, click buy full version

## 1 Introduction

Compression of oxygen is attended with potential hazards that shall be recognized and addressed. The hazards include gases under pressure and the ability of oxygen to accelerate combustion.

An oxygen compressor fire can result in a powerful jet of oxygen with entrained molten metal and metal oxides. This jet can be fatal to unprotected personnel and can severely damage adjacent equipment. Depending on the pressure at the source of the jet and the diameter of the hole through which it emerges, the danger zone can extend to 100 ft (30.5 m) or more.

## 2 Scope and purpose

### 2.1 Scope

This guide contains a summary of current industrial practices used in oxygen compressor installations and applies to oxygen compressors that compress oxygen gas with purities of 90% or greater. Oxygen with a water content of 10 ppm or more can cause corrosion and condensate problems that have not been addressed in this guide. Installations that have operating conditions beyond this scope should be jointly reviewed by the equipment user, installer, and compressor supplier.

Some of the practices presented represent conservative compromise, and not all possible situations are described. The designer is cautioned that this publication is not a design handbook and does not discard the need for competent engineering judgment and interpretation. The user should review any special problems or concerns with others who are knowledgeable in the design of oxygen compression systems such as suppliers of oxygen compressors or major oxygen producers. For more information, see CGA G-4.11, *Reciprocating Compressors for Oxygen Service* and CGA G-4.13, *Centrifugal Compressors for Oxygen Service* [1, 2].<sup>1</sup>

### 2.2 Purpose

This guide is intended to serve the interests of anyone who may be associated or concerned with the compression of oxygen. It also acquaints persons not familiar with compressor application, installation, or operation with factors considered important to safety.

## 3 Compression system design

### 3.1 General

It is imperative that oxygen compression systems be designed to prevent fires and to vent the oxygen inventory as quickly as possible in case of a fire or potential ignition. Fires in oxygen compressors, once started, are almost impossible to extinguish until the contained oxygen gas is consumed in the fire or vented to the atmosphere. While this happens rapidly and the actual oxygen fire is over quickly, extensive damage is likely and materials not normally considered combustible will be consumed. Other combustible material such as oil can be ignited and burn with great vigor in the presence of elevated oxygen concentrations. These materials will continue to burn after the actual oxygen-promoted fire is out.

### 3.2 Design considerations

Careful attention to the following design considerations will greatly reduce the risk of equipment damage and personal injury:

- materials of construction of the compressor and the ancillary equipment from a standpoint of the conditions of service and consequences of significant rub or impact in the event of a malfunction;
- design of monitoring and control systems to detect and/or avoid potentially hazardous conditions; and
- effective isolation of the oxygen compressor gas path from the compressor lubrication system.

---

<sup>1</sup> References are shown by bracketed numbers and are listed in order of appearance in the reference section.