

CGA

Compressed Gas Association

The Standard For Safety Since 1913

CGA G-5.7-2014
CARBON MONOXIDE AND
SYNGAS PIPELINE
SYSTEMS

SECOND EDITION

Currently in preview, click buy full version

PREFACE

As a part of a program of harmonization of industry standards, the European Industrial Gases Association (EIGA) and the Compressed Gas Association (CGA) formed an ad hoc task force and developed CGA G-5.7, *Carbon Monoxide and Syngas Pipeline Systems*. This standard is intended as a joint EIGA/CGA international harmonized standard for the use and application of all members of EIGA and CGA worldwide. The CGA edition is identical in technical content to the EIGA edition except for regional regulatory requirements (noted), and it has changes in formatting and spelling.

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 09-023
HYCO Committee

NOTE—Technical changes from the previous edition are underlined.

NOTE—Appendices C and F (Normative) are a requirement.

NOTE—Appendices A, B, E, G, and H (Informative) are for information only.

SECOND EDITION: 2014
FIRST EDITION: 2005

© – Reproduced with permission from, the European Industrial Gases Association. All rights reserved.

Contents	Page
1 Introduction.....	1
2 Scope and purpose	1
3 Definitions.....	2
4 Design philosophy	5
4.1 General criteria	5
4.2 Properties of Syngas	6
4.3 Metallic materials.....	9
4.4 Nonmetallic materials	14
4.5 Piping systems	17
4.6 Hazard analysis and risk assessment	19
4.7 Site selection	23
5 Piping, valves, and equipment	24
5.1 General criteria	24
5.2 Material selection criteria.....	24
5.3 Electrical hazardous area requirements.....	24
5.4 Piping.....	25
5.5 Valves.....	26
5.6 Other equipment.....	29
6 Cleaning	30
6.1 General requirements.....	30
6.2 Postinstallation cleaning.....	32
7 Construction	34
7.1 General criteria	34
7.2 Specification and manufacture of line pipe material	35
7.3 Construction plan.....	35
7.4 Pipe fabrication and welding.....	36
7.5 Assembly and installation	37
7.6 Inspection and examination.....	38
7.7 Nondestructive testing	39
7.8 Documentation	40
8 Design and construction of static systems	40
8.1 Function.....	40
8.2 Design brief	41
8.3 Control station elements.....	41
8.4 Standards and design codes.....	42
8.5 Materials and fabrication	43
8.6 Access limitation	43
8.7 Location.....	43
8.8 Grounding.....	43
8.9 Installation	44
8.10 Pressure and leak testing.....	44
8.11 Commissioning.....	44
8.12 Operation.....	45
9 Operation and monitoring.....	45
9.1 Operations and maintenance manual	45
9.2 Management systems	46
9.3 General safety requirements.....	46
9.4 Personnel for operation and maintenance	47
9.5 Welding and cutting.....	47
9.6 Shutdown, repair, and startup of pipelines	47

9.7	Venting and pressure relief.....	48
9.8	Commissioning pipelines and stations	48
9.9	Operation and monitoring	49
9.10	Information to third parties, work adjacent to pipelines, and update of documents.....	49
9.11	Specialized surveys.....	50
9.12	Damage to the pipeline system	50
10	General protective measures	51
10.1	Emergency response plan.....	51
10.2	Accident and damage report	52
10.3	Safety management system.....	52
10.4	Leak detection system.....	55

Tables

Table 1	—Effects of carbon monoxide on health and life.....	8
Table 2	—Minimum acceptable absorption energies for different sizes of Charpy V notch specimens.....	12
Table 3	—Chemical resistance of selected nonmetallic materials to carbon monoxide	14
Table 4	—Maximum temperatures for various plastics in hydrogen service.....	15
Table 5	—Chemical resistance of elastomers to hydrogen.....	16
Table 6	—Permeation of hydrogen through elastomers at 25 °C (77 °F) [see Appendix K, reference 16.1.1]... 16	
Table 7	—Damage criteria for thermal radiation	22
Table 8	—Types of pipeline cleaning pigs	31

Appendices

Appendix A	—Typical arrangements for pipelines systems (Informative).....	56
Appendix B	—Embrittlement and environmental damage mechanisms involving carbon monoxide and Syngas mixtures and applicable test methods (Informative)	57
Appendix C	—Nominal alloy compositions and ranges (Normative).....	62
Appendix D	—Metallurgical factors affecting toughness and brittle fracture mechanisms (Informative)	65
Appendix E	—Example of preventive maintenance program for carbon monoxide and Syngas pipelines (Informative).....	69
Appendix F	—Composition criteria for carbon monoxide and Syngas (Normative).....	70
Appendix G	—Probability acceptance criteria (Informative).....	71
Appendix H	—References (Informative)	73

Appendix table

Table G1	—Carbon monoxide toxicity	72
----------	---------------------------------	----

Appendices figures

Figure A1	—Typical transmission and distribution piping systems	56
Figure A2	—Typical arrangement for carbon monoxide and Syngas isolation and metering station.....	56
Figure F1	—Classification of gas mixtures containing hydrogen and/or carbon monoxide	70
Figure G1	—Examples of risk criteria	71

1 Introduction

This publication has been prepared by a group of specialists in pipeline systems representing major industrial gases producers in various countries of Western Europe and North America and is based on the technical information and experience currently available to the authors.

The industrial gases companies have engaged, through the Compressed Gas Association (CGA) and the European Industrial Gases Association (EIGA), in a process of developing harmonized safety practices, and this publication is one of them.

It must be recognized, however, that pipeline systems developed over 40 years in the various European countries and North America have shown good and comparable safety records, although national practices show many differences in design and operations. Some national authorities have also introduced legislation that is mandatory for the operators in those countries.

Thus, the information contained in this document applies only to future installations and not to existing installations or those in the project phase as of the date of this publication. Furthermore, to the extent that they exist, federal, state, provincial/territorial, and local laws supersede the suggested practices listed in this publication. It should not be assumed that every local standard, test, safety procedure, or method is contained in these recommendations or that abnormal or unusual circumstances may not warrant additional requirements or procedures. CGA makes no representations or warranties on the information in or the completeness of this publication and disclaim all warranties, express or implied including, but not limited to, the warranty of merchantability and the warranty of fitness for a particular use or purpose.

SI units and corresponding customary U.S. units in brackets are used in this publication. Corresponding values can be approximate.

Those involved in the safe design, operation, and maintenance of gaseous transmission and distribution systems should be aware of various documents, guidance, publications, and standards prepared by various multinational organizations that can be pertinent to such systems. These are listed in Appendix H. In addition to these documents, there are a number of pertinent publications, technical papers, bulletins, etc., that provide useful information on materials of construction, metallurgy, environmental degradation mechanisms, etc., found also in Appendix H. While the cited references provide a valuable background, it cannot be stated that these are all of the standards documents or technical papers published by international organizations that could be pertinent to the subject of this publication.

2 Scope and purpose

The scope of this publication is for transmission and distribution piping systems for carbon monoxide and hydrogen and carbon monoxide mixtures (referred to as Syngas in the remainder of this publication). Typical arrangements for these pipeline systems are shown in Figure 1 of Appendix A. It is limited to gaseous products with a temperature range between $-40\text{ }^{\circ}\text{C}$ and $150\text{ }^{\circ}\text{C}$ ($-40\text{ }^{\circ}\text{F}$ and $302\text{ }^{\circ}\text{F}$), pressures from 0.1 MPa up to 15 MPa (1.5 psi up to 2250 psi), and the purity criteria defined in Appendix F.

This publication does not apply to the following processes:

- cylinder filling plants;
- producing plants;
- compressor units;
- bulk facilities (liquid or high pressure gas) at the customer's site up to the point where gas enters the distribution systems; or
- piping on specialized equipment and machines.

These systems have many specialized needs and requirements. However, this publication may provide useful background information in other processes where carbon monoxide is present.