



**CGA G-6.1—2022**  
**STANDARD FOR**  
**LARGE INSULATED LIQUID**  
**CARBON DIOXIDE SYSTEMS**  
**AT USER SITES**

**EIGHTH EDITION**

Currently in preview, click buy full version

**PLEASE NOTE:**

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, [www.cganet.com](http://www.cganet.com).

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at [www.cganet.com](http://www.cganet.com). For more information contact CGA. Phone: 703-788-2700, ext. 799. E-mail: [customerservice@cganet.com](mailto:customerservice@cganet.com).

Work Item 16-032  
Carbon Dioxide Committee

---

NOTE—Technical changes from the previous edition are underlined

EIGHTH EDITION: 2022  
SEVENTH EDITION: 2013  
SIXTH EDITION: 2005  
FIFTH EDITION: 2002  
FOURTH EDITION: 1995

© 2022 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope and purpose .....	1
2.1 Scope .....	1
2.2 Purpose .....	1
3 Definitions.....	1
4 Physiological effects of carbon dioxide .....	3
5 Hazards.....	3
5.1 Trapped liquid.....	3
5.2 Trapped solid (dry ice and water ice) in discharge and blowdown piping .....	3
5.3 Personnel overexposure.....	4
5.4 Low temperature effects on materials .....	4
5.5 High volume vapor removal.....	4
5.6 Overfilling containers .....	5
5.7 Interconnected containers .....	7
6 Supply system equipment .....	7
6.1 Container .....	7
6.2 Container filling connections.....	2
6.3 Container pressure relief device.....	2
6.4 Container refrigeration systems.....	4
6.5 Carbon dioxide fire protection containers.....	5
6.6 Vaporizer systems.....	5
6.7 Vapor heater.....	7
6.8 Carbon dioxide pressure regulators .....	8
6.9 Liquid carbon dioxide circulation loops.....	8
6.10 Appurtenances .....	9
6.11 Corrosion allowances .....	9
7 Markings and labeling .....	10
8 Supply system installation .....	10
8.1 Security.....	10
8.2 Container location and installation.....	10
8.3 Piping, tubing, and fittings.....	11
8.4 Hose and hose fittings.....	14
8.5 System assembly and tests.....	15
8.6 Electrical requirements.....	16
9 Sampling of delivery transports at customer site.....	16
9.1 Sensory evaluations .....	17
9.2 Analytical evaluations.....	18
10 Maintenance, inspection, and repairs.....	18
10.1 Maintenance.....	18
10.2 Inspection of systems in service.....	18
10.3 Inspection of systems out of service.....	19
10.4 Repairs .....	20
10.5 Inspection record.....	20
11 References .....	20

## Figures

Figure 1—Examples of incorrect and preferred installation of PRDs on liquid lines .....	4
Figure 2—Safe filling volumes for 350 psi (2410 kPa) carbon dioxide containers .....	6
Figure 3—Multiple container installation example .....	7
Figure 4—Piping schematic of typical foam-insulated carbon dioxide container .....	8
Figure 5—Traditional primary and secondary PRD setup for foam and vacuum insulated containers .....	9
Figure 6—Alternate primary and secondary PRD setup for foam-insulated containers .....	9
Figure 7—Typical foam-insulated carbon dioxide container .....	9
Figure 8—Piping schematic of typical vacuum-insulated carbon dioxide container .....	2
Figure 9—Alternate primary and secondary PRD setup for vacuum-insulated containers .....	2
Figure 10—Typical vacuum-insulated carbon dioxide container .....	3
Figure 11—Typical pressure control settings for carbon dioxide container .....	4
Figure 12—Pressure building vaporizer .....	6
Figure 13—Direct-to-process electric vaporizer .....	6
Figure 14—Steam heated water bath vaporizer .....	7
Figure 15—Vapor heater .....	7
Figure 16—Typical carbon dioxide circulating loop .....	9
Figure 17—Typical caution sign .....	15
Figure 18—Snow horn permanently attached to the customer container .....	17

## Tables

Table 1—Volume expansion upon warming of liquid carbon dioxide saturated at 200 psi (1380 kPa) for a container with a 350 psi (2410 kPa) MAWP .....	6
Table 2—Piping materials commonly used for insulated carbon dioxide service [19] .....	12
Table 3—Tubing .....	13
Table 4—Fitting .....	13

## 1 Introduction

This publication is one of a series compiled by the Compressed Gas Association, Inc., to meet the demand for information on the production, transportation, handling, and storage of carbon dioxide in gaseous, liquid, and solid states. There are other CGA publications that provide similar information on other products.

This publication addresses the hazards specifically associated with insulated liquid carbon dioxide systems at user sites with individual containers each greater than 1000 lb liquid capacity [1].<sup>1</sup>

CGA G-6, *Carbon Dioxide*, contains information critical to safe storage and handling of carbon dioxide [2]. To ensure personnel safety and proper system design, reference to CGA G-6 is highly recommended. Without obtaining CGA G-6, the reader will not be provided significant information related to the physical properties and common hazards associated with storage, production, transportation, and handling of carbon dioxide.

## 2 Scope and purpose

### 2.1 Scope

This publication covers the design, location, installation, operation, and maintenance of large insulated liquid carbon dioxide supply systems located at user sites where each container has a liquid capacity of greater than 1000 lb. Industry often refers to these as bulk systems. The system covered is from the container fill connections to the user's process piping.

It also contains minimum requirements and recommended practices for the design, construction, installation, operation, and maintenance of such systems.

This publication is intended to serve as a guide for regulatory authorities in writing regulations and to assist designers, inspectors, and other interested parties.

Small, stationary, insulated carbon dioxide systems with containers having individual capacities of 1000 lb or less and designed, manufactured, and certified in accordance with ASME Boiler & Pressure Vessel Code, Section VIII, Division 1 requirements are not covered by this publication, refer to CGA G-6.5, *Standard for Small Stationary Insulated Carbon Dioxide Supply Systems* [1, 2].

Stationary, uninsulated carbon dioxide systems are outside the scope of this publication.

NOTE—Many of the provisions and design possibilities in this publication apply to storage units in production and depot service. However, the operation, operating conditions, and control systems of those units may require further engineering, controls and safety equipment than required for storage units at a user site.

### 2.2 Purpose

The purpose of this publication is to provide a standard for stationary insulated liquid carbon dioxide storage and supply systems at user sites.

## 3 Definitions

For the purposes of this publication, the following definitions apply.

### 3.1 Publication terminology

#### 3.1.1 **Small**

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

#### 3.1.2 **Should**

Indicates that a procedure is recommended.

<sup>1</sup> References are shown by bracketed numbers and are listed in order of appearance in the reference section.