

**CGA G-6.3 – 2021
CARBON DIOXIDE
CYLINDER FILLING AND
HANDLING PROCEDURES
FIFTH EDITION**

Currently in preview, click buy full version

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 14-038
Carbon Dioxide Committee

NOTE—Technical changes from the previous edition are underlined.

FIFTH EDITION: 2021
FOURTH EDITION: 2013
THIRD EDITION: 2002
SECOND EDITION: 1995

© 2021 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope and purpose	1
2.1 Scope	1
2.2 Purpose	1
3 Definitions.....	1
4 Physiological effects and hazards of carbon dioxide.....	3
4.1 Physiological effects	3
4.2 Hazards	3
5 Cylinder regulations.....	3
5.1 Cylinder pressure	3
5.2 Materials of construction.....	3
5.3 Regulatory authorization.....	3
5.4 Cylinder markings.....	4
5.5 Cylinder requalification	4
6 Cylinder valves	5
6.1 Standard fill valve	5
6.2 Fire extinguishing cylinder valves.....	5
6.3 Residual pressure valve	6
7 Cylinder inspection and requalification	6
7.1 General.....	6
7.2 External inspection	7
7.3 Hammer test (steel cylinders only).....	9
7.4 Internal inspection	9
7.5 Cylinder requalification	10
7.6 Disposing of condemned or unserviceable cylinders	10
8 Typical cylinder filling system	10
8.1 General.....	10
8.2 System components	11
8.3 Installation	11
8.4 Filling limits for cylinders.....	11
8.5 Operation.....	13
9 Cylinder filling procedure	15
9.1 Filling procedure.....	15
9.2 Typical steps performed when filling carbon dioxide cylinders.....	18
10 Cylinder storage, handling, shipping, and use	19
10.1 Storage	19
10.2 Handling	19
10.3 Shipping.....	19
10.4 Use	19
11 Labeling and placarding regulations.....	20
11.1 Labels.....	20
11.2 Placards.....	20
12 Shipping papers	20
13 References	21

Tables

Table 1—Typical dimensions and capacities of carbon dioxide cylinders 4
Table 2—Maximum allowable filling densities..... 12

Figures

Figure 1—Carbon dioxide cylinder valve and typical pressure relief devices 5
Figure 2—Quick opening cylinder valve for fire suppression system in closed position with locking device engaged 6
Figure 3—Quick opening cylinder valve for fire suppression system with locking device disengaged and valve open 6
Figure 4—Corrosion at the bottom of a condemned carbon dioxide cylinder 9
Figure 5—Sidewall corrosion of a condemned carbon dioxide cylinder..... 10
Figure 6—Example of pressure in a DOT-3AL1800 carbon dioxide cylinder filled to indicated densities at selected temperatures..... 12
Figure 7—Typical carbon dioxide cylinder filling system schematic 13
Figure 8—Cylinder inverting..... 17
Figure 9—Nonflammable gas placards..... 20

Currently in preview, click buy full version

1 Introduction

This publication is one of a series compiled by the Compressed Gas Association, Inc., to satisfy the demand for information on the production, handling, storage, transportation, and use of carbon dioxide in gaseous liquid and solid states. There are other CGA publications that provide similar information on other products.

2 Scope and purpose

2.1 Scope

The scope of this publication includes the inspection, filling, handling, labeling, and shipping of uninsulated carbon dioxide cylinders, and the preparation of shipping papers.

In addition to the cylinder filling procedures in this publication, filling carbon dioxide cylinders for medical, food, or beverage use requires the use of product that meets appropriate CGA quality verification levels (QV) as listed in CGA G-6.2, *Commodity Specification for Carbon Dioxide*, and requires additional procedures per regulatory requirements [1].¹

CGA G-6, *Carbon Dioxide*, contains information critical to safe storage and handling of carbon dioxide [2]. To ensure personnel safety and proper system design, reference to CGA G-6 is highly recommended [2]. Without obtaining CGA G-6, the reader will not be provided with significant information related to the physical properties and common hazards associated with storage, production, transportation, and handling of carbon dioxide [2]. This publication does address the hazards specifically associated with insulated liquid carbon dioxide systems at consumer sites.

This publication does not cover stationary, in place, high pressure cylinder filling systems and processes where individual cylinder fill capacity is not measured by weight. These systems shall have an engineered safety risk-analysis before installation and use.

2.2 Purpose

The primary purpose of this publication is to provide information to personnel engaged in handling, filling, and transporting carbon dioxide cylinders.

3 Definitions

For the purposes of this publication, the definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.