

CGA G-3.1—2013
REAFFIRMED 2018

STANDARD FOR
NITROUS OXIDE SYSTEMS
AT CUSTOMER SITES

FIFTH EDITION

CGA
Compressed Gas Association

The Standard For Safety Since 1913

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA. Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 18-017
Medical Gases Committee

NOTE—No technical information has been changed from the 2013 edition. This reaffirmed edition may include minor editorial changes.

REAFFIRMED: 2018
FIFTH EDITION: 2013
FOURTH EDITION: 2007
THIRD EDITION: 1990
SECOND EDITION:

© 2013 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 14501 George Carter Way, Suite 103, Chantilly VA 20151. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
3 Definitions.....	3
4 Cautions and warnings.....	4
4.1 Characteristics.....	4
4.2 Warning signs.....	4
5 Security	6
6 Location of large volume nitrous oxide systems.....	7
6.1 General.....	7
6.2 Accessibility.....	7
6.3 Relation to other storage	7
6.4 Lower than adjacent storage.....	7
7 Distance between large volume nitrous oxide systems and exposures.....	7
7.1 Minimum distance.....	7
7.2 Special considerations.....	7
7.3 Ventilation in enclosed areas	7
8 Stationary low pressure liquid nitrous oxide containers	9
8.1 General.....	9
8.2 Requirements	9
8.3 Insulation	9
8.4 Materials.....	9
8.5 Supports and foundations	9
8.6 Storage tank pressures	9
8.7 Vaporizer.....	9
8.8 Additional requirements.....	10
9 Portable nitrous oxide containers	10
9.1 Container requirements.....	10
9.2 Marking.....	10
9.3 Outside storage	10
9.4 Inside storage.....	10
9.5 Separation of stored gases	10
9.6 Restricted access	10
10 High pressure nitrous oxide manifold systems.....	10
10.1 General.....	10
10.2 Location.....	10
10.3 Gas capacity for indoor installations.....	11
10.4 Systems of large capacity	11
10.5 Additional requirements.....	11
11 Piping, tubing, and fittings	11
11.1 General.....	11
11.2 Piping and tubing.....	11
11.3 Pressure relief	11
11.4 Cleaning	11
11.5 Location.....	12
11.6 Piping.....	12
11.7 Sleeving protection.....	12
11.8 Shutoff valves	12
11.9 Labeling and marking	12
11.10 Final system cleaning and testing	12

12	Pressure reducing regulators	12
12.1	General.....	12
12.2	Testing, repair, and maintenance	12
12.3	Union nuts and connections	12
13	Pressure relief devices	13
13.1	General.....	13
13.2	Venting	13
13.3	Protection	13
14	Liquid nitrous oxide vaporizers.....	13
14.1	General.....	13
14.2	Installation	13
14.3	Pressure relief	13
14.4	Heating medium	13
15	Equipment assembly and installation	13
15.1	General.....	13
15.2	Joining and sealing.....	13
15.3	Accessories	14
15.4	Supervision.....	14
15.5	Testing.....	14
15.6	Protection	14
15.7	Ventilation.....	14
16	Operating instructions	14
16.1	Responsibility	14
16.2	Training.....	14
17	Maintenance.....	14
17.1	Annual inspection and maintenance	14
17.2	Combustibles.....	14
18	General precautions	14
18.1	Testing for leakage	14
18.2	Cleanliness.....	15
18.3	Opening valves.....	15
18.4	Removal of regulators	15
18.5	Leakage.....	15
18.6	Safety information.....	15
19	References	15

Tables

Table 1—Properties of nitrous oxide.....	2
Table 2—Properties of saturated liquid.....	2
Table 3—Distance to exposures for nitrous oxide	8

Figures

Figure 1—Warning sign for supply enclosure	4
Figure 2—Warning sign (confined area/limited access).....	4
Figure 3—NFPA hazard label for nitrous oxide liquefied compressed gas.....	5
Figure 4—NFPA hazard label for nitrous oxide refrigerated liquid.....	5
Figure 5—Pressure relief device installation.....	11

1 Introduction

At atmospheric pressure and temperature, nitrous oxide is a colorless, practically odorless, tasteless, and non-toxic gas about 50% heavier than air. It is quite soluble in water, vegetable oils, and other liquids. Its main use is as an anesthetic. It is also used as a propellant in pressure package containers, in analytical instruments, as a leak detector, and in other specialized applications.

Nitrous oxide is available in the compressed, liquefied form either in high pressure containers or low pressure insulated containers conforming to the specifications of the U.S. Department of Transportation (DOT), Transport Canada (TC) or in relatively low pressure bulk containers maintained at reduced temperatures. Below the critical point of 97.7 °F (36.5 °C) liquid nitrous oxide is in equilibrium with its vapor at a pressure dependent upon the temperature. For specific data see the *Handbook of Compressed Gases* [1].¹ Under normal conditions of storage and use, nitrous oxide is stable in both gas and liquid phases, and is noncorrosive. It does not form an acid in water.

As with oxygen, ignition of combustible materials can occur more readily in a nitrous oxide-enriched atmosphere than in air with combustion proceeding at a faster rate. Nitrous oxide also decomposes exothermally under conditions of high temperature and pressure. If sufficient heat is added, the decomposition can be self-sustaining and with the appropriate high temperature and pressure, the nitrous oxide can explode. Refer to *CGA G-8.3, Safe Practices for the Storage and Handling of Nitrous Oxide* [2]. Therefore, this standard provides primarily for protection of the nitrous oxide system from fire from sources apart from the system itself. It is important to locate nitrous oxide systems in well-ventilated locations since nitrous oxide-enriched atmospheres can collect temporarily in confined areas in the event of the functioning of a pressure relief device (PRD) or leakage from the system.

The properties of nitrous oxide are shown in Tables 1 and 2.

2 Scope

This standard covers the general principles recommended for the installation of nitrous oxide systems on medical or industrial customer premises.

Such systems consist of a central supply, which can be either cylinders connected to a common manifold or bulk liquid containers and the associated equipment and piping required for connecting the central supply to the line supplying the nitrous oxide to the point of use.

The authority having jurisdiction (AHJ) may authorize the continued use of an existing nitrous oxide system, which is not in strict compliance with the provisions of this standard, where such continued use will not constitute a hazard to life or adjacent property.

This standard does not apply to nitrous oxide manufacturing plants and normally does not apply to distributor bulk stations. However, where distributor bulk stations interface closely with business or facilities unrelated to the handling of nitrous oxide, or where the general public can be exposed to such bulk facilities, the applicable safety provisions of this standard shall be followed.

Additional requirements for nitrous oxide systems are contained in NFPA 99, *Health Care Facilities Code*, NFPA 55, *Compressed Gases and Cryogenic Fluids Code*, and CSA Z305.1, *Nonflammable Medical Gas Piping Systems* [3, 4, 5].

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.