

CGA H-11—2020

**SAFE STARTUP AND
SHUTDOWN PRACTICES FOR
STEAM REFORMERS**

SECOND EDITION

CGA

Compressed Gas Association

The Standard For Safety Since 1913

PREFACE

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has published CGA H-11, *Safe Startup and Shutdown Practices for Steam Reformers*, jointly produced by members of the International Harmonization Council.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure, or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 19-028
HYCO Committee

NOTE—Technical changes from the previous edition are underlined.

SECOND EDITION: 2020

FIRST EDITION: 2013

© 2020 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 14501 George Carter Way, Suite 103, Chantilly VA 20151. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction and purpose.....	1
1.1 Introduction.....	1
1.2 Purpose.....	1
2 Scope.....	2
3 Definitions.....	2
4 General considerations.....	5
4.1 Personnel safety.....	5
4.2 Emergency response.....	5
4.3 Process safety.....	5
4.4 Communication.....	6
4.5 Recommended operating procedures.....	6
4.6 Materials and equipment.....	7
4.7 On-line furnace inspections.....	7
5 Startup.....	7
5.1 Pre-startup preparation.....	7
5.2 Nitrogen flow and reformer ignition.....	9
5.3 Steam generation and introduction.....	11
5.4 Feed introduction considerations.....	12
5.5 Establishment of downstream units.....	13
5.6 Introduction of additional fuel streams.....	14
5.7 Plant restart after trip.....	14
6 Shutdown.....	15
6.1 General shutdown preparation.....	15
6.2 Controlled shutdown procedures (planned shutdown).....	16
6.3 Unplanned shutdown.....	17
6.4 Isolation and purging of flammable gas systems in preparation for maintenance.....	18
7 Training and procedures.....	18
8 References.....	19

This page is intentionally blank.

Currently in preview, click buy full version

1 Introduction and purpose

1.1 Introduction

Large scale hydrogen production has been commercially practiced for decades and the demand for such production has grown over that period. In the last several years, developments in crude oil processing, such as the increased use of hydrogen to remove sulfur and the refinement of heavier crude oil stocks, has driven significant growth in the demand for hydrogen supply.

In response to this demand, industrial gas companies operate and maintain large scale hydrogen production facilities worldwide and have done so with an exemplary safety record for many years. However, it should be noted that large scale hydrogen production involves potential personnel and process safety hazards that shall be addressed in design and operation. Such hazard potential is inherent to the processing of toxic and flammable gases via high temperature reforming as practiced in hydrogen production.

The steam reformer represents the core operating unit of most large scale hydrogen production facilities. Therefore, steam reformer furnace combustion safety is fundamental to the overall safe operation of these large scale hydrogen plants. The startup and shutdown of the reformer can create transitional periods of increased risk to the operation of the facility. The operating procedures and practices employed during startup and shutdown shall effectively address the potential hazards of such transitions to ensure plant safety.

The need to specifically consider and address the startup and shutdown of industrial processes is well recognized as a cornerstone to safe operation. Requirements to ensure startup and shutdown safety are addressed in operating procedures and are included in process safety regulations in Title 29 of the U.S. *Code of Federal Regulations* (29 CFR) Part 1910.119, *Process safety management of highly hazardous chemicals*, referred to as OSHA Process Safety Management (PSM), and in Europe, Seveso III Directive 2012/18/EU, *Control of Major Accident Hazards Involving Dangerous Substances*, among other regulatory bodies [1, 2].¹

Guidelines for the safe startup and shutdown of industrial production units are technology specific. Industry-wide publications addressing startup and shutdown practices exist for many technologies, including industry publications such as CGA P-8, *Safe Practices Guide for Cryogenic Air Separation Plants*, which addresses startup and shutdown of air separation plants [3].

It should be noted that there are other industries such as ammonia and methanol production, that operate large steam reformers. Therefore, it can be instructive to consider the learning and experiences from those industries through organizations such as the American Institute of Chemical Engineering: Ammonia Plant Safety Symposium and the International Methanol Producers and Consumers Association (IMPCA).

Steam reformer furnace design will continue to develop along with methods to implement combustion safety in these furnaces. A wide variety of steam reformer designs, configurations, and component equipment exists today. Therefore, this publication includes generalized statements and recommendations on matters which there may be diversity of opinion or practice. Users of this publication should recognize that it is presented with the understanding that it can supplement, but not take the place of, sound engineering judgment, training, and experience. It does not constitute, and should not be construed to be, a code or rules or regulations.

1.2 Purpose

The purpose of this publication is to inform and guide interested parties on the procedures and practices fundamental to combustion safety in the operation of steam reformers. This publication presents a baseline for safe reformer operation which, if followed, assures our customers that the hydrogen they receive from member companies has been produced according to accepted industry-wide safety guidelines. This publication provides a technical basis that can be used to present a common viewpoint to government and regulatory authorities, ensuring proper application of rules and regulations.

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.

2 Scope

This publication applies to steam reformers that are operated with natural gas, refinery off gas, naphtha, and other light hydrocarbon streams. It specifically applies to large volume hydrogen production plants, defined for this publication as a production capacity of 380 000 scfh (10 000 Nm³h) (9 MMSCFD or 240 000 Nm³D) or greater. This publication may be applied to smaller reformers depending on the technology used.

This publication covers operational safety of steam reformer startup and shutdown. Emphasis is placed on operational guidance and features that provide safeguards against the hazards associated with the transition and infrequent nature of startups and shutdowns. The publication is not intended to address the details of design, installation, construction, and initial startup (commissioning) of steam reformers.

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.

3.2 Technical definitions

3.2.1 Boiler

Closed vessel in which water is heated and steam is generated by heat input from combustible fuels in a self-contained or attached furnace.

3.2.2 Burner

Device for the introduction of fuel and air into a combustion chamber at the velocity, turbulence, and concentration required to maintain ignition and combustion of fuel.

3.2.3 Burner management system (BMS)

Control system dedicated to combustion safety and operator assistance in the starting and stopping of fuel preparation and combustion equipment and for preventing improper operation of and damage to fuel preparation and burning equipment.

3.2.4 Bypass

Means used to temporarily deactivate an alarm, control, or protection system including, but not limited to: jumper wires, control system overrides, forced values, modified setpoints, modification of the normal lock open or closed valve positions, taking the device offline, or running temporary hoses.

NOTE—Based on the type of bypass, it can also be referred to as an override, shunt, or jumper.

3.2.5 Bypass log

Formal document used to track the approval, installation, management, and removal of bypasses.