

CGA H-7 — 2024

1<sup>ST</sup> EDITION

**STANDARD  
PROCEDURES FOR  
HYDROGEN  
SUPPLY SYSTEMS**

---



## PREFACE

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has published CGA H-7, *Standard Procedures for Hydrogen Supply Systems*, jointly produced by members of the International Harmonization Council.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

## PLEASE NOTE

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure, or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, [www.cganet.com](http://www.cganet.com).

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at [www.cganet.com](http://www.cganet.com). For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: [customerservice@cganet.com](mailto:customerservice@cganet.com).

Work Item 22-107  
Hydrogen Technologies Committee

NOTE—Appendix A (Normative) is a requirement.

NOTE—Appendix B (Normative) is for U.S. facilities.

NOTE—Appendix C (Informative) is for information only.

FIRST EDITION: 2024

© 2024 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

<b>Contents</b>	<b>Page</b>
1 Introduction.....	1
2 Scope .....	1
3 Definitions.....	1
4 General safety principles.....	2
4.1 Hydrogen properties.....	2
4.2 Safe venting of hydrogen.....	3
4.3 Grounding of hydrogen supply systems.....	3
4.4 Personal protective equipment.....	3
4.5 Purging equipment and piping.....	4
4.6 Safety planning.....	6
4.7 Additional procedures.....	8
5 Examples of implementing general safety practices.....	9
5.1 Commissioning and initial fill.....	9
5.2 Transferring hydrogen and routine deliveries.....	10
5.3 Maintenance.....	10
5.4 Decommissioning.....	11
6 References.....	12
7 Additional References.....	13
<b>Figures</b>	
Figure 1—Purging hydrogen supply systems into service.....	5
Figure 2—Purging hydrogen supply systems out of service.....	6
<b>Appendices</b>	
Appendix A—Additional Requirements (Normative).....	15
Appendix B—U.S. DOT and OSHA marking and labeling (Normative for U.S. facilities).....	17
Appendix C—Additional Information (Informative).....	20
<b>Appendix figures</b>	
Figure B-1—Hydrogen placards.....	17
Figure B-2—Liquid hydrogen workplace label.....	18
Figure B-3—Gaseous hydrogen workplace label.....	18
Figure B-4—Hazard identification signs for liquid hydrogen and gaseous hydrogen.....	19

## 1 Introduction

With the increased emphasis on renewable and clean energy, the hydrogen space is seeing tremendous growth both in activities and in entrants to the space. Much of that growth is taking place in near-consumer locations, such as gas stations and convenience stores, as opposed to the more traditional industrial settings historically associated with the use of hydrogen. Additionally, more personnel are becoming involved with the use of hydrogen.

It is important that these new entrants learn the best practices for working safely with and around hydrogen. The general public has concerns about the safety of hydrogen and must be comfortable with the work of those in the hydrogen space.

## 2 Scope

This publication provides recommended best practices and standardized procedures for personnel using hydrogen supply systems. The practices and procedures are limited to bulk gaseous and cryogenic liquid hydrogen and do not address nonbulk (cylinders) supply systems. This publication addresses processes for commissioning, filling, decommissioning, maintaining, and operating hydrogen supply systems.

This publication assumes that the hydrogen supply system has been designed and installed in accordance with the appropriate codes, standards, and local permits, as well as having an emergency preparedness plan in place. Users are encouraged to read the applicable codes and standards listed in Section 6 and Section 7 before undertaking any work on a hydrogen supply system. This publication does not replace the content found in those standards but is intended to supply best practices for working around hydrogen and with equipment in hydrogen service.

This publication contains general guidelines for any equipment that is storing, processing, or transporting hydrogen that otherwise has no procedural guidance. It is not intended to replace any system-specific standards or guidelines.

## 3 Definitions

For the purpose of this publication, the following definitions apply.

### 3.1 Publication terminology

#### 3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

#### 3.1.2 Should

Indicates that a procedure is recommended.

#### 3.1.3 May

Indicates that the procedure is optional.

#### 3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

#### 3.1.5 Can

Indicates a possibility or ability.

### 3.2 Technical definitions

#### 3.2.1 Authority having jurisdiction (AHJ)

Organization, office, or individual responsible for enforcing the requirements of a code or standard or responsible for approving equipment, materials, installations, or procedures.

NOTE—There may be multiple AHJs with various levels of responsibility and authority.