



**CGA P-35 – 2021  
GUIDELINE FOR UNLOADING  
TANKERS OF CRYOGENIC  
OXYGEN, NITROGEN, AND  
ARGON**

**SECOND EDITION**

Currently in preview, click buy full version

**PLEASE NOTE:**

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our website, [www.cganet.com](http://www.cganet.com).

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at [www.cganet.com](http://www.cganet.com). For more information contact CGA. Phone: 703-788-2700, ext. 799. E-mail: [customerservice@cganet.com](mailto:customerservice@cganet.com).

Work Item 19-002  
Distribution and Fleet Safety Committee

NOTE—Technical changes from the previous edition are underlined

SECOND EDITION: 2021  
REAFFIRMED: 2013  
REAFFIRMED: 2006  
FIRST EDITION: 2001

© 2021 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

<b>Contents</b>	<b>Page</b>
1 Scope .....	1
2 Definitions.....	1
3 Safety while unloading at a customer's site .....	1
4 Unloading liquid product into the customer station.....	2
5 References .....	6

Currently in preview, click buy full version

## 1 Scope

This publication was developed to provide general safety and unloading guidelines to be used by service providers and providers of drivers and equipment to the compressed gas industry for the distribution of cryogenic liquids by bulk cargo tank. These guidelines assist drivers when there are physical differences between the cargo tanks, pumping systems, and customer storage tanks that the driver will operate during the unloading of cryogenic liquids.

NOTE—In this guideline, the use of “driver,” “operator,” and “unloading personnel” are interchangeable.

Specific details for pumping power systems are not included in this publication. The operator should refer to the appropriate operating manual before unloading liquid product at the customer station.

A warm storage vessel fill procedure is not within the scope of this publication. Warm storage vessels should be filled with the assistance of a cryogenic tank technician in accordance with a written procedure.

## 2 Definitions

For the purpose of this publication, the following definitions apply.

### 2.1 **Publication terminology**

#### 2.1.1 **Shall**

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

#### 2.1.2 **Should**

Indicates that a procedure is recommended.

#### 2.1.3 **May**

Indicates that the procedure is optional.

#### 2.1.4 **Will**

Is used only to indicate the future, not a degree of requirement.

#### 2.1.5 **Can**

Indicates a possibility or ability.

## 3 Safety while unloading at customer's site

While unloading product at a customer's site, follow these general safety guidelines:

- Unauthorized persons are not allowed in the immediate area while unloading;
- Clean, loose-fitting, insulated gauntlet gloves, hard hats, safety glasses, full-face shields, hearing protection, and safety shoes should be worn for protection. Some companies also require the use of personal atmospheric monitoring and/or flame-retardant clothing. High-visibility clothing may be used. For additional information on personal protective equipment, see CGA P-44, Selection of Personal Protective Equipment [1];<sup>1</sup>

**CAUTION:** Full-face shields shall be lowered during loading and unloading to protect the driver from cryogenic splash or spray.

Use only low ignition energy tools when unloading oxygen. See CGA PS-55, CGA Position Statement on Use of Nonsparking Tools, for additional information about low ignition energy tools [2];

- No smoking, flames, or other ignition sources are permitted within 25 ft (7.6 m) in any direction around a liquid oxygen trailer and tractor;

<sup>1</sup> References are shown by bracketed numbers and are listed in order of appearance in the reference section.