



CGA P-8.8—2021
SAFE DESIGN AND OPERATION
OF CRYOGENIC ENCLOSURES
THIRD EDITION

Currently in preview, click buy full version

PREFACE:

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has issued CGA P-8.8, *Safe Design and Operation of Cryogenic Enclosures*, jointly produced by members of the International Harmonization Council and originally published by the European Industrial Gases Association (EIGA) as EIGA Doc 170, *Safe Design and Operation of Cryogenic Enclosures*.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure, method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 23-020
Atmospheric Gases and Equipment Committee

NOTE—Technical changes from the previous edition are underlined.

THIRD EDITION: 2021
SECOND EDITION: 2017
FIRST EDITION: 2012

© 2021 Reproduced with permission from, the European Industrial Gases Association. All rights reserved.

Contents	Page
1 Introduction.....	1
2 Scope and purpose	1
3 Definitions.....	1
4 Design considerations	2
4.1 Types of insulation.....	2
4.2 Enclosure casing	3
4.3 Piping design.....	4
4.4 Enclosure materials of construction.....	5
4.5 Load calculation.....	6
4.6 Structure beams and process equipment support.....	6
4.7 Foundations.....	7
4.8 Enclosure bottom.....	7
4.9 Maintenance facilities	8
4.10 Protection of small bore lines	8
4.11 Protection from cryogenic embrittlement.....	8
4.12 General design considerations for equipment aging	9
4.13 Special considerations for flammable and toxic fluids.....	9
5 Construction	10
6 Operation of cryogenic enclosures.....	11
6.1 Purge gas—Air separation unit processes	11
6.2 Purge gas—Processes with flammable or toxic gases.....	13
6.3 Maintenance.....	15
7 Enclosure hazards.....	15
7.1 General hazards.....	15
7.2 Overpressure.....	16
7.3 Unsafe compositions	18
7.4 Cold temperatures.....	19
7.5 Equipment erosion	19
7.6 Feed stocks containing oxides of nitrogen	19
8 Troubleshooting.....	20
8.1 Process leaks and detection	22
8.2 Ice on enclosure external surfaces and piping	24
8.3 Purge gas sampling.....	24
8.4 Purge gas flow and pressure changes	25
8.5 Operating with process leaks	25
8.6 Emergency condition guidance	26
9 Changes, modifications, and repairs to cryogenic enclosures	26
9.1 Management of change.....	26
9.2 Structural members and panels.....	27
9.3 Insulation removal	27
9.4 Confined space entry.....	27
9.5 Equipment isolation	27
9.6 Perlite removal from piping and process equipment	27
9.7 Piping and equipment.....	28
10 Training	28
11 Quality assurance.....	29
12 References	29

Figures

Figure 1—Casing pressure versus time 17

Tables

Table 1—Enclosure upset scenarios symptoms and consequences 20

Appendix Tables

Table A1—Example of a coldbox located pressure equipment annual inspection checklist 32

Table A2—Example of a coldbox located pressure equipment inspection checklist 34

Currently in preview, click buy full version

1 Introduction

Cryogenic processes often operate inside enclosures that insulate the process equipment and interconnecting piping from ambient air and temperature. This prevents many problems, including excessive heat leak into the process and water freezing around the equipment. In many cases, the enclosure is purged with a dry gas to prevent ambient air from entering the enclosure and creating hazardous mixtures.

2 Scope and purpose

Cryogenic enclosures can create potential process safety hazards. This publication identifies general hazards and provides guidance to reduce their frequency and consequences. It provides safety guidance and addresses design and operating practices only as they affect safety.

This publication addresses both cryogenic air separation unit (ASU) and hydrogen/carbon monoxide (H₂/CO) processes. A number of existing publications cover special requirements of these processes and their equipment [1, 2, 3, 4].

This publication is primarily to document current practices and is intended to apply to new facilities. It is recognized that some existing plants may not meet all recommendations or requirements from this publication. This publication is not intended to be applied retroactively, including where this publication uses the word "shall".

This publication does not cover the following:

- generally accepted engineering practices for structures and process equipment. Only those issues that are specific to cryogenic enclosures are included;
- enclosures for processes producing liquid hydrogen or helium. The extreme cold temperatures of these processes require specialized knowledge and practices that are beyond the scope of this publication; and
- external structures on/attached to the cryogenic enclosure, for example, platforms, ladders, vents, lightning arrestors, etc. For more information on the safe location of oxygen and nitrogen vents relative to the location of platforms and ladders, see CGA P-8.7, *Safe Location of Oxygen and Inert Gas Vents* [5].

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.