



**CGA P-8.9—2023
BULK LIQUID OXYGEN,
NITROGEN, AND ARGON
STORAGE SYSTEMS AT
PRODUCTION SITES**

THIRD EDITION

Currently in preview. Click buy full version

PREFACE:

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has issued CGA P-8.9, *Bulk Liquid Oxygen, Nitrogen, and Argon Storage Systems at Production Sites*, jointly produced by members of the International Harmonization Council and originally published by the European Industrial Gases Association (EIGA) as EIGA Doc 127, *Bulk Liquid Oxygen, Nitrogen, and Argon Storage Systems at Production Sites*.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulation.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 24-51

Atmospheric Gases and Equipment Committee

NOTE—Technical changes from the previous edition are underlined.

THIRD EDITION: 2023
SECOND EDITION: 2020
FIRST EDITION: 2013

© 2023 – Reproduced with permission from, the European Industrial Gases Association. All rights reserved.

Contents	Page
1 Introduction.....	1
2 Scope and purpose	1
2.1 Scope	1
2.2 Purpose	1
3 Definitions.....	2
4 General properties and hazards	3
4.1 Oxygen	4
4.2 Argon	4
4.3 Nitrogen	5
4.4 Ice build-up	6
4.5 Oil, grease, combustible materials, cleaning, and other foreign matter	6
4.6 Embrittlement of materials.....	6
4.7 Cryogenic temperatures	6
4.8 Perlite	7
5 Storage tank system design considerations	7
5.1 General.....	7
5.2 Flat-bottom tanks	7
5.3 Piping and nozzles	10
5.4 Tank control and protection	12
5.5 Isolation valves	20
5.6 Foundations.....	21
6 Storage tank fabrication	24
6.1 General.....	24
6.2 Storage and cleanliness of materials at erection site	25
6.3 Inspection and testing during the fabrication	25
7 Site selection and layout of installation	25
7.1 General.....	25
7.2 Safety distances	26
7.3 Location of the installation	26
7.4 Liquid transfer area.....	29
8 Testing and commissioning	29
8.1 Controls during manufacturing and construction	29
8.2 Testing, precommissioning checks, and commissioning of installations	29
8.3 Commissioning	31
9 Operation and maintenance	31
9.1 Operation of the installation	31
9.2 Hot work	31
9.3 Periodic inspection and maintenance	31
9.4 Modifications and change of service	34
10 Training and protection of personnel.....	34
10.1 Work permit	34
10.2 Entry into tanks	35
10.3 Training of personnel.....	35
10.4 Emergency procedures	35
11 References	36

Figures

Figure 1—Example of liquid level definitions for flat-bottom storage tanks 3
Figure 2—Example of a flat-bottom tank storage system 14
Figure 3—Emergency shutoff valves 21
Figure 4—Typical arrangement of base insulation system 23

Appendices

Appendix A—Specific requirements for cluster storage tanks at production sites 39
Appendix B—Specific requirements for large capacity vacuum-insulated storage tanks
at production sites 10
Appendix C—Example of a bulk storage tank annual external inspection checklist 4

Currently in preview, click buy full versi

1 Introduction

The increase in recent years in the size and production capacity of air separation plants has led to a corresponding increase in the capacity of cryogenic liquid storage installations at production sites. Therefore, it has become more important to consider the potential hazards associated with cryogenic liquid, the consequences and effects on the local environment of a major release of liquid, and the preventive measures required.

2 Scope and purpose

2.1 Scope

This publication specifically covers storage installations on production sites where the storage tank is flat-bottom constructed, is connected to the production process plant, and the individual tank capacity is greater than 125 000 liters.

See Appendices A and B, for bulk liquid storage installations on production sites where the storage tank(s):

- is vacuum-insulated constructed with an individual capacity greater than 125 000 liters,
- are manifolded vacuum-insulated tanks with a combined capacity greater than 125 000 liters;
- are cluster tanks where the tanks have a combined capacity greater than 125 000 liters; or
- are combinations of vacuum-insulated tanks and cluster tanks that are manifolded together and have a combined capacity greater than 125 000 liters.

The information contained in this publication applies only to new installations designed after the publication of this document and not to existing installations. However, the information contained in this publication may benefit existing installations or those in the project phase.

Specific requirements for loading systems can be found in CGA P-31, *Liquid Oxygen, Nitrogen, and Argon Cryogenic Tanker Loading Systems* [1].¹

For flat-bottom storage tanks not connected to a production process plant, the requirements of this publication shall be met. For vacuum-insulated tanks or other storage configurations, see Appendices A and B.

2.2 Purpose

This publication provides guidance for those persons directly associated with the design, installation, operation, and maintenance of bulk cryogenic liquid storage systems. The intent of this publication is to ensure that a minimum, uniform level of safety is provided throughout the industrial gas industry for the protection of the public and industry employees. Users of this publication should recognize that it is presented with the understanding that it cannot take the place of sound engineering judgment, training, and experience.

The information presented does not supplant, but is intended to complement, national and local regulations and codes of practice such as the British Compressed Gases Association publications, (BCGA) CP20, *Bulk liquid oxygen storage at production sites* and BCGA CP22, *Bulk liquid argon or nitrogen storage at production sites* [2, 3].

This publication presents recommendations to reduce the possibility of large releases of stored cryogenic fluids from a storage system through installation of protective equipment and instrumentation, equipment inspection and testing, and storage system design criteria.

It is the intent of this publication to emphasize prevention of releases. However, this publication provides basic information about mitigation of releases even if they are unlikely.

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section.