



CSA/ANSI Z21.10.3:19 • CSA 4.3:19
National Standard of Canada
American National Standard



Gas-fired water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous



Standards Council of Canada
Conseil canadien des normes

Legal Notice for Standards

Canadian Standards Association and CSA America Standards Inc. (operating as "CSA Group") develop standards through a consensus standards development process approved by the Standards Council of Canada and the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This is a draft document for the purpose of comment, review, and approval only. This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group's and/or others' intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Assignment of copyright

A user who provides a comment to CSA Group in relation to this document agrees that the entire copyright in the comment is hereby assigned to CSA Group and waives all associated moral rights, such that CSA Group is the exclusive owner of such comment and may use such comment as it sees fit. The user, being the sole owner of the copyright or having the authority to assign the copyright on behalf of his or her employer, confirms his or her ability to assign the copyright in the comment provided to CSA Group.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached draft standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.

Revision History

CSA/ANSI Z21.10.3:19 • CSA 4.3:19, Gas-fired water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous

Revision from previous edition	Revision symbol (in margin)
Clauses 3 , 4.1.25 , 4.2.9 , 4.2.11 , 4.9.1 , 4.9.2 , 4.26 , 4.31.2 , 4.32.3 , 4.32.37 , 5.5 , 5.9.1 , 5.17 , 5.18 , 5.33 , and 8.4 Tables 3 , 2-A , and 2-B	Δ

Currently in preview, click buy full version

Standards Update Service

***CSA/ANSI Z21.10.3:19 • CSA 4.3:19
November 2019***

Title: *Gas-fired water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **126 27**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada’s economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada



Standards Council of Canada
Conseil canadien des normes

Cette Norme Nationale du Canada n’est disponible qu’en anglais.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

**A trademark of the Canadian Standards Association, operating as “CSA Group”*

CSA Group

The Canadian Standards Association (operating as "CSA Group"), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group's standards development by volunteering their time and skills to Committee work and supporting CSA Groups objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group's total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Groups standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects product that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard, Toronto, Ontario,
Canada M9W 1R3

American National Standards Institute

The American National Standards Institute (ANSI), Inc. is the nationally recognized coordinator of voluntary standards development in the United States through which voluntary organizations, representing virtually every technical discipline and every facet of trade and commerce, organized labor and consumer interests, establish and improve the some 10,000 national consensus standards currently approved as American National Standards.

ANSI provides that the interests of the public may have appropriate participation and representation in standardization activity, and cooperates with departments and agencies of U.S. Federal, State and local governments in achieving compatibility between government codes and standards and the voluntary standards of industry and commerce.

ANSI represents the interests of the United States in international nontreaty organizations such as the International Organization for Standardization (ISO) and the International Electrotechnical Commission (IEC). The Institute maintains close ties with regional organizations such as the Pacific Area Standards Congress (PASC) and the Pan American Standards Commission (COPANT). As such, ANSI coordinates the activities involved in the U.S. participation in these groups.

ANSI approval of standards is intended to verify that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standards has been achieved. ANSI coordination is intended to assist the voluntary system to ensure that national standards needs are identified and met with a set of standards that are without conflict or unnecessary duplication in their requirements.

Responsibility of approving American standards rests
with the
American National Standards Institute, Inc.
25 West 43rd Street, Fourth floor
New York, NY 10036

*National Standard of Canada
American National Standard*

*CSA/ANSI Z21.10.3:19 • CSA 4.3:19
Gas-fired water heaters, volume III,
storage water heaters with input
ratings above 75,000 Btu per hour,
circulating and instantaneous*



*American National
Standards Institute, Inc.*



*®A trademark of the Canadian Standards Association and
CSA America Standards Inc. operating as "CSA Group"*

IGAC

*Interprovincial
Gas Advisory Council*



*Approved on September 23, 2019 by ANSI
Approved on October 9, 2019 by IGAC
Effective in Canada May 1, 2021
Published in November 2019 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at store.csagroup.org
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 97.100.20; 91.140.65
ISBN 978-1-4883-1547-3*

*© 2019 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Interprovincial Gas Advisory Council	4
Canadian Technical Committee on Gas Appliances and Related Accessories	6
Z21/83 Technical Committee on Performance and Installation of Gas Burning Appliances and Related Accessories	9
Joint Technical Subcommittee on Gas-Fired Water Heaters	12
Preface	18
1 Scope	21
2 Reference publications	23
3 Definitions	27
4 Construction	38
4.1 General construction	38
4.2 Materials	44
4.3 Combustion air supply	47
4.4 Water heater openings	48
4.5 Burners	48
4.6 Flame spreaders	50
4.7 Primary air adjustment means	50
4.8 Main burner orifices and orifice fitting	51
4.9 Automatic gas ignition systems	52
4.10 Pilot gas filters	56
4.11 Gas connections	57
4.12 Opening for relief valve	59
4.13 Dip tubes	59
4.14 Manually operated gas valves	60
4.15 Gas appliance pressure regulators and gas pressure switches	61
4.16 Adjustment of minimum input rating	62
4.17 Thermostats	62
4.18 Automatic valves and safety shutoff valves	62
4.19 Bleeds and vents	63
4.20 Automatic gas shutoff systems	63
4.21 Relief valves	64
4.22 Condensate disposal	65
4.23 Flue collars	66
4.24 Flue pipe extensions	66
4.25 Draft hoods	66
4.26 Non-metallic vent and air intake connection strength test	67
4.27 Automatic vent damper devices	68
4.28 Automatic flue damper devices	68
4.29 Electrical equipment and wiring	70

4.30	Vent and air intake pipes of direct vent systems	84
4.31	Instructions	85
4.32	Marking	97
5	Performance	109
5.1	General	109
5.2	Test gases	115
5.3	Test pressures and burner adjustments	117
5.4	Combustion	117
5.5	Category determination	119
5.6	Burner and pilot operating characteristics	123
5.7	Piloted ignition systems	126
5.8	Proved igniter systems	130
5.9	Direct ignition systems	132
5.10	Efficiency	134
5.11	Gas appliance pressure regulators	134
5.12	Automatic valves and safety shutoff valves	134
5.13	Temperature control	135
5.14	Storage heater temperature limits	135
5.15	Temperature limiting devices	137
5.16	Evaluation of burn hazard potential of exterior surfaces	139
5.17	Wall, floor, and ceiling temperatures	142
5.18	Non-metallic vent material temperatures	143
5.19	Flue gas temperature	145
5.20	Temperature of manually operated parts	146
5.21	Burner and flame spreader temperatures	147
5.22	Draft hoods	148
5.23	Draft tests for water heaters equipped with power burners	152
5.24	Automatic vent damper devices	154
5.25	Automatic flue damper devices	154
5.26	Wind test	158
5.27	Safety circuit analysis	160
5.28	Capacities of storage vessels	161
5.29	Capacities of tube type water heaters	161
5.30	Hydrostatic test	161
5.31	Burner durability	162
5.32	Venting systems for Category II, III, or IV water heaters	163
5.33	Condensate disposal system(s)	163
5.34	Rain tests	164
5.35	Direct vent systems	166
5.36	Marking material adhesion and legibility	173
6	Manufacturing and production tests	174
7	Items unique to the United States	175
7.1	High altitude	175
7.2	Thermal efficiency	175
7.3	Temperature and pressure relief valves	175
7.4	Marking material adhesion and legibility	175

7.5 General construction and assembly 176

8 Items unique to Canada 176

- 8.1 High altitude 176
- 8.2 Relief valves 176
- 8.3 Storage vessels 176
- 8.4 Outdoor installation 176
 - 8.4.1 Components for low temperature operation 176
 - 8.4.2 Rating plate marking for outdoor heaters 177
- 8.5 Draft hoods 177
- 8.6 Pilot burners and safety shutoff devices 177
- 8.7 Thermal efficiency 177
- 8.8 French translations for quoted instructions and markings 177

-
- Annex A (normative) — Outline of lighting instructions for appliances equipped with continuous pilots 195
 - Annex B (normative) — Outline of operating instructions for appliances equipped with intermittent pilot or interrupted pilot systems 198
 - Annex C (normative) — Outline of operating instructions for appliances equipped with direct ignition systems 201
 - Annex D (normative) — Optional Clauses for listed gas appliance conversion kits 204
 - Annex E (normative) — Efficiency test procedures 207
 - Annex F (informative) — Pertinent references to ANSI Y14.15 212
 - Annex G (informative) — Wire color designations 213
 - Annex H (informative) — Recommended wire color usage 214
 - Annex I (informative) — Preferred graphic symbols of commonly used items, extracted from standard ANSI/IEEE 315, graphic symbols for electrical and electronics diagrams, and abbreviations for the symbols 215
 - Annex J (informative) — Sample failure mode and effects analysis for component miswiring* 217
 - Annex K (informative) — Table of conversion factors 218
 - Annex L (informative) — Legibility and placement of safety information in water heater markings and manuals 221

Preface

This is the ninth edition of CSA/ANSI Z21.10.3 • CSA 4.3, *Gas-fired water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*. It supersedes the previous editions published in 2017, 2015, 2014, 2013, 2011, 2004, 2001, and 1998.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Joint Technical Subcommittee on Gas-Fired Water Heaters under the jurisdiction of the Z21/83 Technical Committee on Performance and Installation of Gas Burning Appliances and Related Accessories and the Strategic Steering Committee on Fuels and Appliances. It has been formally approved by the Z21/83 Technical Committee, the Canadian Technical Committee on Gas Appliances and Related Accessories, and the Interprovincial Gas Advisory Council.

This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

This Standard has been approved by the American National Standards Institute (ANSI) as an American National Standard.

Interpretations: The Strategic Steering Committee on Fuels and Appliances has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant CSA committee interpretation has not already been published, CSA Group’s procedures for interpretation shall be followed to determine the intended safety principle.”

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

- 5) *This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

History of the development of CSA/ANSI Z21.10.3 • CSA 4.3

Note: *This history is informative and is not part of the standard.*

With the onset of the Free Trade Agreement between the United States and Canada on January 2, 1988, significant attention was given to the harmonization of the United States and Canadian safety standards addressing gas-fired equipment for residential, commercial, and industrial applications. It was believed that the elimination of the differences between the standards would remove potential trade barriers and provide an atmosphere in which North American manufacturers could market more freely in the United States and Canada. The harmonization of these standards was also seen as a step toward harmonization with international standards. Joint subcommittees were established to facilitate the standards harmonization process between the United States and Canada.

The draft harmonized standard was based on current coverage from the American National Standard for *Gas Water Heaters, Volume III, Storage Water Heaters, with Input Rating above 75,000 Btu Per Hour, Circulating and Instantaneous*, ANSI Z21.10.3-1993 and Addenda Z21.10.3a-1994, Z21.10.3b-1994, Z21.10.3c-1996 and the Canadian Standard for *Circulating Tank, and Instantaneous and Large Automatic Storage Type Gas Water Heaters*, CAN1-4.3-M85. The draft was subsequently issued for public review and comment during April 1996.

Following reconsideration and modification of the proposed draft standard, in light of comments received, the joint water heater subcommittee, at its July 24-25, 1996 meeting, recommended the proposed draft to the Z21 Committee and the CGA Standards Steering Committee for approval.

The proposed draft of the harmonized standard for gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous, as modified by the joint subcommittee at its meeting of July 24-25, 1996, was approved by the Z21/83 Committee at its April 17, 1997 meeting and by the CGA Standards Steering Committee on May 6, 1997.

The first edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters, with input rating above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on September 10, 1997 and by the American National Standards Institute Inc. on March 19, 1998.

The second edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on August 1, 2001 and by the American National Standards Institute, Inc. on December 20, 2001.

The third edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on September 7, 2004 and by the American National Standards Institute, Inc. on July 2, 2004.

The fourth edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on January 15, 2009 and by the American National Standards Institute, Inc. on June 20, 2008.

The fifth edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on March 25, 2013 and by the American National Standards Institute, Inc. on February 25, 2013.

The sixth edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on August 7, 2014 and by the American National Standards Institute, Inc. on July 2, 2014.

The seventh edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on August 7, 2015 and by the American National Standards Institute, Inc. on October 5, 2015.

The eighth edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on August 18, 2017 and by the American National Standards Institute, Inc. on August 21, 2017.

This, the ninth edition of the harmonized Z21/CSA Standard for *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, was approved by the Canadian Interprovincial Gas Advisory Council on October 9, 2019 and by the American National Standards Institute, Inc. on September 23, 2019.

The previous editions of the *Gas water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous*, and addenda thereto, approved by the Interprovincial Gas Advisory Council and American National Standards Institute, Inc. are as follows:

Z21.10.3-1998 • CSA 4.3-M98	Z21.10.3-2001 • CSA 4.3-2001
Z21.10.3a-2000 • CSA 4.3a-M00	Z21.10.3a-2003 • CSA 4.3a-2003
Z21.10.3b-2000 • CSA 4.3b-2000	Z21.10.3b-2004 • CSA 4.3b-2004
ANSI Z21.10.3-2004 • CSA 4.3-2004	Z21.10.3-2011 • CSA 4.3-2011
ANSI Z21.10.3a-2007 • CSA 4.3a-2007	
ANSI Z21.10.3b-2008 • CSA 4.3b-2008	
Z21.10.3-2013 • CSA 4.3-2013	Z21.10.3-2014 • CSA 4.3-2014
Z21.10.3-2015 • CSA 4.3-2015	Z21.10.3-2017 • CSA 4.3-2017

The following identifies the designation and year of the ninth edition of the Standard:

CSA/ANSI Z21.10.3:19 • CSA 4.3:19

Note: *This edition of CSA/ANSI Z21.10.3 • CSA 4.3 incorporates changes to the 2017 edition. Changes, other than editorial, are denoted by a delta in the margin.*

CSA/ANSI Z21.10.3:19 • CSA 4.3:19

Gas-fired water heaters, volume III, storage water heaters with input ratings above 75,000 Btu per hour, circulating and instantaneous

1 Scope

1.1

This Standard applies to newly produced, large automatic storage water heaters having input ratings above 75,000 Btu/hr (21 980 W), instantaneous water heaters, circulating water heaters including booster water heaters (see Clause [3](#), Definitions), hereinafter referred to as water heaters or appliances, constructed entirely of new, unused parts and materials:

- a) for use with natural gas;
- b) for use with manufactured gas;
- c) for use with mixed gas;
- d) for use with liquefied petroleum gases;
- e) for use with LP gas-air mixtures;
- f) for recreational vehicle installation for use with liquefied petroleum gases only (see Clause [4.1.27](#));
- g) for manufactured home (mobile home) installation convertible for use with natural gas and liquefied petroleum gases when provision is made for the simple conversion from one gas to the other (see Clause [4.1.26](#));
- h) for recreational vehicle installation convertible for use with natural gas and liquefied petroleum gases when provision is made for the simple conversion from one gas to the other (see Clause [4.1.27](#)); and
- i) for use with combination potable water/space heating applications (see Clauses [3](#), Definitions, and Clause [4.1.30](#)).

Automatic storage water heaters having input ratings of 75,000 Btu/hr (21 980 W) or less are covered in Volume I.

1.2

Instantaneous water heaters with input ratings of 200,000 Btu/h (58 614 W) or less, which are designed to deliver water at a controlled temperature of less than 180 °F (82 °C), are subject to Federal minimum efficiency requirements for residential water heaters or covered in Clause [8](#), Items unique to Canada, are exempt from recovery, thermal efficiencies and standby loss, and related markings required by this Standard.

1.3

Direct vent water heaters anticipated by this Standard are essentially balanced flue appliances with the air intake and vent outlet in close proximity. Other designs are to be subjected to such additional tests as believed necessary at the discretion of the testing agency.