

# **Thermoplastic hose and hose couplings for conducting propane and natural gas**



# Legal Notice for Standards

Canadian Standards Association and CSA America Standards Inc. (operating as "CSA Group") develop standards through a consensus standards development process approved by the Standards Council of Canada and the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

## Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

## Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group's and/or others' intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

## Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

## Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in printed or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and must not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



# *Revision History*

**CSA 8.3-2015, Thermoplastic hose and hose couplings for conducting propane and natural gas**

Errata — October 2018	Revision symbol (in margin)
Clause <a href="#">4.5</a>	Δ

Currently in preview, click buy full version

# ***Standards Update Service***

***CSA 8.3-2015***

***August 2015***

**Title:** *Thermoplastic hose and hose couplings for conducting propane and natural gas*

To register for e-mail notification about any updates to this publication

- go to [store.csagroup.org](http://store.csagroup.org)
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **24229.1**

If you require assistance, please e-mail [techsupport@csagroup.org](mailto:techsupport@csagroup.org) or call 416-747-2233.

Visit CSA Group's policy on privacy at [www.csagroup.org/legal](http://www.csagroup.org/legal) to find out how we protect your personal information.

*CSA 8.3-2015*  
***Thermoplastic hose and hose  
couplings for conducting propane  
and natural gas***

**IGAC**

*Interprovincial Gas Advisory Council*



® A trademark of the Canadian Standards Association and CSA America Inc., operating as "CSA Group"

*Approved on August 7, 2015 by IGAC  
Effective in Canada January 2017  
Published in August 2015 by CSA Group  
A not-for-profit private sector organization  
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at [store.csagroup.org](http://store.csagroup.org)  
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ISBN 978-1-77139-534-2*

*© 2015 Canadian Standards Association  
All rights reserved. No part of this publication may be reproduced in any form whatsoever  
without the prior permission of the publisher.*

# Contents

Interprovincial Gas Advisory Council	3
Technical Committee on Gas Appliances and Related Accessories	5
Z21/CSA Joint Technical Subcommittee on Standards for Connectors for Gas Appliances	7
Preface	9
<b>1 Scope</b>	<b>10</b>
<b>2 Reference publications</b>	<b>11</b>
<b>3 Definitions</b>	<b>13</b>
<b>4 Hose</b>	<b>13</b>
4.1 General construction	13
4.1.1 Design pressure	13
4.1.2 Design tolerances	13
4.1.3 Inner tube construction	13
4.1.4 Tube reinforcement	14
4.1.5 Outer surface construction	14
4.2 Identification and marking	14
4.3 Tests and methods of test	14
4.3.1 Hydrostatic pressure test	14
4.3.2 Burst test	14
4.3.3 Hydrostatic proof pressure test	15
4.3.4 Tensile strength and elongation of tube	15
4.3.5 Swelling test of tube	15
4.3.6 Cold flexibility test	15
4.3.7 Air aging	16
4.3.8 Repeated bending	16
4.4 Ultraviolet light exposure	17
4.5 Permeation	17
4.6 Frequency of testing	17
<b>5 Hose end couplings</b>	<b>17</b>
5.1 Construction	17
5.1.8 Hose barb bending moment test	18
5.1.9 Salt spray test (for steel hose end couplings)	19
5.1.10 Ammonia vapor test (for brass hose end couplings)	19
5.1.11 Non-metallic resistant test	19
<b>6 Hose assemblies</b>	<b>20</b>
6.1 Proof pressure test	20
6.2 Burst	20
6.3 Pull force	20
6.4 Marking	21

6.4.3 Marking material adhesion and legibility 22

**7 Manufacturing and production tests for hose end couplings and hose assemblies 23**

---

Currently in preview, click buy full version

# Preface

This is the third edition of CSA 8.3, *Thermoplastic hose and hose couplings for conducting propane and natural gas*. It supersedes the previous editions published in 1975 and 1977.

This Standard was prepared by the Z21/CSA Joint Technical Subcommittee on Standards for Connectors for Gas Appliances, under the jurisdiction of the Strategic Steering Committee on Standards for Gas Appliances and Related Accessories, and had been formally approved by the CSA Technical Committee and the Interprovincial Gas Advisory Council.

**Interpretations:** The Strategic Steering Committee on Standards for Standards for Gas Appliances and Related Accessories has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA’s procedures for interpretation shall be followed to determine the intended safety principle.”

## Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *This standard contains SI (Metric) corresponding to the yard/pound quantities, the purpose being to allow the standard to be used in SI (Metric) units. (Standard for use of the International System of Units (SI): The Modern Metric System, IEEE/ASTM SI 10 or ISO 80000-1:2009 Quantities and units- Part 1: General are used as a guide in making metric conversion from yard/pound quantities.) If a value for a measurement and a corresponding value in other units are stated, the first stated value is to be regarded as the requirement. The given corresponding value may be approximate. If a value for a measurement and a corresponding value in other units are both specified as a quoted marking requirement, the first stated unit, or both shall be provided.*
- 3) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 4) *This publication was developed by consensus, which is defined by CSA Policy governing standardization - Code of good practice for standardization as substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.*
- 5) *This Standard is subject to periodic review, and suggestions for their improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Proposal for change” in the subject line:*
  - a) *Standard designation (number)*
  - b) *relevant clause (table), and/or figure number;*
  - c) *wording of the proposed change; and*
  - d) *rational justification for the change.*
- 6) *To submit a request for interpretation of this Standard, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Request for interpretation” in the subject line:*
  - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
  - b) *provide an explanation of circumstances surrounding the actual field condition; and*
  - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

*Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at [standardsactivities.csa.ca](http://standardsactivities.csa.ca).*

# CSA 8.3-2015

## Thermoplastic hose and hose couplings for conducting propane and natural gas

### 1 Scope

#### 1.1

This Standard applies to newly produced thermoplastic hose, hose couplings, and complete assemblies of hose and couplings used to conduct natural gas in a gaseous state and propane in either a liquid or gaseous state to be used at temperatures between -40°F (-40 °C) and 140°F (60 °C).

#### 1.2

Hose assemblies covered in this Standard are installed in accordance with the appliance and/or the equipment manufacturers instructions. If installation instructions are not present, installation of this product shall be completed in accordance with the *Natural Gas and Propane Installation Code*, CSA B149.1.

**Note:** Per the *Natural Gas and Propane Installation Code*, CSA B149.1 this Standard does not apply to appliance applications covered by the *Standard for Connectors for Gas Appliances*, ANSI Z21.24 • CSA 6.10, the *Standard for Gas Hose Connectors for Portable Outdoor Gas-Fired Appliances*, ANSI Z21.24 • CSA 8.4, the *Standard for Connectors for Movable Gas Appliances*, ANSI Z21.69 • CSA 6.16, the *Standard for Connectors of Outdoor Gas Appliances and Manufactured Homes*, ANSI Z21.75 • CSA 6.27, and the *Standard for Gas Hose Connectors for Portable and Movable Gas Appliances*, ANSI Z21.101 • CSA 8.1.

#### 1.3

Clause 4, Hose, covers hose having a rated working pressure of at least 350 psig (2.4 MPa) and a minimum burst pressure of five times the rated working pressure.

#### 1.4

Clause 5, Couplings, covers hose couplings of a type to be used with the hose complying with Clause 4 of this Standard.

#### 1.5

Clause 6, Hose assemblies, covers hose assemblies or types using hose and couplings complying with Clauses 4 and 5 of this Standard.

#### 1.6

This Standard contains SI (Metric) units corresponding to the yard/pound quantities, the purpose being to allow the standard to be used in SI (Metric) units. (IEEE/ASTM SI 10, *American National Standard for Metric Practice*, or ISO 80000-1:2009, *Quantities and units - Part 1: General*, is used as a guide in making metric conversion from yard/pound quantities.) If a value for a measurement and a corresponding value in other units are stated, the first stated value is to be regarded as the requirement. The given corresponding value may be approximate. If a value for a measurement and a corresponding value in other units are both specified as a quoted marking requirement, the first stated unit, or both, are to be provided.