



**CSA
Group**

ANSI Z83.18-2017

**Recirculating direct gas-fired heating and
forced ventilation appliances for
commercial and industrial applications**



Legal Notice for Standards

Canadian Standards Association and CSA America, Inc. (operating as "CSA Group") develop standards through a consensus standards development process approved by the Standards Council of Canada and the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group's and/or others' intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in printed or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and must not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Revision History

ANSI Z83.18-2017, Recirculating direct gas-fired heating and forced ventilation appliances for commercial and industrial applications

Revision from previous edition	Revision symbol (in margin)
Clause 1.1 Annex B	Δ

Currently in preview, click buy full version

Standards Update Service

ANSI Z83.18-2017

March 2017

Title: *Recirculating direct gas-fired heating and forced ventilation appliances for commercial and industrial applications*

To register for e-mail notification about any updates to this publication

- go to shop.csa.ca
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **124 97**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

CSA Group

The Canadian Standards Association (operating as CSA Group), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Groups standards development by volunteering their time and skills to Committee work and supporting CSA Groups objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Groups total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Groups standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects product that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard, Toronto, Ontario,
Canada M9W 1R3

American National Standards Institute

The American National Standards Institute (ANSI), Inc. is the nationally recognized coordinator of voluntary standards development in the United States through which voluntary organizations, representing virtually every technical discipline and every facet of trade and commerce, organized labor and consumer interests, establish and improve the some 10,000 national consensus standards currently approved as American National Standards.

ANSI provides that the interests of the public may have appropriate participation and representation in standardization activity, and cooperates with departments and agencies of U.S. Federal, State and local governments in achieving compatibility between government codes and standards and the voluntary standards of industry and commerce.

ANSI represents the interests of the United States in international nontreaty organizations such as the International Organization for Standardization (ISO) and the International Electrotechnical Commission (IEC). The Institute maintains close ties with regional organizations such as the Pacific Area Standards Congress (PASC) and the Pan American Standards Commission (COPANT). As such, ANSI coordinates the activities involved in the U.S. participation in these groups.

ANSI approval of standards is intended to verify that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standards has been achieved. ANSI coordination is intended to assist the voluntary system to ensure that national standards needs are identified and met with a set of standards that are without conflict or unnecessary duplication in their requirements.

Responsibility of approving American standards rests
with the
American National Standards Institute, Inc.
25 West 43rd Street, Fourth floor
New York, NY 10036

ANSI Z83.18-2017
**Recirculating direct gas-fired
heating and forced ventilation
appliances for commercial and
industrial applications**



American National Standards Institute, Inc.



**CSA
Group**

®A trademark of the Canadian Standards Association and CSA America Inc., operating as "CSA Group"

*Approved on June 14, 2016 by ANSI
Published in March 2017 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at shop.csa.ca
or call toll-free 1-800-463-6727 or 416-747-4044.*

ISBN 978-1-4883-0428-6

© 2017 CSA Group

*All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Z21/83 Technical Committee on Performance and Installation of Gas Burning Appliances and Related Accessories 3

Z83/CSA Joint Technical Subcommittee on Gas-Fired Heavy-Duty Forced Air Heaters 6

Preface 9

1 Scope 13

2 Reference publications 14

3 Definitions 17

4 Construction 24

4.1 General construction 24

4.2 Assembly 25

4.3 Accessibility 26

4.4 Main burners 26

4.5 Combustion air control 27

4.6 Orifices and orifice fittings 27

4.7 Automatic gas ignition systems 27

4.8 Flame safeguards 28

4.9 Valve trains 30

4.10 Manual gas valves 31

4.11 Gas supply lines 31

4.12 Atmospheric vents and gas reliefs or backdraft dampers 34

4.13 Automatic valves and safety shutoff valves 35

4.14 Gas appliance pressure regulators 35

4.15 Discharge air, purge, limit controls, and interlocks 36

4.16 Thickness of materials 39

4.17 Fan motors 41

4.18 Fans 44

4.19 Air filters 44

4.20 Protection of service personnel 44

4.21 Operating and installation instructions 47

4.22 Markings 50

5 Performance 54

5.1 General 54

5.2 Test gases 56

5.3 Test pressure and burner adjustments 57

5.4 Basic test arrangement 57

5.5 Air throughput measurement 61

5.6 High temperature limit control system 61

5.7 Air flow sensing systems 62

5.8 Operating temperature control system 65

5.9 Combustion 66

5.10	Burner operating characteristics	68
5.11	Piloted ignition systems	69
5.12	Direct ignition systems	70
5.13	Gas appliance pressure regulators	71
5.14	Automatic valves	71
5.15	Burner and heater input rating determination	72
5.16	Manifold and control assembly capacity	72
5.17	Wall, floor (optional), ceiling, electrical equipment, and wiring temperatures	72
5.18	Electrical continuity and dielectric strength	73
5.19	Heaters for outdoor installation	74
5.20	Rain and wind tests for inlet air openings	77
5.21	Marking material adhesion and legibility	79

6 Electrical equipment and wiring 80

7 Manufacturing and production tests 91

Annex A (normative)	— Emissions protocol	93
Annex B (informative)	— Protocol for the measurement of and emissions testing for Nitrogen Oxides and Carbon Monoxide from direct gas-fired heaters	106
Annex C (informative)	— Pertinent references to ANSI Y14.15	106
Annex D (informative)	— Wire color designations	109
Annex E (informative)	— Recommended wire color usage	110
Annex F (informative)	— Preferred graphic symbols of commonly used items, extracted from standard ANSI/IEEE 315, Graphic symbols for electrical and electronics diagrams, and abbreviations for these items	111
Annex G (informative)	— Table of conversion factors	113

Z21/83 Technical Committee on Performance and Installation of Gas Burning Appliances and Related Accessories

B.J. Swiecicki	National Propane Gas Association, Washington, District of Columbia, USA <i>Category: Gas Supplier</i>	<i>Chair</i>
M.W. Wilber	Crane Engineering, Plymouth, Minnesota, USA <i>Category: General Interest</i>	<i>Vice-Chair</i>
M. Ali	Association of Home Appliance Manufacturers, Washington, District of Columbia, USA <i>Category: Manufacturer</i>	<i>Alternate</i>
J. Brania	Underwriters Laboratories Inc., Melville, New York, USA <i>Category: Research/Testing</i>	
J. Cutts	The Home Depot, Atlanta, Georgia, USA <i>Category: General Interest</i>	
M. Deegan	Clearwater Gas System, Clearwater, Florida, USA <i>Category: Government and/or Regulatory Authority</i>	
M. Diesch	Lennox International Inc., Carrollton, Texas, USA <i>Category: Manufacturer</i>	
J.M. Emmel	Virginia Tech, Blacksburg, Virginia, USA <i>Category: Consumer/User</i>	
G. Gross	International Code Council, Chicago, Illinois, USA <i>Category: Government and/or Regulatory Authority</i>	

C. Grider	Intertek Testing Services NA Inc., Cortland, New York, USA <i>Category: Research/Testing</i>	<i>Alternate</i>
T.F. Hardin	Underwriters Laboratories Inc., Research Triangle Park, North Carolina, USA <i>Category: Research/Testing</i>	<i>Alternate</i>
D. Hubbard	Intertek Commercial & Electrical, Chagrin Falls, Ohio, USA <i>Category: Research/Testing</i>	
D.M. Jakobs	Rheem Manufacturing Company Air Conditioning Division, Fort Smith, Arkansas, USA <i>Category: Manufacturer</i>	
R.A. Jordan	Consumer Product Safety Commission, Rockville, Maryland, USA	<i>Non-Voting</i>
S. Kristjansson	Sempra Energy Utility, Los Angeles, California, USA <i>Category: Gas Supplier</i>	<i>Alternate</i>
A. Lanier Papageorge	Southern Company Gas, Atlanta, Georgia, USA <i>Category: Gas Supplier</i>	
G. McPherson	Sturgis, South Dakota, USA <i>Category: General Interest</i>	
F. Myers	Ft. Worth, Texas, USA <i>Category: General Interest</i>	
G.J. Potter	Heater Technologies, LLC, Marthasville, Missouri, USA <i>Category: Manufacturer</i>	
T. Poulin	A.O. Smith Enterprises Ltd., Fergus, Ontario, Canada	<i>Non-Voting</i>
J.A. Ranfone	American Gas Association Inc., Washington, District of Columbia, USA <i>Category: Gas Supplier</i>	

N.W. Rolph	Lochinvar, LLC, Lebanon, Tennessee, USA	<i>Alternate</i>
I. Sargunam	Bloomington, Indiana, USA <i>Category: General Interest</i>	
C. Souhrada	North American Association of Food Equipment Manufacturers, Chicago, Illinois, USA <i>Category: Manufacturer</i>	
F.A. Stanonik	Air-Conditioning, Heating, and Refrigeration Institute, Arlington, Virginia, USA	<i>Non-Voting</i>
T. Stroud	Hearth Patio & Barbecue Association, Seattle, Washington, USA <i>Category: General Interest</i>	
C. Suchovsky	Burner Technology Unlimited, Inc., Walton Hills, Ohio, USA <i>Category: General Interest</i>	
H. Virgil	Brownsburg, Indiana, USA <i>Category: Consumer/User</i>	
A.B. Sherwin	St. Louis Community College, St. Louis, Missouri, USA <i>Category: Consumer/User</i>	
M.B. Williams	Association of Home Appliance Manufacturers (AHAM), Washington, District of Columbia, USA <i>Category: Manufacturer</i>	
L. Willmore	Southern California Gas Company, Los Angeles, California, USA <i>Category: Gas Supplier</i>	
J. Novkovic	CSA Group, Cleveland, Ohio, USA	<i>Program Manager</i>
S. M. Corcoran	CSA Group, Cleveland, Ohio, USA	<i>Project Manager</i>

Z83/CSA Joint Technical Subcommittee on Gas-Fired Heavy-Duty Forced Air Heaters

T.C. Slaby	Heatco Inc., Cartersville, Georgia, USA	<i>Chair</i>
G.J. Potter	Heater Technologies, LLC, Marthasville, Missouri, USA	<i>Vice-Chair</i>
K. Alphas	Modine Manufacturing Company, Commercial HVAC&R Division, Racine, Wisconsin, USA	
P.A. Baker	Maxitrol Company, Port Dover, Ontario, Canada	<i>Alternate</i>
R. Blasko	Reznor, LLC., Mercer, Pennsylvania, USA	
K.J. Carlisle	Karl Dungs Inc., Blaine, Minnesota, USA	
D.C. Delaquila	Aquila Consulting, LLC, Warren, Ohio, USA	<i>Non-Voting</i>
Z.J. Fraczkowski	Technical Standards & Safety Authority (TSSA), Toronto, Ontario, Canada	<i>Non-Voting</i>
S. Halasa	Beckett Gas Inc., North Ridgeville, Ohio, USA	
K. Ingersoll	AbsolutAire, Inc., Kalamazoo, Michigan, USA	
J.M. Jagers	Mestex, A Division of Mestek, Inc., Dallas, Texas, USA	
R.T. Jauch, Jr.	CES Group, LLC, Oklahoma City, Oklahoma, USA	
J. Kwon	Air-Conditioning, Heating, and Refrigeration Institute, Arlington, Virginia, USA	

P. Lengauer	Reznor, LLC, Mercer, Pennsylvania, USA	<i>Alternate</i>
B. Mickelson	Honeywell International Inc., Golden Valley, Minnesota, USA	
D. Neufeldt	Sure Flame Products, A Division of Haul-All Equipment Ltd., Lethbridge, Alberta, Canada	
D.M. Perry	Maxon - A Honeywell Company, Muncie, Indiana, USA	
V. Quiring	Engineered Air, Division of Airtex Manufacturing Partnership, Calgary, Alberta, Canada	
S. Richter	Roberts Gordon, LLC, Buffalo, New York, USA	
J.J. Schlachter	Maxitrol Company, Southfield, Michigan, USA	
S. Stallings	Applied Air, a Division of Mestex, LTD., Dallas, Texas, USA	
J. Stanley	Karl Dungs Inc., Blaine, Minnesota, USA	<i>Alternate</i>
C. Suchovsky	Burner Technology Unlimited, Inc., Walton Hills, Ohio, USA	
M. Thomas	Natural Resources Canada CanmetENERGY, Ottawa, Ontario, Canada	
S. Wang	Lenuan Heating Appliances Co., Ltd., Foshan, Guangdong, China	<i>Non-Voting</i>
A. Yilmaz	Air-Conditioning, Heating, and Refrigeration Institute, Arlington, Virginia, USA	<i>Alternate</i>
J. Novkovic	CSA Group, Cleveland, Ohio, USA	<i>Program Manager</i>

S. M. Corcoran

CSA Group,
Cleveland, Ohio, USA

Project Manager

Preface

This is the 7th edition of ANSI Z83.18, Recirculation direct gas-fired heating and forced ventilation appliances for commercial and industrial applications. It supersedes the previous editions published in 2015, 2012, 2004, 2000, 1990 and 1987.

This Standard was prepared by the Z83/CSA Joint Technical Sub-Committee on Standards for Gas-Fired Heavy Duty Forced Air Heaters under the jurisdiction of the Technical Committee on Gas Appliances and Related Accessories, the Z21/83 Technical Committee on Performance and Installation of Gas Burning Appliances and Related Accessories, and the Strategic Steering Committee on Standards for Fuel Burning Appliances, and had been formally approved by the Technical Committee(s), American National Standards Institute, and the Interprovincial Gas Advisory Council.

This publication represents a basic standard for safe operation, substantial and durable construction, and acceptable performance of Recirculating direct gas-fired industrial air heaters. It is the result of years of experience in the manufacture, testing, installation, maintenance, inspection, and research on appliances designed for the utilization of gas. There are risks of injury to persons inherent in appliances that, if completely eliminated, would defeat the utility of the appliance. The provisions in this Standard are intended to help reduce such risks while retaining the normal function of the appliance.

Nothing in this Standard is to be considered in any way as indicating a measure of quality beyond compliance with the provisions it contains. It is designed to allow compliance of direct gas-fired process heaters, the safety, construction, and performance of which may exceed the various provisions specified herein. In its preparation, recognition has been given to possibilities of improvement through ingenuity of design. As technical advances take place, revisions may become necessary. When they are believed desirable, recommendations or suggestions should be forwarded to the CSA Group, 8501 East Pleasant Valley Road, Cleveland, Ohio 44131. A proposal form is provided in the back of this document.

Safe and satisfactory operation of a direct gas-fired process heater depends to a great extent upon its proper installation, use, and maintenance. It should be installed in accordance with the *National Fuel Gas Code, ANSI Z223.1/NFPA 54*, manufacturers' installation instructions, and local municipal codes.

Users of this American National Standard are advised that the devices, products, and activities within its scope may be subject to regulation at the Federal, state, or local level. Users are strongly urged to investigate this possibility through appropriate channels. In the event of a conflict with this Standard, the Federal, state, or local regulations should be followed.

THIS STANDARD IS INTENDED TO BE USED BY THE MANUFACTURING SECTOR AND BY THOSE APPLYING THE EQUIPMENT AND BY THOSE RESPONSIBLE FOR ITS PROPER INSTALLATION. IT IS THE RESPONSIBILITY OF THESE USERS TO DETERMINE THAT IN EACH CASE THIS STANDARD IS SUITABLE FOR AND APPLICABLE TO THE SPECIFIC USE THEY INTEND.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc., require that action be taken to reaffirm, revise, or withdraw this Standard no later than five (5) years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, Inc., 25 West 43rd Street, Fourth Floor, New York, N.Y. 10036, (212) 642-4900.

Interpretations: The Strategic Steering Committee on Standards for Fuel Burning Appliances has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA Group’s procedures for interpretation shall be followed to determine the intended safety principle.”

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *This Standard contains SI (Metric) units corresponding to the yard/pound quantities, the purpose being to allow the standard to be used in SI (Metric) units. (IEEE/ASTM SI 10, American National Standard for Metric Practice, or ISO 80000-1:2009, Quantities and units – Part 1: General, is used as a guide in making metric conversion from yard/pound quantities.) If a value for a measurement and a corresponding value in other units are stated, the first stated value is to be regarded as the requirement. The given corresponding value may be approximate. If a value for a measurement and a corresponding value in other units are both specified as a quoted marking requirement, the first stated unit, or both, are to be provided.*
- 3) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 4) *This publication was developed by consensus, which is defined by CSA Policy governing standardization – Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity.” It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.*
- 5) *This Standard is subject to review at least every five years, suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*
- 6) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing Standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca

History of the development of the Standard for Recirculating direct gas-fired heating and forced ventilation appliances for commercial and industrial applications

Note: *This history is informative and is not part of the standard.*

At its March 1983 meeting, the Z83 Subcommittee on Standards for Gas-Fired Heavy Duty Forced Air Heaters considered the need to increase the discharge air temperature limit in the direct gas-fired make-up air heater standard (Z83.4), in light of the increased use of make-up air heaters as total space heating appliances. The heavy duty heater subcommittee appointed a working group of subcommittee members and interested individuals to gather information on the use of direct gas-fired make-up heaters for total space heating.

The working group's report to the subcommittee confirmed there were several local codes permitting the installation of gas-fired make-up air heaters as total space heating appliances in non-residential buildings. Consequently, the working group was requested to develop standards coverage for make-up air heaters installed as total space heating appliances for inclusion in Z83.4.

Although it was initially intended that the necessary coverage would be included in Z83.4, following review of the working group's suggested coverage of its July 1984 meeting, the subcommittee concluded that because of design and function differences (i.e., recirculation of inside air) a separate standard would better suit the needs of certification agencies and Code officials.

A draft standard for industrial air heaters, developed by the working group at a series of meetings, was adopted by the heavy duty heater subcommittee at its June 1985 meeting and distributed for industry review in December 1985. Following reconsideration of this draft standard in light of comments received at its February 1986 meeting, the heavy duty heater subcommittee recommended the draft standard to the Z83 Committee.

At its October 1986 meeting, the Z83 Committee approved the proposed standard for submittal the American National Standards Institute, Inc.

The first edition of the Standard for Direct Gas-Fired Industrial Air Heaters was approved by the American National Standards Institute, Inc., in September 1987. The second edition was approved by the American National Standards Institute, Inc., on November 30, 1990. The third edition was approved by the American National Standards Institute, Inc., on June 22, 2000. The fourth edition of the Standard was approved as American National Standard by the American National Standard Institute, Inc. on December 20, 2004. The fifth edition of the Standard was approved by the American National Standards Institute on December 18, 2012. The sixth edition of the Standard was approved by the American National Standards Institute on January 8, 2015.

This, the seventh edition of the Standard was approved by the American National Standards Institute on June 14, 2016.

Following procedures outlined above, further revisions to this Standard were developed in line with industry developments.

Previous editions of the Standard for recirculating direct gas-fired heating and forced ventilation appliances for commercial and industrial applications, and addenda thereto, approved by the American National Standards Institute, are as follows:

Z83.18-1987	Z83.18a-1989	Z83.18b-1989
Z83.18-1990	Z83.18a-1991	Z83.18b-1992

Z83.18-2000	Z83.18a-2001	Z83.18b-2003
Z83.18-2004	Z83.18a-2005	Z83.18b-2008
Z83.18-2012		
Z83.18-2015		

The following identifies the designation and year of the seventh edition of the Standard:

ANSI Z83.18-2017

Note: *This, the 2017 edition incorporates changes to the 2015 edition of Z83.18. Changes other than editorial are denoted by a delta in the margin.*

ANSI Z83.18-2017

Recirculating direct gas-fired heating and forced ventilation appliances for commercial and industrial applications

1 Scope

Δ 1.1

This Standard applies to newly produced, recirculating direct gas-fired heating and forced ventilation appliances, hereinafter referred to as heaters, whose purpose is to offset building heat loss and provide outside air ventilation to address the ventilation requirements of the building. Ventilation air to the heater is ducted directly from outdoors and the products of combustion generated by the heater are released into the air stream being heated.

Heaters covered by this Standard are intended for use in industrial and commercial applications. This Standard applies to heaters designed for a heated discharge air temperature of 160 °F (71 °C) or less.

This Standard is intended to cover only complete packaged heaters with integral air moving components, i.e., those which are designed by, cataloged by, and built on a repetitive basis by the manufacturer.

1.2

Inside air may be introduced before or after the combustion zone.

1.3

Outside ventilation air is required to the heater. See Clauses [4.21.1-f](#)), [4.21.1-n](#)), and [4.22.2-u](#)).

1.4

If a value for measurement as given in this Standard is followed by an equivalent value in other units, the first stated value is to be regarded as the specification.

1.5

All references to “psi” throughout this Standard are to be considered gage pressure unless otherwise specified.

1.6

Clause [2](#), Reference publications, contains a list of standards specifically referenced in this Standard, and sources from which they may be obtained.

1.7

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that

which is advised but not required; “may” is used to express an option or that which is permissible within the limits of the standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

2 Reference publications

This Standard refers to the following publications, and where such reference is made, it is to the edition listed below.

CSA Group

ANSI Z21.15-2009 (R2014) • CSA 9.1-2009 (R2014), ANSI Z21.15a-2012 (R2014) • CGA 9.1a-2012 (R2014)

Manually Operated Gas Valves for Appliances, Appliance Connector Valves and Hose End Valves

ANSI Z21.18-2007 (R2012) • CSA-6.3-2007 (R2012), Z21.18a-2010 (R2012) • CSA-6.3a-2010 (R2012)
Gas Appliance Pressure Regulators

ANSI Z21.20-2005 (R2016), Z21.20a-2008 (R2016)
Automatic Gas Ignition Systems and Components

ANSI Z21.21-2015 • CSA 6.5-2015
Automatic Valves for Gas Appliances

ANSI Z21.78-2010 (R2015) • CSA 6.20-2010 (R2015)
Combination Gas Controls for Gas Appliances

CSA C22.2 No. 0.15-15
Adhesive Labels

Air Movement and Control Association Inc.

AMCA 203-1990 (R2011)
Field Performance Measurements of Fan Systems

American Gas Association

ANSI Z223.1-2015/NFPA 54-2015
National Fuel Gas Code

American National Standards Institute, Inc.

ANSI Y14.15-1966 (R1988), and Supplements ANSI Y14.15a-1971, ANSI Y14.15b-1973
Electrical and Electronics Diagrams (No Longer Available)