



**CSA
Group**

ANSI Z83.4-2015 • CSA 3.7-2015

Non-recirculating direct gas-fired industrial air heaters

Currently in preview, click buy full versio

Avis juridique concernant les normes

L'Association canadienne de normalisation (qui exerce ses activités sous le nom «Groupe CSA») élabore des normes selon un processus consensuel approuvé par le Conseil canadien des normes. Ce processus rassemble des volontaires représentant différents intérêts et points de vue dans le but d'atteindre un consensus et d'élaborer une norme. Bien que le Groupe CSA assure l'administration de ce processus et détermine les règles qui favorisent l'équité dans la recherche du consensus, il ne met pas à l'essai, ni n'évalue ou vérifie de façon indépendante le contenu de ces normes.

Exclusion de responsabilité

Ce document est fourni sans assertion, garantie ni condition explicite ou implicite de quelque nature que ce soit, y compris, mais non de façon limitative, les garanties ou conditions implicites relatives à la qualité marchande, à l'adaptation à un usage particulier ainsi qu'à l'absence de violation des droits de propriété intellectuelle des tiers. Le Groupe CSA ne fournit aucune garantie relative à l'exactitude, à l'intégralité ou à la pertinence des renseignements contenus dans ce document. En outre, le Groupe CSA ne fait aucune assertion ni ne fournit aucune garantie quant à la conformité de ce document aux lois et aux règlements pertinents.

LE GROUPE CSA, SES VOLONTAIRES, SES MEMBRES, SES FILIALES OU SES SOCIÉTÉS AFFILIÉES DE MÊME QUE LEURS EMPLOYÉS, LEURS DIRIGEANTS ET LEURS ADMINISTRATEURS NE PEUVENT EN AUCUN CAS ÊTRE TENUS RESPONSABLES DE TOUTE BLESSURE, PERTE OU DÉPENSE OU DE TOUT PRÉJUDICE DIRECT, INDIRECT OU ACCESSOIRE, Y COMPRIS, MAIS NON DE FAÇON LIMITATIVE, TOUT PRÉJUDICE SPÉCIAL OU CONSÉCUTIF, TOUTE PERTE DE RECETTES OU DE CLIENTÈLE, TOUTE PERTE D'EXPLOITATION, TOUTE PERTE OU ALTÉRATION DE DONNÉES OU TOUT AUTRE PRÉJUDICE ÉCONOMIQUE OU COMMERCIAL, QU'IL SOIT FONDÉ SUR UN CONTRAT, UN DÉLIT CIVIL (Y COMPRIS LE DÉLIT DE NÉGLIGENCE) OU TOUT AUTRE ÉLÉMENT DE RESPONSABILITÉ TIRANT SON ORIGINE DE QUELQUE FAÇON QUE CE SOIT DE L'UTILISATION DE CE DOCUMENT ET CE, MÊME SI LE GROUPE CSA A ÉTÉ AVISÉ DE L'ÉVENTUALITÉ DE TELS PRÉJUDICES.

En publiant et en offrant ce document, le Groupe CSA n'entend pas fournir des services professionnels ou autres au nom de quelque personne ou entité que ce soit, ni remplir les engagements que de telles personnes ou entités auraient pris auprès de tiers. Les renseignements présentés dans ce document sont destinés aux utilisateurs qui possèdent le niveau d'expérience nécessaire pour utiliser et mettre en application ce contenu. Le Groupe CSA rejette toute responsabilité découlant de quelque façon que ce soit de toute utilisation des renseignements contenus dans ce document ou de toute confiance placée en ceux-ci.

Le Groupe CSA est un organisme privé sans but lucratif qui publie des normes volontaires et des documents connexes. Le Groupe CSA n'entend pas imposer la conformité au contenu des normes et des autres documents qu'elle publie et ne possède pas l'autorité nécessaire pour ce faire.

Propriété et droits de propriété intellectuelle

Tel que convenu entre le Groupe CSA et les utilisateurs de ce document (qu'il soit imprimé ou sur support électronique), le Groupe CSA est propriétaire ou titulaire de permis de toutes les marques de commerce (à moins d'indication contraire) et de tous les documents contenus dans ce document, ces derniers étant protégés par les lois visant les droits d'auteur. Le Groupe CSA est également propriétaire ou titulaire de permis de toutes les inventions et de tous les secrets commerciaux que pourrait contenir ce document, qu'ils soient ou non protégés par des brevets ou des demandes de brevet. Sans que soit limitée la portée générale du paragraphe, l'utilisation, la modification, la copie ou la divulgation non autorisée de ce document pourrait contrevenir aux lois visant la propriété intellectuelle du Groupe CSA ou d'autres parties et donner ainsi droit à l'organisme ou autre partie d'exercer ses recours légaux relativement à une telle utilisation, modification, copie ou divulgation. Dans la mesure prévue par le permis ou la loi, le Groupe CSA conserve tous les droits de propriété intellectuelle relatifs à ce document.

Droits de brevet

Veuillez noter qu'il est possible que certaines parties de cette norme soient visées par des droits de brevet. Le Groupe CSA ne peut être tenue responsable d'identifier tous les droits de brevet. Les utilisateurs de cette norme sont avisés que c'est à eux qu'il incombe de vérifier la validité de ces droits de brevet.

Utilisations autorisées de ce document

Ce document est fourni par le Groupe CSA à des fins informationnelles et non commerciales seulement. L'utilisateur de ce document n'est autorisé qu'à effectuer les actions décrites ci-dessous.

Si le document est présenté sur support électronique, l'utilisateur est autorisé à :

- télécharger ce document sur un ordinateur dans le seul but de le consulter ;
- consulter et parcourir ce document ;
- imprimer ce document si c'est la version PDF.

Un nombre limité d'exemplaires imprimés ou électroniques de ce document peuvent être distribués aux seules personnes autorisées par le Groupe CSA à posséder de tels exemplaires et uniquement si le présent avis juridique figure sur chacun d'eux.

De plus, les utilisateurs ne sont pas autorisés à effectuer, ou à permettre qu'on effectue, les actions suivantes :

- modifier ce document de quelque façon que ce soit ou retirer le présent avis juridique joint à ce document ;
- vendre ce document sans l'autorisation du Groupe CSA ;
- faire une copie électronique de ce document.

Si vous êtes en désaccord avec l'une ou l'autre des dispositions du présent avis juridique, vous n'êtes pas autorisé à télécharger ou à utiliser ce document, ni à en reproduire le contenu, auquel cas vous êtes tenu d'en détruire toutes les copies. En utilisant ce document, vous confirmez que vous acceptez les dispositions du présent avis juridique.



Revision History

ANSI Z83.4-2015 • CSA 3.7-2015, Non-recirculating direct gas-fired industrial air heaters

Revision from previous edition	Revision symbol (in margin)
Clause 5.9.4 Annex A	Δ

Currently in preview, click buy full version

Standards Update Service

ANSI Z83.4-2015 • CSA 3.7-2015 February 2015

Title: *Non-recirculating direct gas-fired industrial air heaters*

To register for e-mail notification about any updates to this publication

- go to shop.csa.ca
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **24233.5**

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

CSA Group

The Canadian Standards Association (operating as "CSA Group"), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group's standards development by volunteering their time and skills to Committee work and supporting CSA Group's objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group's total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group's standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects product that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to

CSA Group
178 Rexdale Boulevard,
Toronto, Ontario,
Canada M9W 1R3

American National Standards Institute

The American National Standards Institute (ANSI), Inc. is the nationally recognized coordinator of voluntary standards development in the United States through which voluntary organizations, representing virtually every technical discipline and every facet of trade and commerce, organized labor and consumer interests, establish and improve the some 10,000 national consensus standards currently approved as American National Standards.

ANSI provides that the interests of the public may have appropriate participation and representation in standardization activity, and cooperates with departments and agencies of U.S. Federal, State and local governments in achieving compatibility between government codes and standards and the voluntary standards of industry and commerce.

ANSI represents the interests of the United States in international nontreaty organizations such as the International Organization for Standardization (ISO) and the International Electrotechnical Commission (IEC). The Institute maintains close ties with regional organizations such as the Pacific Area Standards Congress (PASC) and the Pan American Standards Commission (COPANT). As such, ANSI coordinates the activities involved in the U.S. participation in these groups.

ANSI approval of standards is intended to verify that the principles of openness and due process have been followed in the approval procedure and that a consensus of those directly and materially affected by the standards has been achieved. ANSI coordination is intended to assist the voluntary system to ensure that national standards needs are identified and met with a set of standards that are without conflict or unnecessary duplication in their requirements.

Responsibility of approving American standards rests with the

American National Standards Institute, Inc.
25 West 43rd Street, Fourth floor
New York, NY 10036

ANSI Z83.4-2015 • CSA 3.7-2015
Non-recirculating direct gas-fired
industrial air heaters



American National Standards Institute, Inc.

IGAC

Interprovincial Gas Advisory Council



**CSA
Group**

™A trade-mark of the Canadian Standards Association and CSA America Inc., operating as "CSA Group"

*Approved on January 8, 2015 by ANSI
Approved on February 5, 2015 by IGAC
Effective in Canada September 15, 2016
Published in February 2015 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at shop.csa.ca
or call toll-free 1-800-463-6727 or 416-747-4044.*

ISBN 978-1-77139-727-8

© 2015 CSA Group

*All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Interprovincial Gas Advisory Council	3
Z21/83 Committee on Performance and Installation of Gas Burning Appliances and Related Accessories	5
Technical Committee on Gas Appliances and Related Accessories	8
Joint Z83/CSA Technical Sub-Committee on Standards for Gas-Fired Heavy-Duty Forced Air	17
Preface	14
1 Scope	18
2 Reference publications	19
3 Definitions	22
4 Construction	30
4.1 General construction and assembly	30
4.2 Assembly	31
4.3 Accessibility	32
4.4 Main burners	32
4.5 Combustion air control	33
4.6 Orifices and orifice fittings	33
4.7 Automatic gas ignition systems	33
4.8 Flame safeguards	34
4.9 Valve trains	36
4.10 Manual gas valves	36
4.11 Gas supply lines	37
4.12 Atmospheric vents and gas reliefs or bleeds	40
4.13 Automatic valves and safety shutoff valves	41
4.14 Gas appliance pressure regulators	42
4.15 Discharge air, purge, limit controls, and interlocks	42
4.16 Thickness of materials	44
4.17 Fan motors	45
4.18 Fans	45
4.19 Air filters	49
4.20 Protection of service personnel	49
4.21 Operating and installation instructions	52
4.22 Marking	55
5 Performance	58
5.1 General	58
5.2 Test gases	59
5.3 Test pressure and burner adjustments	60
5.4 Basic test arrangement	61
5.4.1 Test duct — outlet	61

5.4.2	Test duct — inlet	62
5.4.3	Instrumentation	62
5.5	Air throughput measurement	65
5.6	High temperature limit control system	66
5.7	Air flow sensing systems	66
5.8	Operating temperature control system	68
5.9	Combustion	69
5.10	Burner operating characteristics	71
5.11	Piloted ignition systems	72
5.12	Direct ignition systems	73
5.13	Gas appliance pressure regulators	74
5.14	Automatic valves	74
5.15	Burner and heater input rating determination	75
5.16	Manifold and control assembly capacity	75
5.17	Wall, floor (optional), ceiling, electrical equipment and wiring temperatures	76
5.18	Electrical continuity, leakage, and dielectric strength	76
5.19	Heaters for outdoor installation	77
5.20	Rain and wind tests for inlet air openings	80
5.21	Marking material adhesion and legibility	82

6 Items unique to the United States 83

6.1	Electrical equipment and wiring	83
6.2	Construction requirements	94

7 Items unique to Canada 95

7.1	Instructions and markings	95
7.2	Electrical equipment and wiring	95
7.3	French translations for quoted instructions and markings	95

8 Manufacturing and production tests 97

Annex A (normative)	— Emissions protocol	99
Annex B (informative)	— Pertinent references to ANSI Y14.15	112
Annex C (informative)	— Wire color designations	113
Annex D (informative)	— Recommended wire color usage	114
Annex E (informative)	— Preferred graphic symbols of commonly used items, extracted from standard ANSI/IEEE 315, Graphic symbols for electrical and electronics diagrams, and abbreviations for these items	115
Annex F (informative)	— Table of conversion factors	118

Interprovincial Gas Advisory Council

J.R. Marshall	Technical Standards & Safety Authority (TSSA), Toronto, Ontario, Canada	<i>Chair</i>
J. Renaud	Régie du bâtiment du Québec, Montréal, Québec, Canada	<i>First Vice-Chair</i>
M.E. Davidson	Province of New Brunswick Dept of Public Safety, Fredericton, New Brunswick, Canada	<i>Second Vice-Chair</i>
A. Asif	Government of Nunavut Dept of Community & Government Svcs, Regina, Saskatchewan, Canada	
R. Brousseau	Régie du Bâtiment du Québec, Montréal, Québec, Canada	<i>Alternate</i>
P. Christensen	Yukon Government Community Services, Whitehorse, Yukon, Canada	
P. Fowler	Nova Scotia Dept of Labour and Advanced Education, Dartmouth, Nova Scotia, Canada	
Z.J. Fraczkowski	Technical Standards & Safety Authority (TSSA), Toronto, Ontario, Canada	<i>Alternate</i>
D.N. Hird	SaskPower, Regina, Saskatchewan, Canada	
C. Lashek	Manitoba, Office of the Fire Commissioner, Winnipeg, Manitoba, Canada	
W. Lock	British Columbia Safety Authority (BCSA), New Westminster, British Columbia, Canada	
S.C. Manning	Alberta Municipal Affairs Safety Services, Edmonton, Alberta, Canada	
J. McRae	Government of the NWT Public Works & Services, Yellowknife, Northwest Territories, Canada	

B.W. Reid	Department of Environment, Energy and Forestry, Charlottetown, Prince Edward Island, Canada	
G. Slingerland	Standards Council of Canada, Ottawa, Ontario, Canada	<i>Associate</i>
G. Tremblett	Service NL, Newfoundland & Labrador, St. John's, Newfoundland and Labrador, Canada	
C. Valliere	Alberta Municipal Affairs Safety Services, Edmonton, Alberta, Canada	<i>Alternate</i>
M.A. Wani	Government of Nunavut Dept of Community & Government Svcs, Iqaluit, Nunavut, Canada	
B. Zinn	British Columbia Safety Authority (BCSA), Coquitlam, British Columbia	<i>Alternate</i>

Z21/83 Committee on Performance and Installation of Gas Burning Appliances and Related Accessories

B.J. Swiecicki	National Propane Gas Association, Washington, District of Columbia, USA <i>Category: Gas Supplier</i>	<i>Chair</i>
M.W. Wilber	Crane Engineering, Plymouth, Minnesota, USA <i>Category: General Interest</i>	<i>Vice-Chair</i>
C.W. Adams	A.O. Smith Corporation, Milwaukee, Wisconsin, USA <i>Category: Manufacturer</i>	
S.R. Caudle	Southern California Gas Company, Los Angeles, California, USA <i>Category: Gas Supplier</i>	<i>Alternate</i>
M. Deegan	Clearwater Gas System, Clearwater, Florida, USA <i>Category: Government and/or Regulatory Authority</i>	
M. Diesch	Lennox International Inc, Carrollton, Texas, USA <i>Category: Manufacturer</i>	
R. Ehsan	Association of Home Appliance Manufacturers (AHAM), Washington, District of Columbia, USA <i>Category: Manufacturer</i>	<i>Alternate</i>
J.M. Emmel	Virginia Tech, Blacksburg, Virginia, USA <i>Category: Consumer/User</i>	
Z.J. Fraczkowski	Technical Standards & Safety Authority (TSSA), Toronto, Ontario, Canada	<i>Associate</i>
R.R. Frazier	ATMOS Energy, Arlington, Texas, USA <i>Category: Gas Supplier</i>	

M. Garcia	Sempra Energy Utility, Los Angeles, California, USA <i>Category: Gas Supplier</i>	
T.F. Hardin	Underwriters Laboratories Inc., Research Triangle Pk, North Carolina, USA <i>Category: Research/Testing</i>	<i>Alternate</i>
D.M. Jakobs	Rheem Manufacturing Company Air Conditioning Division, Fort Smith, Arkansas, USA <i>Category: Manufacturer</i>	
R.A. Jordan	Consumer Product Safety Commission, Rockville, Maryland, USA	<i>Associate</i>
A. Kovalenko	Heat Transfer Products Inc., East Freetown, Massachusetts, USA	<i>Associate</i>
A. Lanier Papageorge	AGL Resources Inc., Atlanta, Georgia, USA <i>Category: Gas Supplier</i>	
F. Myers	PVI Industries LLC, Fort Worth, Texas, USA <i>Category: Manufacturer</i>	
D. Parker	Western Industries, Inc. Engineered Products Group, Watertown, Wisconsin, USA	<i>Associate</i>
G.J. Potter	Heater Technologies, LLC, Marthasville, Missouri, USA <i>Category: Manufacturer</i>	
J.A. Ranfone	American Gas Association Inc., Washington, District of Columbia, USA <i>Category: Gas Supplier</i>	
N.W. Rolph	Lochinvar LLC, Lebanon, Tennessee, USA <i>Category: Manufacturer</i>	<i>Alternate</i>
G.A. Ruzicka	Lowe's Companies, Inc., Mooresville, North Carolina, USA <i>Category: General Interest</i>	

I. Sargunam	Bloomington, Indiana, USA <i>Category: General Interest</i>	
A.B. Sherwin	St. Louis Community College, St. Louis, Missouri, USA <i>Category: Consumer/User</i>	
C. Souhrada	North American Association of Food Equipment Manufacturers, Chicago, Illinois, USA <i>Category: Manufacturer</i>	
F.A. Stanonik	Air-Conditioning, Heating, and Refrigeration Institute, Arlington, Virginia, USA	<i>Associate</i>
T. Stroud	Hearth Patio & Barbecue Association, Seattle, Washington, USA <i>Category: General Interest</i>	
C. Suchovsky	Burner Technology Unlimited, Inc, Walton Hills, Ohio, USA <i>Category: General Interest</i>	
H. Virgil	Brownsburg, Indiana, USA <i>Category: Consumer/User</i>	
M.B. Williams	Association of Home Appliance Manufacturers (AHAM), Washington, District of Columbia, USA <i>Category: Manufacturer</i>	
R. Wozniak	Underwriters Laboratories Inc., Melville, New York, USA <i>Category: Research/Testing</i>	
C.L. Rake	CSA Group, Cleveland, Ohio, USA	<i>Program Manager</i>
S.M. Corcoran	CSA Group, Cleveland, Ohio, USA	<i>Project Manager</i>

Technical Committee on Gas Appliances and Related Accessories

T.W. Poulin	A.O. Smith Enterprises Ltd., Fergus, Ontario <i>Category: Producer Interest</i>	<i>Chair</i>
A. Gould	Reliance Comfort Ltd. Partnership dba Reliance Home Comfort, Cambridge, Ontario, Canada <i>Category: User Interest</i>	<i>First Vice-Chair</i>
D.N. Hird	SaskPower, Regina, Saskatchewan, Canada <i>Category: Government and/or Regulatory Authority</i>	<i>Second Vice-Chair</i>
A. Abdel-Rehim	A.O. Smith Enterprises Ltd., Fergus, Ontario, Canada	<i>Associate</i>
J.K. Angus	J.M.A. Associates Representing EnerCare Solutions, Midland, Ontario, Canada <i>Category: General Interest</i>	
P.A. Baker	Maxitrol Company, Port Dover, Ontario, Canada <i>Category: Producer Interest</i>	
D. Baxter	Enbridge Gas Distribution, Thorold, Ontario, Canada <i>Category: User Interest</i>	
J. Boros	Rheem Sales Co Inc AKA Rheem Manufacturing Co, Montgomery, Alabama, USA <i>Category: Producer Interest</i>	
T. Brennan	Natural Resources Canada, Ottawa, Ontario, Canada	<i>Associate</i>
C. Côté	Gaz Métro, Montréal, Québec, Canada <i>Category: User Interest</i>	

Z.J. Fraczkowski	Technical Standards & Safety Authority (TSSA), Toronto, Ontario, Canada <i>Category: Government and/or Regulatory Authority</i>	
C. Gibbs	Guelph, Ontario, Canada <i>Category: General Interest</i>	
D.R. Jamieson	GHP Group Inc., Oakville, Ontario, Canada <i>Category: Producer Interest</i>	
C.E. Jorgenson	British Columbia Safety Authority (BCSA), New Westminster, British Columbia, Canada <i>Category: Government and/or Regulatory Authority</i>	
S. Katz	S. Katz and Associates Inc., North Vancouver, British Columbia, Canada	<i>Associate</i>
J.R. Marshall	Technical Standards & Safety Authority (TSSA), Toronto, Ontario, Canada	<i>Associate</i>
J. Melling	SaskPower, Saskatoon, Saskatchewan, Canada	<i>Associate</i>
J. Overall	Toronto, Ontario, Canada	<i>Associate</i>
G.B. Prociw	Union Gas Limited, Chatham, Ontario, Canada <i>Category: User Interest</i>	
B.J. Swiecicki	National Propane Gas Association, Washington, District of Columbia, USA	<i>Associate</i>
M. Thomas	Natural Resources Canada CanmetENERGY, Ottawa, Ontario, Canada	<i>Associate</i>
M. Travers	Reliance Comfort L.P., Cambridge, Ontario, Canada	<i>Associate</i>
P. Verhas	Dettson Industries, Inc., Sherbrooke, Québec, Canada	<i>Associate</i>
C.L. Rake	CSA Group, Cleveland, Ohio, USA	<i>Program Manager</i>

J. Vulovic

CSA Group,
Etobicoke, Ontario, Canada

Project Manager

Joint Z83/CSA Technical Sub-Committee on Standards for Gas-Fired Heavy-Duty Forced Air

T.C. Slaby	Heatco Inc., Cartersville, Georgia, USA	<i>Chair</i>
G.J. Potter	Heater Technologies, LLC, Marthasville, Missouri, USA	<i>Vice-Chair</i>
K. Alphs	Modine Manufacturing Company Commercial HVAC&R Division, Racine, Wisconsin, USA	
P.A. Baker	Maxitrol Company, Port Dover, Ontario, Canada	<i>Alternate</i>
R. Blasko	Reznor, LLC, Mercer, Pennsylvania, USA	
K.J. Carlisle	Karl Dungs Inc., Blaine, Minnesota, USA	
D.C. Delaquila	Aquila Consulting, LLC, Warren, Ohio, USA	<i>Associate</i>
Z.J. Fraczkowski	Technical Standards & Safety Authority (TSSA), Toronto, Ontario, Canada	<i>Associate</i>
A.C. Hayden	CanmetENERGY-Ottawa, Ottawa, Ontario, Canada	<i>Alternate</i>
J.M. Jagers	Mestex, A Division of Mestek, Inc., Dallas, Texas, USA	
R.T. Jauch, Jr.	CES Group, LLC, Oklahoma City, Oklahoma, USA	
P. Lengauer	Reznor, LLC, Mercer, Pennsylvania, USA	<i>Alternate</i>

B. Mickelson	Honeywell International Inc., Golden Valley, Minnesota, USA	
D. Neufeldt	Sure Flame Products, A Div. of Haul-All Equipment Ltd., Lethbridge, Alberta	
D.M. Perry	Maxon - A Honeywell Company, Muncie, Indiana, USA	
V. Quiring	Engineered Air, Division of Airtex Manufacturing Partnership, Calgary, Alberta	
S. Richter	Roberts Gordon LLC, Buffalo, New York, USA	
J.J. Schlachter	Maxitrol Company, Southfield, Michigan, USA	
J. Stanley	Karl Dungs Inc., Blaine, Minnesota, USA	<i>Alternate</i>
F.A. Stanonik	Air-Conditioning, Heating, and Refrigeration Institute, Arlington, Virginia, USA	<i>Alternate</i>
C. Suchovsky	Burner Technology Unlimited, Inc., Walton Hills, Ohio, USA	
R. Thayer	AbsolutAire, Inc., Kalamazoo, Michigan, USA	
M. Thomas	Natural Resources Canada CanmetENERGY, Ottawa, Ontario, Canada	
R. Wozniak	Underwriters Laboratories Inc., Melville, New York, USA	
D.M. Wynnck	Lennox Industries Inc., Carrollton, Texas, USA	
A. Yilmaz	Air-Conditioning, Heating, and Refrigeration Institute, Arlington, Virginia, USA	

C.L. Rake

CSA Group,
Cleveland, Ohio, USA

Program Manager

S.M. Corcoran

CSA Group,
Cleveland, Ohio, USA

Project Manager

Preface

This is the fourth edition of ANSI Z83.4 • CSA 3.7, Standard for Non-recirculating direct gas-fired industrial air heaters. It supersedes the previous editions published in 2013, 2003 and 1999.

This Standard was prepared by the Z83/CSA Joint Technical Sub-Committee on Standards for Gas-Fired Heavy-Duty Forced Air Heaters under the jurisdiction of the Technical Committee on Gas Appliances and Related Accessories, the Z21/83 Technical Committee on Performance and Installation of Gas Burning Appliances and Related Accessories, and the Strategic Steering Committee on Standards for Fuel Burning Appliances, and had been formally approved by the Technical Committee(s), American National Standards Institute, and the Interprovincial Gas Advisory Council.

This publication represents a basic standard for safe operation, substantial and durable construction, and acceptable performance of non-recirculating direct gas-fired industrial heaters. It is the result of years of experience in the manufacture, testing, installation, maintenance, inspection, and research on appliances designed for the utilization of gas. There are risks of injury to persons inherent in appliances that, if completely eliminated, would defeat the utility of the appliance. The provisions in this Standard are intended to help reduce such risks while retaining the normal function of the appliance.

Nothing in this Standard is to be considered in any way as indicating a measure of quality beyond compliance with the provisions it contains. It is designed to allow compliance of non-recirculating direct gas-fired industrial air heaters, the safety, construction, and performance of which may exceed the various provisions specified herein. In its preparation, recognition has been given to possibilities of improvement through ingenuity of design. As technical advances take place, revisions may become necessary. When they are believed desirable, recommendations or suggestions should be forwarded to the CSA America, 8501 East Pleasant Valley Road, Cleveland, Ohio 44131. A proposal form is provided in the back of this document.

Safe and satisfactory operation of a non-recirculating direct gas-fired industrial air heater depends to a great extent upon its proper installation, use, and maintenance. It should be installed in accordance with the *National Fuel Gas Code, ANSI Z223.1/NFPA 54*, manufacturers' installation instructions, and local municipal codes.

Users of this American National Standard are advised that the devices, products, and activities within its scope may be subject to regulation at the Federal, state, or local level. Users are strongly urged to investigate this possibility through appropriate channels. In the event of a conflict with this Standard, the Federal, state, or local regulations should be followed.

THIS STANDARD IS INTENDED TO BE USED BY THE MANUFACTURING SECTOR AND BY THOSE APPLYING THE EQUIPMENT AND BY THOSE RESPONSIBLE FOR ITS PROPER INSTALLATION. IT IS THE RESPONSIBILITY OF THESE USERS TO DETERMINE THAT IN EACH CASE THIS STANDARD IS SUITABLE FOR AND APPLICABLE TO THE SPECIFIC USE THEY INTEND.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc., require that action be taken to reaffirm, revise, or withdraw this Standard no later than five (5) years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, Inc., 25 West 43rd Street, Fourth Floor, New York, N.Y. 10036, (212) 642-4900.

EFFECTIVE DATE: An organization using this Standard for product evaluation as a part of its certification program will normally establish the date by which all products certified by that organization should comply with this Standard.

Interpretations: The Strategic Steering Committee on Standards for Fuel Burning Appliances has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA Group’s procedures for interpretation shall be followed to determine the intended safety principle.”

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *This Standard contains SI (Metric) units corresponding to the yard/pound quantities, the purpose being to allow the standard to be used in SI (Metric) units. (IEEE/ASTM SI 10, American National Standard for Metric Practice, or ISO 80000-1:2009, Quantities and units – Part 1: General, is used as a guide in making metric conversion from yard/pound quantities.) If a value for a measurement and a corresponding value in other units are stated, the first stated value is to be regarded as the requirement. The given corresponding value may be approximate. If a value for a measurement and a corresponding value in other units are both specified as a quoted marking requirement, the first stated unit, or both, are to be provided.*
- 3) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 4) *This publication was developed by consensus, which is defined by CSA Policy governing standardization – Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity.” It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.*
- 5) *This Standard is subject to review five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*
- 6) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

History of development of the Standard for Non-Recirculating Direct Gas-Fired Industrial Air Heaters

Note: *This History is informative and is not part of the Standard.*

With the onset of the Free Trade Agreement between the United States and Canada on January 2, 1988, significant attention was given to the harmonization of the United States and Canadian safety standards addressing gas-fired equipment for residential, commercial, and industrial applications. It was believed that the elimination of the differences between the standards would remove potential trade barriers and provide an atmosphere in which North American manufacturers could market more freely in the United States and Canada. The harmonization of these standards was also seen as a step toward harmonization with international standards. Joint subcommittees were established to facilitate the standards harmonization process between the United States and Canada.

At its July 14-16, 1992 meeting, the Z21/CGA Joint Subcommittee on Standards for Gas-Fired, Heavy-Duty Forced Air Heaters group agreed to prepare a draft bi-national standard for Direct Gas-Fired Industrial Air Heaters. During its November 7-8, 1996 meeting, the joint subcommittee agreed to send the draft standard for public review and comment.

The first draft harmonized standard was based on current coverage from the American National Standards/Canadian Gas Association Standards for Direct Gas-Fired Non-recirculating Make-up Air Heaters, ANSI Z83.4, Direct Gas-Fired Make-up Air Heaters, CGA-3.7, the Direct Gas Fired Door Air Heaters, Z83.17 and CGA-3.12, and Direct Gas Fired Industrial Air Heaters, Z83.18.

Following reconsideration and modification of the proposed draft standard, in light of comments received, the joint heavy duty heaters subcommittee at its July 22-24, 1997 meeting, recommended the proposed draft standard to Accredited Standards Committee Z21/83 and the (Interim CSA) Standards Steering Committee for approval.

The proposed draft of the harmonized Standard for Non-Recirculating Direct Gas-Fired Industrial Air Heaters, as modified by the joint subcommittee, was approved by the Z21/83 Committee by letter ballot dated August 10, 1998 and by the CGA Standards Steering Committee by letter ballot dated October 6, 1997.

The first edition of the American National Standard/CSA Standard for Non-Recirculating Direct Gas-Fired Industrial Air Heaters was approved by the Canadian Interprovincial Gas Advisory Council on July 7, 1999, and by the American National Standards Institute, Inc., on November 9, 1999.

Following the procedures outlined above, further revisions to this Standard, Z83.4 CSA 3.7, were made in line with industry developments. The second edition of the American National Standard/CSA Standard for Non-Recirculating Direct Gas-Fired Industrial Air Heaters was approved by the Interprovincial Gas Advisory Council on September 11, 2003, and by the American National Standards Institute, Inc., on November 26, 2003.

The third edition of the American National Standard/CSA Standard for Non-Recirculating Direct Gas-Fired Industrial Air Heaters was approved by the Interprovincial Gas Advisory Council on February 25, 2013, and the American National Standards Institute, Inc., on December 19, 2012.

This, the fourth edition of the American National Standard/CSA Standard for Non-Recirculating Direct Gas-Fired Industrial Air Heaters, was approved by the Interprovincial Gas Advisory Council on February 5, 2015, and the American National Standards Institute, Inc., on January 8, 2015.

Previous editions of the harmonized Non-Recirculating Direct Gas-Fired Industrial Air Heaters, and addenda thereto, approved by the Interprovincial Gas Advisory Council and the American National Standards Institute are as follows:

Z83.4-1999 • CSA 3.7-1999
Z83.4a-2001 • CSA 3.7a-2001
Z83.4b-2002 • CSA 3.7b-2002
Z83.4-2013 • CSA 3.7-2013

Z83.4-2003 • CSA 3.7-2003
Z83.4a-2004 • CSA 3.7a-2004
Z83.4b-2006 • CSA 3.7b-2006

The following identifies the designation and year of the fourth edition of the Standard:

ANSI Z83.4-2015 CSA 3.7-2015

Note: *This, the 2015 edition of Z83.4 • CSA 3.7, incorporates changes to the 2013 edition. Changes, other than editorial, are denoted by a vertical line in the margin.*

ANSI Z83.4-2015 • CSA 3.7-2015

Non-recirculating direct gas-fired industrial air heaters

1 Scope

1.1

This Standard applies to newly produced, direct gas-fired industrial air heaters of the non-recirculating type, hereinafter referred to as heaters, whose purpose is to offset building heat loss. All air to the heater is ducted directly from outdoors and the products of combustion generated by the heater are released into the air stream being heated.

Heaters covered by this Standard are intended for use in industrial and commercial applications. Heaters covered by this Standard are not intended for use in any area containing sleeping quarters. The installation conforms with local codes, or in the absence of local codes, in accordance with the *National Fuel Gas Code*, ANSI Z223.1/NFPA 54, or the *Natural Gas and Propane Installation Code*, CSA B149.1.

1.2

This Standard applies to heaters designed for heated discharge air temperature of 160 °F (71 °C) or less.

1.3

This Standard is intended to cover only complete packaged heaters with integral air moving components, i.e., those which are designed by, cataloged by, and built on a repetitive basis by the manufacturer.

1.4

If a value for measurement as given in this Standard is followed by an equivalent value in other units, the first stated value is to be regarded as the specification.

1.5

Items unique to the U.S.A. are shown in Clause 6.

1.6

Items unique to Canada are shown in Clause 7.

1.7

Clause 2, Reference publications, contains a list of standards specifically referenced in this Standard, and sources from which these referenced standards may be obtained.

1.8

All references to “psi” through this Standard are to be considered gage pressure unless otherwise specified.

1.9

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user shall satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

2 Reference publications

This Standard refers to the following publications, and where such reference is made, it is to the edition listed below.

CSA Group

CSA C22.1-12

Canadian Electrical Code, Part I

CSA C22.2 No. 3-1988 (R2004)

Electrical Features of Fuel-Burning Equipment

CSA C22.2 No. 77-95 (R2013)

Motors with Inherent Overheating Protection

CSA C22.2 No. 199-M89 (R2004) (withdrawn)

Combustion Safety Controls and Solid-State Igniters for Gas- and Oil-Burning Equipment

CAN/CSA Z234.1-00 (withdrawn)

Canadian Metric Practice Guide

CGA 2.17-M91 (R2014)

Gas-Fired Appliances for Use at High Altitudes

CGA 3.11-M88 (R2009)

Lever Operated Pressure Lubricated Plug Type Gas Shut-Off Valves

CGA 3.16-M88 (R2009)

Lever Operated Non-Lubricated Gas Shut-Off Valves

CSA 6.4-M79 (R2011)

Automatic Gas Ignition Systems and Components

CSA B149.1-10

Natural Gas and Propane Installation Code