



**CSA B415.1:22**  
National Standard of Canada



# Performance testing of solid-biofuel-burning heating appliances



scc  ccn

# Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

## Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

## Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

## Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

## Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



# *Revision History*

CSA B415.1:22, Performance testing of solid-biofuel-burning heating appliances

Errata — February 2022	Revision symbol (in margin)
<a href="#">Preface</a>	Δ

Currently in preview, click buy full version

# ***Standards Update Service***

## ***CSA B415.1:22 January 2022***

**Title:** *Performance testing of solid-biofuel-burning heating appliances*

To register for e-mail notification about any updates to this publication

- go to [www.csagroup.org/store/](http://www.csagroup.org/store/)
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **24297.7**

If you require assistance, please e-mail [techsupport@csagroup.org](mailto:techsupport@csagroup.org) or call 416-747-2233.

Visit CSA Group's policy on privacy at [www.csagroup.org/legal](http://www.csagroup.org/legal) to find out how we protect your personal information.

**Canadian Standards Association (operating as “CSA Group”)**, under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

More than 10 000 members indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in fourteen countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to  
CSA Group  
178 Rexdale Boulevard  
Toronto, Ontario, M9W 1R3  
Canada

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at [www.scc.ca](http://www.scc.ca).

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada’s economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at [www.scc.ca](http://www.scc.ca).

Standards Council of Canada  
600-55 Metcalfe Street  
Ottawa, Ontario, K1P 6L5  
Canada



La norme nationale du Canada n'est disponible qu'en anglais.

*Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.*

*\*A trademark of the Canadian Standards Association, operating as “CSA Group”*

*National Standard of Canada*

*CSA B415.1:22*

***Performance testing of solid-biofuel-  
burning heating appliances***



®A trademark of the Canadian Standards Association,  
operating as "CSA Group."



Published in January 2022 by CSA Group  
A not-for-profit private sector organization  
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3

To purchase standards and related publications, visit our Online Store at [www.csagroup.org/store/](http://www.csagroup.org/store/)  
or call toll-free 1-800-463-6727 or 416-747-4044.

ICS 91.140.65  
ISBN 978-1-4883-4053-6

© 2022 Canadian Standards Association  
All rights reserved. No part of this publication may be reproduced in any form whatsoever  
without the prior permission of the publisher.

# Contents

Technical Committee on Energy Efficiency and Related Performance of Fuel-Burning Appliances and Equipment 4

Subcommittee on Performance Testing of Solid-Fuel-Burning Appliances 7

Preface 9

## 1 Scope 11

- 1.1 Product range 11
- 1.2 Reporting metrics 11
- 1.3 Product types 11
- 1.4 Fuels 11
- 1.5 Products not covered 11
- 1.6 Emissions limits 12
- 1.7 Units of measurement 12
- 1.8 Terminology 12

## 2 Reference publications 12

## 3 Definitions 15

## 4 Requirements 20

- 4.1 General 20
  - 4.1.1 Particulate matter reporting for Type 2, 3, 4, and 5 appliances 20
  - 4.1.2 Manufacturer's instructions 20
  - 4.1.3 Third-party certification 20
  - 4.1.4 Carbon monoxide (CO) emissions 20
  - 4.1.5 Specific requirement for catalytic combustor 20
- 4.2 Type 1 — Site-built appliances (burn-in-place) 21
  - 4.2.1 General 21
  - 4.2.2 Construction and installation 21
  - 4.2.3 Gaseous emissions 21
  - 4.2.4 Particulate emissions 21
  - 4.2.5 Thermal performance 21
- 4.3 Type 2 — Room heaters 21
  - 4.3.1 Construction and installation 21
  - 4.3.2 Gaseous emissions 21
  - 4.3.3 Particulate emissions 21
  - 4.3.4 Thermal performance 22
- 4.4 Type 3 — Forced-air furnaces 22
  - 4.4.1 Construction and installation 22
  - 4.4.2 Gaseous emissions 22
  - 4.4.3 Particulate emissions 22
  - 4.4.4 Thermal performance 22
- 4.5 Type 4 — Hydronic heating appliances 22
  - 4.5.1 Construction and installation 22
  - 4.5.2 Gaseous emissions 22

4.5.3	Particulate emissions	23
4.5.4	Thermal performance	23
4.6	Type 5 — Hybrid heating appliances	24
4.6.1	Construction and installation	24
4.6.2	Gaseous emissions	24
4.6.3	Particulate emissions	24
4.6.4	Thermal performance	24
<b>5</b>	<b>Marking and instructions</b>	<b>24</b>
5.1	General	24
5.2	Type 1 — Site-built appliances (built-in-place)	25
5.2.1	Markings	25
5.2.2	Instructions	25
5.3	Type 2 — Room heaters	25
5.3.1	Markings and labelling	25
5.3.2	Instructions	25
5.4	Type 3 — Forced-air furnaces	25
5.4.1	Markings and labelling	25
5.4.2	Instructions	25
5.5	Type 4 — Hydronic heating appliances	26
5.5.1	Markings and labelling	26
5.5.2	Instructions	26
5.6	Type 5 — Hybrid heating appliances	26
5.6.1	Markings and labelling	26
5.6.2	Instructions	26
<b>6</b>	<b>Inspection and methods of test</b>	<b>27</b>
6.1	General	27
6.1.1	Test room conditions and preparation for Type 2, 3, 4, and 5 appliances	27
6.1.2	Ambient air temperature for Type 2, 3, 4, and 5 appliances	27
6.1.3	Flue gas analysis for Type 2, 3, 4, and 5 appliances	27
6.1.4	Determination of calorific value for Type 1 to Type 5 appliances	28
6.1.5	Electrical power production and consumption for Type 1 to Type 5 appliances	28
6.1.6	Calibration for Type 1 to Type 5 appliances	30
6.1.7	Particulate sampling for Type 2, 3, 4, and 5 appliances	31
6.1.8	Data collection and recording for Type 2, 3, 4, and 5 appliances	31
6.1.9	Pressure and humidity for Type 1 to Type 5 appliances	32
6.1.10	Efficiency and carbon monoxide for Type 1 to Type 5 appliances	32
6.1.11	Particulate emission rate, total particulate emissions, and particulate emission factor	39
6.1.12	Manufacturer's instructions	40
6.2	Type 1 — Site-built appliances (built-in-place)	40
6.2.1	Test apparatus	40
6.2.2	Gaseous emissions and measurements	42
6.2.3	Particulate emissions test	42
6.2.4	Thermal efficiency test	42
6.3	Type 2 — Room heaters	43
6.3.1	Installation of apparatus for testing room heaters	43
6.3.2	Gaseous emissions and measurements	43
6.3.3	Particulate measurements	43

6.3.4	Thermal efficiency	44
6.4	Type 3 — Forced-air furnace	44
6.4.1	Installation instructions	44
6.4.2	Forced-air furnace output rates	48
6.4.3	Manually or automatically fuelled cordwood forced-air furnace — Specific requirements	50
6.4.4	Automatically fuelled forced-air furnace — Specific requirements	55
6.5	Type 4 — Hydronic heating appliances	68
6.5.1	General requirements	68
6.5.2	Installation instructions	69
6.5.3	Gaseous emissions	69
6.5.4	Particle measurements	69
6.6	Type 5 — Hybrid heating appliances	69
6.6.1	Test apparatus	69
6.6.2	Gaseous emissions test	70
6.6.3	Particulate emissions test	70
6.6.4	Thermal efficiency test	71

---

Annex A (informative) — Spreadsheet for calculating the energy efficiency and total heat output of solid-biofuel-burning heating appliances 72

Annex B (informative) — Automatically fuelled appliances that burn fuels larger than wood pellet size 73

Annex C (informative) — Recognition of CEN EN 303-5:2021 third-party certified automatic appliances in CSA B415.1 74

# ***Technical Committee on Energy Efficiency and Related Performance of Fuel-Burning Appliances and Equipment***

<b>D. M. Jakobs</b>	Rheem Manufacturing Company, Fort Smith, Arkansas, USA <i>Category: Producer Interest</i>	<i>Chair</i>
<b>P. Koepfgen</b>	FortisBC, Surrey, British Columbia, Canada <i>Category: User Interest</i>	<i>Vice Chair</i>
<b>M. Thomas</b>	Natural Resources Canada, CanmetENERGY, Ottawa, Ontario, Canada <i>Category: General Interest</i>	<i>Vice Chair</i>
<b>E. Adair</b>	Hearth, Patio & Barbecue Association, Dixon, California, USA <i>Category: General Interest</i>	
<b>S. Davison</b>	Ecolibrium Global Technologies Ltd., Calgary, Alberta, Canada	<i>Non-voting</i>
<b>C. Gherghel</b>	Wolf Steel Ltd., Barrie, Ontario, Canada	<i>Non-voting</i>
<b>A. Gould</b>	Reliance Comfort LP, Cambridge, Ontario, Canada	<i>Non-voting</i>
<b>P. Hikspoors</b>	Plant Factories Inc., Montréal, Québec, Canada <i>Category: Producer Interest</i>	
<b>A. Howse</b>	Ontario Ministry of Energy, Northern Development and Mines, Toronto, Ontario, Canada	<i>Non-voting</i>
<b>P. Kirchner</b>	A.O. Smith Enterprises Ltd., Fergus, Ontario, Canada	<i>Non-voting</i>

<b>S. Krsikapa</b>	Ontario Ministry of Energy, Northern Development and Mines, Toronto, Ontario, Canada <i>Category: Regulatory Authority</i>	
<b>M. J. Miles</b>	Miles Industries Ltd., North Vancouver, British Columbia, Canada <i>Category: Producer Interest</i>	
<b>A. Morrison</b>	Caneta Research Inc./Caneta Energy, Mississauga, Ontario, Canada <i>Category: General Interest</i>	
<b>I. Picard</b>	Natural Gas Technologies Centre (NGTC), Boucherville, Québec, Canada	<i>Non-voting</i>
<b>F. Rad</b>	Enbridge Gas Inc., Toronto, Ontario, Canada <i>Category: User Interest</i>	
<b>J. Richer</b>	Selkirk Canada Corporation, Stoney Creek, Ontario, Canada <i>Category: General Interest</i>	
<b>T. Saatcioglu</b>	Natural Resources Canada, Ottawa, Ontario, Canada <i>Category: Regulatory Authority</i>	
<b>B. S. Sadri</b>	Enbridge Gas Inc., North York, Ontario, Canada	<i>Non-voting</i>
<b>C. Shook</b>	British Columbia Ministry of Energy, Mines and Low Carbon Innovation, Victoria, British Columbia, Canada <i>Category: Regulatory Authority</i>	
<b>R. Storey</b>	Delaur Ltd., Oakville, Ontario, Canada	<i>Non-voting</i>
<b>G. Thibodeau-Fortin</b>	SBI, Saint-Augustin-de-Desmaures, Québec, Canada	<i>Non-voting</i>
<b>M. Travers</b>	Reliance Comfort LP, Cambridge, Ontario, Canada <i>Category: User Interest</i>	

<b>P. Verhas</b>	Dettson Industries, Inc., Sherbrooke, Québec, Canada <i>Category: Producer Interest</i>	
<b>T. J. Whitehead</b>	Enbridge Gas Distribution, Toronto, Ontario, Canada <i>Category: User Interest</i>	
<b>A. Jami</b>	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

# ***Subcommittee on Performance Testing of Solid-Fuel-Burning Appliances***

<b>M. A. Cantin</b>	SBI, Saint-Augustin-de-Desmaures, Québec, Canada	<i>Chair</i>
<b>E. Adair</b>	Hearth, Patio & Barbecue Association, Dixon, California, USA	
<b>S. Davison</b>	Ecolibrium Global Technologies Ltd., Calgary, Alberta, Canada	
<b>H. Dresser</b>	Wood Pellet Association of Canada, Bethel, Maine, USA	
<b>D. Dubois</b>	Fink Machine Inc., Cache Creek, British Columbia, Canada	
<b>M. Evans</b>	CSA Group, Toronto, Ontario, Canada	
<b>R. W. Ferguson</b>	Ferguson Consulting LLC, South Royalton, Vermont, USA	
<b>L. Gilbert</b>	Industrial Chimney Company (ICC) Inc., Saint-Jérôme, Québec, Canada	
<b>D. H. Haynes</b>	HY-C Company, St. Louis, Missouri, USA	
<b>M. Langille</b>	NB Lung Association, Fredericton, New Brunswick, Canada	
<b>S. Law</b>	Ontario Ministry of the Environment, Conservation and Parks, Toronto, Ontario, Canada	
<b>S. Madrali</b>	Natural Resources Canada, CanmetENERGY, Ottawa, Ontario, Canada	
<b>C. R. Pemberton-Pigott</b>	New Dawn Engineering (Pty) Ltd., Waterloo, Ontario, Canada	

<b>G. Piedalue</b>	POLYTESTS Services Inc., Saint-Jean-sur-Richelieu, Québec, Canada	
<b>T. Sauvé</b>	Ontario Ministry of Agriculture, Food and Rural Affairs (OMAFRA), Alfred, Ontario, Canada	
<b>N. Senf</b>	Masonry Heater Association of North America (MHA), Shawville, Québec, Canada	
<b>G. Thibodeau-Fortin</b>	SBI, Saint-Augustin-de-Desmaures, Québec, Canada	
<b>A. Jami</b>	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

## Δ Preface

This is the fourth edition of CSA B415.1, *Performance testing of solid-biofuel-burning heating appliances*. It supersedes the previous editions, published in 2010 and 2000 under the title *Performance testing of solid-fuel-burning heating appliances*, and published in 1992 under the title *Performance Testing of Solid-Fuel-Burning Stoves, Inserts, and Low-Burn-Rate Factory-Built Appliances*.

This Standard can be used as a stand-alone document that can be referenced by the appropriate authority having jurisdiction (AHJ).

The major changes from the previous edition are as follows:

- a) this Standard has been restructured to comply with current CSA Group requirements;
- b) the general layout has been restructured to make this Standard easier to follow for each type of product covered;
- c) the types of products covered by this Standard have been clarified and expanded;
- d) site-built heating appliances and hybrid heaters have been added as new product types covered by this Standard;
- e) definitions have been added for hybrid hydronic heaters and hybrid forced-air heaters;
- f) certain definitions have been clarified and updated (e.g., factory-built fireplace, masonry heater, room heater);
- g) reference publications have been updated to the latest editions;
- h) informative Annex B, pertaining to the total combustible carbon method for determination of energy efficiency, has been deleted;
- i) for many types of appliances, content has been replaced with a referenced standard (e.g., ASTM E2515, ASTM E3053), allowing for less text duplication, better harmonization with the United States Environmental Protection Agency (U.S. EPA), and improved alignment with other International or Regional Standards;
- j) this Standard now includes references to and uses definitions from the CSA ISO 17225 series of Standards on graded solid biofuels;
- k) emission requirements have been added for hybrid hydronic heaters and hybrid forced-air heaters;
- l) emission limits for room heaters have been lowered and harmonized with the U.S. EPA;
- m) emission limits for forced-air furnaces and hydronic heaters have been lowered and harmonized with the U.S. EPA, with compliance deadlines of January 1, 2025, and January 1, 2024, respectively;
- n) an emission cap applicable to any single test run has been added for forced-air furnaces;
- o) the test method for forced-air furnaces (i.e., duct velocity measurement) has been clarified and improved based on lab experience since this Standard was last published;
- p) a test method has been developed using portable flue gas analyzers for measuring the gaseous emissions and thermal efficiency of site-built appliances;
- q) test fuel characteristics for automatically fuelled appliances have been clarified and expanded;
- r) CEN EN 303-5 has been recognized in this Standard for third-party certified automatically fed hydronic heaters with a nominal heat output between 50 and 500 kW;
- s) an emission requirement (expressed in mg/Nm<sup>3</sup>) and a minimum delivered thermal efficiency requirement have been added for third-party certified automatically fed hydronic heaters tested to CEN EN 303-5; and
- t) output and efficiency calculations have been modified to address appliances that generate electricity.

The CSA Technical Committee has endeavoured to make the test methodology of this Standard consistent with the U.S. EPA's regulations, where possible. The interpretation of U.S. EPA regulations is

periodically updated by the issuance of Applicability Determinations. Anyone using this Standard who also intends to seek U.S. EPA product approval should be fully conversant with all U.S. EPA requirements.

The “Standards of Performance for New Residential Wood Heaters (Subpart AAA)” and “Method 1— Sample and Velocity Traverses for Stationary Sources” were created by the U.S. Environmental Protection Agency (U.S. EPA). They are reproduced in Canada with permission from U.S. EPA.

Reprinted, with permission, from “ASTM E2515-11 (2017): Standard Test Method For Determination Of Particulate Matter Emissions Collected By A Dilution Tunnel”, “ASTM E3053-18e1: Standard Test Method for Determining Particulate Matter Emissions from Wood Heaters Using Cordwood Test Fuel”, and “E2618-13 (2019): Standard Test Method for Measurement of Particulate Emissions and Heating Efficiency of Solid Fuel-Fired Hydronic Heating Appliances”, copyright ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428. A copy of the complete standard may be obtained from ASTM International, [www.astm.org](http://www.astm.org).

CSA acknowledges that the development of this Standard was made possible, in part, by the financial support of the Hearth, Patio & Barbecue Association (HPBA).

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Subcommittee on Performance Testing of Solid-Fuel-Burning Appliances, under the jurisdiction of the Technical Committee on Energy Efficiency and Related Performance of Fuel-Burning Appliances and Equipment and the Strategic Steering Committee on Fuels and Appliances, and has been formally approved by the Technical Committee.

This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

**Notes:**

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Request for interpretation” in the subject line:*
  - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
  - b) *provide an explanation of circumstances surrounding the actual field condition; and*
  - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

*Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at [standardsactivities.csa.ca](http://standardsactivities.csa.ca).*

- 5) *This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Proposal for change” in the subject line:*
  - a) *Standard designation (number);*
  - b) *relevant clause, table, and/or figure number;*
  - c) *wording of the proposed change; and*
  - d) *rationale for the change.*

# CSA B415.1:22

## Performance testing of solid-biofuel-burning heating appliances

### 1 Scope

#### 1.1 Product range

This Standard specifies requirements for performance testing of solid-biofuel-burning heating appliances, including maximum emission rates.

#### 1.2 Reporting metrics

This Standard specifies a method for determining

- a) heat outputs;
- b) appliance efficiencies;
- c) emission levels and composition; and
- d) electrical energy consumption and production.

#### 1.3 Product types

This Standard applies to

- a) Type 1: site-built heating appliances;
- b) Type 2: room heaters;
- c) Type 3: forced-air furnaces;
- d) Type 4: hydronic heating appliances; and
- e) Type 5: hybrid heating appliances.

**Note:** Typically, units tested under this Standard will have outputs less than 150 kW (500 000 BTU/h).

For the purposes of this Standard, solid-biofuel-burning appliances include manually and automatically fuelled systems (including add-ons and combinations).

#### 1.4 Fuels

This Standard covers appliances that burn biomass fuels such as

- a) cordwood;
- b) wood chips;
- c) wood pellets;
- d) sawdust;
- e) firelogs;
- f) wood, paper, and other biomass pellets and briquettes; and
- g) non-woody solid biofuels from agricultural, herbaceous, and fruit origins such as kernel corn, other grains, cherry pits, and pelletized or briquetted straw, hay, and corn stover.

#### 1.5 Products not covered

This Standard does not apply to

- a) factory-built fireplaces intended to be used primarily for aesthetic enjoyment and not as space heaters; and