



**CSA
Group**

C22.2 No. 131-14

Type TECK 90 cable

Currently in preview, click buy full version

Legal Notice for Standards

Canadian Standards Association (operating as "CSA Group") develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group's and/or others' intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by license or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

C22.2 No. 131-14
March 2014

Title: *Type TECK 90 cable*

To register for e-mail notification about any updates to this publication

- go to shop.csa.ca
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **242214**

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at csagroup.org/legal to find out how we protect your personal information.

C22.2 No. 131-14
Type TECK 90 cable



™A trade-mark of the Canadian Standards Association, operating as "CSA Group"

*Published in March 2014 by CSA Group
A not-for-profit private sector organization
5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6*

*To purchase standards and related publications, visit our Online Store at shop.csa.ca
or call toll-free 1-800-463-6727 or 416-747-4044.*

ISBN 978-1-77139-050-7

© 2014 CSA Group

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

Contents

Technical Committee on Wiring Products 3

Subcommittee on Metal-Clad Cables 5

Preface 7

1 Scope 8

2 Reference publications 8

3 Definitions 9

4 General requirements 9

5 Construction 9

5.1 Circuit conductors 9

5.1.1 Material 9

5.1.2 Joints 10

5.1.3 Sizes 10

5.1.4 Conductor shield 10

5.2 Bonding conductors 11

5.2.1 General 11

5.2.2 Multi-conductor cable 11

5.2.3 Single-conductor cable 11

5.3 Insulation 12

5.3.1 General 12

5.3.2 Thickness 12

5.4 Coverings and separators 12

5.5 Insulation shielding 12

5.6 Assembly of multi-conductor cables 12

5.7 Fillers 13

5.8 Binder 13

5.9 Inner jacket 13

5.9.1 General 13

5.9.2 Thickness of inner jacket 13

5.10 Tape over inner jacket (optional) 14

5.11 Armour 14

5.11.1 General 14

5.11.2 Splices 14

5.11.3 Interior surface 14

5.11.4 Strip 14

5.12 Optional outer jacket 15

5.13 Coding of conductors 15

6 Marking 15

6.1 Marking of cables 15

6.1.1 Manufacturer's marker 15

6.1.2	Type designation	15
6.1.3	Type of insulation	15
6.1.4	Low temperature classification	16
6.1.5	Flame test rating	16
6.1.6	Cables with aluminum conductors	16
6.1.7	Acid gas (optional)	16
6.1.8	Weather resistance (optional)	16
6.1.9	Legend spacing	16
6.1.10	Additional marking of cable (optional)	16
6.2	Marking of coils or reels	17
7	Tests	17
7.1	Properties of concentric bonding conductors	17
7.1.1	Tensile strength of aluminum wires removed from a concentric bonding conductor	17
7.1.2	Bending test on aluminum wires removed from a concentric bonding conductor	17
7.2	Physical properties of inner jacket	17
7.3	Heat shock test — Thermoplastic inner jacket	18
7.4	Deformation test — Thermoplastic inner jacket	18
7.5	Protective coating on steel strip	18
7.6	Condition of interior surface of armour	19
7.7	Flexibility of armour	19
7.8	Physical properties of outer jacket	19
7.9	Flexibility at low temperatures	19
7.10	Low temperature test — Impact test	20
7.11	Deformation — Outer thermoplastic jacket	20
7.12	Flame tests — Finished cable	20
7.12.1	Vertical flame test — FT1 (mandatory)	20
7.12.2	Vertical flame test — Cables in cable tray (optional)	20
7.12.3	Horizontal flame test — FT6 (optional)	20
7.13	Dielectric strength test — Finished cable	21
7.14	Insulation resistance — Finished cable	21
7.15	Continuity of conductors — Finished cable	21
7.16	Acid gas evolution (optional)	21
7.17	Weather resistance test	22
7.17.1	Inner jacket (optional)	22
7.17.2	Outer jacket (optional)	22
7.17.3	Insulation (optional)	22
7.18	Compatibility test — Single conductors and individual conductors intended for use in multiple-conductor cables insulated with ethylene propylene rubber	22
7.19	Spark test	23

Technical Committee on Wiring Products

K.L. Rodel	Hubbell Canada LP, Pickering, Ontario <i>Category: Producer Interest</i>	<i>Chair</i>
P. Desilets	Leviton Manufacturing of Canada Limited, Pointe-Claire, Québec <i>Category: Producer Interest</i>	<i>Vice-Chair</i>
L. Letea	CSA Group, Mississauga, Ontario	<i>Project Manager</i>

Category: General Interest

W.J. Burr	Burr and Associates, Campbell River, British Columbia
S.W. Douglas	International Association of Electrical Inspectors, Toronto, Ontario
T. Simmons	British Columbia Institute of Technology, Burnaby, British Columbia
A.Z. Tsisserev	AZT Engineering, Electrical and Fire Safety Consulting Services, Port Moody, British Columbia

Category: Producer Interest

C. Davis	Electro Cables Incorporated, Trenton, Ontario
D. Drysdale	Nexans Canada Inc., Milton, Ontario
E. Thompson	Atkore International, Harvey, Illinois, USA

Category: Government and/or Regulatory Authority

R.J. Kelly Government of Nunavut, Department of Community
& Government Services,
Iqaluit, Nunavut

G. Montminy Régie du bâtiment du Québec,
Québec, Québec

T. Olechna Electrical Safety Authority,
Mississauga, Ontario

M.K. Shea City of Victoria,
Victoria, British Columbia

Currently in preview, click buy full version

Subcommittee on Metal-Clad Cables

C. Davis	Electro Cables Incorporated, Trenton, Ontario	<i>Chair</i>
H. Aitken	Nexans Canada Inc., Milton, Ontario	
D. Armstrong	Northern Cables Inc., Brockville, Ontario	
J.R. Cancelosi	The Okonite Company, Ramsey, New Jersey, USA	
C. Choo-Wing	General Cable Canada Ltd., Toronto, Ontario	
E. Cometa	CSA Group, Toronto, Ontario	
W.A. Crawford	The Okonite Company, Ramsey, New Jersey, USA	
C. Doan	Columbia-MBF, Mississauga, Ontario	
P.V. Donovan	Deca Cables Inc., Trenton, Ontario	
D. Drysdale	Nexans Canada Inc., Milton, Ontario	
T. Edwards	General Cable, Atlanta, Georgia, USA	
T. Hamden	CSA Group, Toronto, Ontario	
S.P. Hawkins	Shawflex a Division of ShawCor Ltd., Toronto, Ontario	
C.K. Hunter	General Cable, Las Vegas, Nevada, USA	
E. Jaimes	Nexans Colombia, Bucaramanga, Colombia	
T.R. Jurczak	General Cable, Fort Wayne, Indiana, USA	
R. Kummer	Southwire Co., Carrollton, Georgia, USA	
C. Lima	Prysmian Power Cables and Systems Canada Ltd., St-Jean-sur-Richelieu, Québec	
J. McInnes	PolyOne Canada, Inc., Orangeville, Ontario	
B.F. O'Connell	Pentair Thermal Management Canada Ltd., Trenton, Ontario	

G. Passler	Shawflex, a Division of ShawCor Ltd., Toronto, Ontario	
J. Prema	Shawflex, a Division of ShawCor Ltd., Toronto, Ontario	
V.G. Rowe	Marex Canada Limited, Nanaimo, British Columbia	
T. Rudd	Shawflex, a Division of ShawCor Ltd., Toronto, Ontario	
C. Rueck	Southwire Canada, Burnaby, British Columbia	
G. Shoshani	RSCC Wire & Cable LLC, East Granby, Connecticut, USA	
D.L. Standen	Northern Cables Inc., Brockville, Ontario	
G.A. Straniero	AFC Cable Systems, Inc., Freehold, New Jersey, USA	
A.Z. Tsisserev	AZT Engineering, Electrical and Fire Safety Consulting Services, Port Moody, British Columbia	
J. Turner	Swansea Consulting, Toronto, Ontario	
R. Williamson	Aetna Insulated Wire Company, Virginia Beach, Virginia, USA	
W. Hendricks	CSA Group, Mississauga, Ontario	<i>Project Manager</i>

Preface

This is the fifth edition of CSA C22.2 No. 131, *Type TECK 90 cable*, one of a series of Standards issued under Part II of the *Canadian Electrical Code*. It supersedes the previous editions, published in 2007, 1989, 1981, and 1965.

For general information on the Standards of the *Canadian Electrical Code, Part II*, see the preface of CAN/CSA-C22.2 No. 0.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Subcommittee on Metal-Clad Cables, under the jurisdiction of Technical Committee on Wiring Products and the Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the Technical Committee.

Interpretations: The Strategic Steering Committee on Requirements for Electrical Safety has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA Group’s procedures for Interpretation shall be followed to determine the intended safety principle.”

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
 - 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
 - 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
 - 4) *To submit a request for interpretation of this Standard, please send the following information to **inquiries@csagroup.org** and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*
- Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at **standardsactivities.csa.ca**.*
- 5) *This Standard is subject to review five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to **inquiries@csagroup.org** and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

C22.2 No. 131-14

Type TECK 90 cable

1 Scope

1.1

This Standard applies to single- and multi-conductor Type TECK 90 armoured cable intended for installation in accordance with the *Canadian Electrical Code, Part I*, on systems having nominal voltages of 5000 V and less and having a maximum temperature rating of 90 °C in both dry and wet locations.

1.2

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

2 Reference publications

This Standard refers to the following publications, and where such reference is made, it shall be to the edition listed below, including all amendments published thereto.

CSA Group

C22.1-12

Canadian Electrical Code, Part I

CAN/CSA-C22.2 No. 0-10

General requirements — Canadian Electrical Code, Part II

C22.2 No. 0.3-09

Test methods for electrical wires and cables

C22.2 No. 38-10

Thermoset-insulated wires and cables

C22.2 No. 239-09

Control and instrumentation cables