

# **Electric motors and generators for use in hazardous (classified) locations**



# Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

## Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

## Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

## Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

## Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



# Revision History

C22.2 No. 145-11, *Electric motors and generators for use in hazardous (classified) locations* — originally published May 2011

**Note:** For information about the **Standards Update Service** or if you are missing any updates go to [store.csagroup.org](http://store.csagroup.org) or [techsupport@csagroup.org](mailto:techsupport@csagroup.org)

## Revisions issued:

**Update No. 1** — May 2017; and **Update No. 2** — November 2018

Update No. 3 — December 2020	Revision symbol (in margin)
Cover, Copyright page, Preface, and Annexes A and B  <b>Note:</b> Only the revised pages have been provided.	

## CONTENTS

Preface .....	6
1 Scope .....	8
2 Conditions for Use .....	8
3 Normative References .....	9
4 Dated and Undated References .....	9
5 Definitions .....	9
6 Components .....	10
7 Units of Measurement .....	10
8 Terminology .....	10
9 Zone and Group Equivalency .....	10
9.1 Class I, Zone 1, Group IIA .....	10
9.2 Class I, Zone 1, Group IIB .....	11
9.3 Class I, Zone 1, Group IIB+H2 .....	11
9.4 Zone 20 and 21 .....	11
10 Enclosures .....	11
10.1 Material .....	11
10.2 Porosity in castings .....	12
10.3 Thickness .....	12
10.4 Strength .....	13
11 Joints in Enclosure .....	13
11.1 General .....	13
11.2 Groups C and D locations .....	14
11.3 Group B locations .....	15
11.4 Class II Locations .....	17
11.5 Class I and II Locations - Main poles and interpoles of D.C. motors .....	18
12 Holes in Enclosure .....	18
13 Shaft Openings .....	19
13.1 General .....	19
13.2 Groups F and G locations .....	20
13.3 Group E locations .....	21
14 Drain and Breather Plugs in Enclosure .....	21
15 Air-Gap Gauge Plugs in Enclosure .....	21
16 Devices with Operating Shafts or Spindles .....	21
17 Protection Against Corrosion .....	22
17.1 General .....	22
17.2 Submersible sewage-pump motor .....	22
18 Materials Applied to Joint Surfaces .....	22
19 Field-Wiring Connections .....	22
19.1 Permanently connected motors .....	22
19.2 Field wiring leads .....	24
19.3 Equipment grounding terminals and leads .....	27
20 Field-Connected Motors .....	28
20.1 General .....	28
20.2 Terminal enclosure .....	29
20.3 Conductor seal .....	29
20.4 Packing gland .....	29
20.5 Strain relief .....	30
20.6 Bonding for grounding .....	30
20.7 Equipment grounding .....	31

20.8 Attachment of threaded parts .....	32
21 Assemblies of Equipment .....	32
21.1 General .....	32
21.2 Electric brake .....	32
22 External Fans and Fan Guards .....	32
22.1 Materials .....	32
22.2 Fan-cooled motor .....	32
23 Gasoline Submersible Motors .....	33
23.1 General .....	33
23.2 Lubrication .....	33
23.3 Mechanical seal .....	33
24 Leakage Detectors .....	33
24.1 Submersible sewage-pump motor .....	33
24.2 Cord-connected submersible sewage-pump motor .....	33
25 Maximum External Surface Temperatures .....	33
26 Devices for Limiting External Surfaces Temperatures .....	34
27 Spacings .....	34
27.1 Motors rated 1500 volts or less .....	34
27.2 Motors rated more than 1500 volts .....	37
28 Test Voltages and Test Conditions .....	37
29 Instrumentation – Temperature Measurements .....	38
30 Variable-Frequency Inverter-Drive Motors .....	39
31 Temperature Tests – General .....	39
32 Temperature Tests on Sinewave Power for Single Speed or Multi-Speed Motors .....	39
32.1 Normal temperature test .....	39
32.2 Running-overload test .....	40
32.3 Running-overload to burnout test .....	40
32.4 Single-phasing test .....	40
32.5 Locked-rotor test .....	40
32.6 72-Hour locked-rotor test .....	41
32.7 Air test .....	41
32.8 Dry-dust blanket test .....	41
32.9 Moist-dust blanket test – Group G locations .....	42
33 Temperature Tests for Variable-Frequency Inverter-Drive Motors .....	42
33.1 Normal temperature test .....	42
33.2 Running-overload test .....	43
33.3 Running-overload to burnout test .....	43
33.4 Locked-rotor test .....	43
33.5 Air test .....	44
33.6 Dry-dust blanket test .....	44
33.7 Moist-dust blanket test – Group G locations .....	45
33.8 Tests on fan-duty and air-over motors with temperature-limiting devices .....	45
34 Dielectric Voltage Withstand Test .....	45
35 Dust-Penetration Test .....	46
36 Explosion Test .....	47
36.1 General .....	47
36.2 Explosion pressure test .....	48
36.3 Flame propagation test .....	49
36.4 Exceptions for non-standard joints .....	49
37 Over Pressure Test on Enclosures .....	49
38 Tests on Temperature-Limiting Devices for Limiting External Surface Temperature .....	50
38.1 Arc-rupturing tests for thermal cut-off device in D.C. motor circuit .....	50
38.2 Temperature-limiting device in the motor-control circuit .....	50

38.3	Overload test .....	50
38.4	Endurance test .....	50
38.5	Calibration test .....	51
39	Secureness Test on Conduit Hubs .....	51
40	Electrical-Resistance Test .....	51
41	Accelerated-Aging Test on Bushings .....	51
42	Cord-Pull Test .....	52
43	Rough-Usage Test .....	52
44	Drop Test .....	53
45	Gasoline-Leakage Test .....	53
46	Non-Metallic Fans and Fan Guards Test .....	53
46.1	General .....	53
46.2	Conductivity test .....	53
46.3	Accumulation of static electricity test .....	54
47	Pull Test on Tubes .....	55
48	Sealing Compounds Test .....	55
49	Low Ambient-Duty Motors .....	57
49.1	General .....	57
49.2	Construction .....	57
49.3	Explosion test .....	58
49.4	Drop test on lead seal .....	58
49.5	Manufacturing and Production Tests – Dielectric Voltage-Withstand Test .....	58
50	Grounding-Continuity Test .....	59
51	Markings .....	59

## Annex A (normative) Standard References

## Annex B (informative) Standards for components

B1	Component Standards .....	92
----	---------------------------	----

## Annex C (normative) Construction or Waiver of Explosion Tests

C1	Explosion tests per the exception to 36.1.2 .....	93
C2	Joints .....	93
C2.1	General .....	93
C2.2	Threaded joints .....	93
C2.3	Bolts in Joint Width .....	93
C2.4	Through-bolts .....	94
C3	Shaft Openings .....	94
C3.1	Class I Locations .....	94

## 1 Scope

1.1 This standard applies to electric motors and generators or submersible and nonsubmersible sewage pumps and systems suitable for use in Class I, Division 1, Groups B, C and D, and Class II, Division 1, Groups E, F and G, hazardous (classified) locations as defined by the *Canadian Electrical Code, C22.1 Part I (CEC)*, and the *National Electrical Code, ANSI/NFPA 70 (NEC)*.

1.2 This standard covers the same type of electrical equipment indicated in 1.1 for installation and use in Class I, Zone 1, Groups IIA and IIB, IIB+H<sub>2</sub>, and Zone 20 and 21 hazardous locations.

1.3 This standard also covers other rotating machinery such as, but not limited to, electric brakes, tachometers, encoders, and slip rings.

1.4 This standard does not address types of protection other than explosion-proof or dust-ignition proof.

1.5 For Canada Only - This standard does not include Canadian energy efficiency or product performance requirements. For such requirements, see Annex A, item 19. It is possible that item 19 is referenced in whole or in part in federal, provincial, territorial, or local laws or regulations relating to energy efficiency or product performance. The appropriate governmental authorities should be consulted to confirm whether item 19 has been referenced in laws or regulations.

**Note:** This standard also does not include U.S. energy efficiency requirements for electric motors used in hazardous (classified) locations.

## 2 Conditions for Use

2.1 This standard covers motors and generators intended for use under the conditions specified in 2.2 – 2.6.

2.2 Normal ambient duty conditions are defined by the following:

- a) An oxygen concentration not to exceed 21% by volume.
- b) A nominal barometric pressure of 101.4 kPa (14.7 psia) (1 atmosphere).
- c) Temperature range of minimum -25°C to +40°C.
- d) Altitude not exceeding 1000 m (3281 ft).

In Canada, the normal ambient temperature is minus 50°C to +40°C.

2.3 Low ambient duty conditions are considered to be not less than minus 70°C.

2.4 Products intended and marked for an ambient of lower than minus 25°C shall be tested (e.g.: explosion pressure test) at 5°C below the marked lower temperature.

In Canada, products intended and marked for an ambient of lower than minus 50°C shall be tested (e.g.: explosion pressure test) at 5°C below the marked lower temperature.