



**CSA
Group**

CSA C22.2 No. 179:09
National Standard of Canada
(reaffirmed 2019)



Airport series lighting cables

Currently in preview, click buy full version



Standards Council of Canada
Conseil canadien des normes

REVISED FEBRUARY 2019

Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Revision History

CSA C22.2 No. 179:09, Airport series lighting cables

National Standard of Canada — February 2019
Outside front cover, National Standard of Canada text, and title page.
This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

Currently in preview, click buy full version

Update No. 1

C22.2 No. 179-09

October 2015

Note: For information about the **Standards Update Service**, go to **shop.csa.ca** or e-mail **techsupport@csagroup.org**.

Title: *Airport series lighting cables* — originally published October 2009

The following revisions have been formally approved and are marked by the symbol delta (Δ) in the margin on the attached replacement pages:

Revised	Preface and Clause 7.1.2
New	Clause 6.6.9
Deleted	None

- Update your copy by inserting these revised pages.
- Keep the pages you remove for reference.

Δ Preface

This is the fourth edition of CSA C22.2 No. 179, *Airport series lighting cables*, one of a series of Standards issued by the Canadian Standards Association under the *Canadian Electrical Code, Part II*. It supersedes the previous editions, published in 2000, 1987, and 1982. This standard supersedes TIL J-36.

For general information on the Standards of the *Canadian Electrical Code, Part II*, see the Preface of CAN/CSA-C22.2 No. 0, *General Requirements — Canadian Electrical Code, Part II*.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Integrated Committee on Fixed Installation Wires and Cables, under the jurisdiction of the Technical Committee on Wiring Products and the Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the Technical Committee.

Interpretations: The Strategic Steering Committee on Requirements for Electrical Safety has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA’s procedures for interpretation shall be followed to determine the intended safety principle.”

Notes:

- (1) Use of the singular does not exclude the plural (and vice versa) when the sense allows.
- (2) Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.
- (3) This publication was developed by consensus, which is defined by CSA policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.
- (4) CSA Standards are subject to periodic review, and suggestions for their improvement will be referred to the appropriate committee.
- (5) All enquiries regarding this Standard, including requests for interpretation, should be addressed to Canadian Standards Association, 5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6.
Requests for interpretation should
 - (a) define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;
 - (b) provide an explanation of circumstances surrounding the actual field condition; and
 - (c) be phrased where possible to permit a specific “yes” or “no” answer.

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are published in CSA’s periodical Info Update, which is available on the CSA Web site at www.csa.ca

6.6.7 Permittivity

6.6.7.1

The permittivity of the insulation of a specimen of cable shall not exceed a value of 4 while at a temperature of not less than 22 °C and while in the same distilled water in which it has been immersed for 24 h. After 14 d of immersion, the permittivity shall not have risen by more than

- (a) 10% over the value determined at the end of the first 24 h; or
- (b) 3% over the value determined at the end of the first 7 d.

6.6.7.2

Compliance with Clause 6.6.7.1 shall be determined in accordance with the apparatus and method specified in the capacitance and relative permittivity test of CAN/CSA-C22.2 No. 2556.

6.6.8 Continuity of conductors

6.6.8.1

The conductor in a length of finished cable shall be continuous.

6.6.8.2

Compliance with Clause 6.6.8.1 shall be determined in accordance with the apparatus and method specified in the continuity test of CAN/CSA-C22.2 No. 2556.

Δ 6.6.9 Weather resistance test — Optional

The test, if performed, shall be conducted in accordance with the test Physical Properties in CSA C22.2 No. 2556. The insulation shall retain a minimum of 80% of its unconditioned tensile strength and elongation values following 1000 h xenon arc exposure in a weatherometer.

7 Marking

7.1 Marking on product

7.1.1 Manufacturer's identification

A finished cable shall have a durable distinctive marking throughout its entire length by which the organization responsible for the product is readily identified. The space between marking legends shall not exceed 1 m.

Δ 7.1.2 Additional markings

A finished cable shall have the following marked on it in the same manner specified in Clause 7.1.1:

- (a) type designation "ASLC";
- (b) nominal voltage rating 5000 V;
- (c) size (AWG);
- (d) month and year of manufacture; and
- (e) "Sunlight Resistant", "Sun Res" or "SR" for products complying with Clause 6.6.9.

7.2 Package marking

Cables and reels of wire shall be tagged or marked to legibly indicate the following:

- (a) manufacturer's name;
- (b) month and year of manufacture;
- (c) type designation "ASLC";
- (d) size (AWG); and
- (e) nominal voltage 5000 V.

Table 1
Overall diameter
(See Clause 5.2.4.)

Size, AWG	Overall diameter, mm	
	Minimum	Maximum
8	9.5	11.8
6	10.4	12.8
4	11.3	14.0

Table 2
DC resistance of conductor
(See Clause 6.3.1.)

Conductor size, AWG	Maximum dc resistance of conductor at 20 °C, Ω/km	
	Bare copper	Coated copper
8	2.10	2.16
6	1.32	1.36
4	0.832	0.856

Table 3
Physical properties of extruded semiconducting shielding material
(See Clause 5.4.2.)

Condition	Requirement
Elongation after air oven test for 168 h at 121 ± 1 °C	100% min
Brittleness temperature	Not warmer than -25 °C

Table 4
Physical properties of insulation
(See Clause 6.5.1.)

Condition	Minimum tensile strength	Minimum elongation
Before aging	12.4 MPa	150%
After aging for 7 d at 121 ± 1 °C	75% of unaged value	75% of unaged value

Standards Update Service

CSA C22.2 No. 179:09
October 2009

Title: *Airport series lighting cables*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **24203.7**

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada



Standards Council of Canada
Conseil canadien des normes

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada

Cette Norme Nationale du Canada n'est disponible qu'en anglais.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

®A trademark of the Canadian Standards Association, operating as “CSA Group”

National Standard of Canada

CSA C22.2 No. 179:09
Airport series lighting cables



*®A trademark of the Canadian Standards Association,
operating as "CSA Group"*



*Published in October 2009 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at store.csagroup.org
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 29.060.20; 49.100
ISBN 978-1-55491-318-3*

*© 2009 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Technical Committee on Wiring Products v

Integrated Committee on Fixed Installation Wires and Cables vi

Preface ix

1 Scope 1

2 Reference publications 1

3 Definitions 2

4 General requirements 2

5 Construction 2

5.1 Conductors 2

5.1.1 Material 2

5.1.2 Wires 2

5.1.3 Sizes 2

5.1.4 Stranding 3

5.1.5 Joints 3

5.1.6 Conductor shielding 3

5.2 Insulation 3

5.2.1 General 3

5.2.2 Repairs 3

5.2.3 Thickness 3

5.2.4 Overall diameter 3

6 Tests 3

6.1 Insulation thickness 3

6.2 Overall diameter 3

6.3 DC resistance of conductors 4

6.4 Conductor shielding 4

6.4.1 Volume resistivity 4

6.4.2 Physical tests for semiconducting material intended for extrusion 4

6.5 Physical properties of insulation 5

6.5.1 General 5

6.5.2 Physical properties test 5

6.5.3 Insulation shrinkback 5

6.6 Tests on finished cable 5

6.6.1 Deformation test 5

6.6.2 Burning particles (dropping) test 6

6.6.3 Cold bend test 6

6.6.4 Dielectric voltage-withstand test 6

6.6.5 Test for insulation resistance (IR) at 15 °C 6

6.6.6 Test for insulation resistance (IR) at 90 °C 6

6.6.7 Permittivity 7

6.6.8 Continuity of conductors 7

7 Marking 7

7.1 Marking on product 7

- 7.1.1 Manufacturer's identification 7
 - 7.1.2 Additional markings 7
 - 7.2 Package marking 7
-

Tables

- 1** — Overall diameter 8
- 2** — DC resistance of conductor 8
- 3** — Physical properties of extruded semiconducting shielding material 8
- 4** — Physical properties of insulation 8
- 5** — Minimum insulation resistance (IR) at 15 °C 9
- 6** — Minimum insulation resistance (IR) at 90 °C 9