



# **Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations**



# Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

## Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

## Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

## Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

## Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



# Revision History

**C22.2 No. 213-17, Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations** — originally published September 2017

**Note:** For information about the **Standards Update Service** or if you are missing any updates go to [store.csagroup.org](http://store.csagroup.org) or [techsupport@csagroup.org](mailto:techsupport@csagroup.org).

**Revisions issued:** Update No. 1 — August 2018

**Revisions issued:** Update No. 2 — August 2019

| Update No. 3 — April 2021   | Revision symbol (in margin) |
|---|-----------------------------|
| Title page, copyright page, preface, Clauses 3.11, 3.30, 3.34, 4.1.1, 4.2.1, 4.4.1, 4.4.2, 5.1.2, 5.2.2, 5.3.1, 5.6.0, 13.1.5, 13.1.8 and 16.2.1 and Annexes A and B<br><br><b>Note:</b> Only the revised pages have been provided. |                             |

*National Standard of Canada*

*C22.2 No. 213-17*

***Nonincendive electrical equipment  
for use in Class I and II, Division 2  
and Class III, Divisions 1 and 2  
hazardous (classified) locations***



*®A trademark of the Canadian Standards Association,  
operating as "CSA Group."*



ICS 29.260; 29.020  
ISBN 978-1-4883-0927-4



CSA Group  
CSA C22.2 No. 213-17  
Third Edition



Underwriters Laboratories Inc.  
UL 121201  
Ninth Edition

**Nonincendive Electrical Equipment for Use in Class I and II,  
Division 2 and Class III, Divisions 1 and 2 Hazardous  
(Classified) Locations**

September 15, 2017

(Title Page Reprinted: August 26, 2019)



ANSI/UL 121201-2019



## Commitment for Amendments

This standard is issued jointly by the Canadian Standards Association (operating as “CSA Group”) and Underwriters Laboratories Inc. (UL). Comments or proposals for revisions on any part of the standard may be submitted to CSA Group or UL at anytime. Revisions to this standard will be made only after processing according to the standards development procedures of CSA Group, and UL. CSA Group and UL will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue.

---

## ISBN 978-1-4883-0927-4 © 2017 CSA Group

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

This Standard is subject to review five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to [inquires@csagroup.org](mailto:inquires@csagroup.org) and include “Proposal for change” in the subject line: Standard designation (number); relevant clause, table, and/or figure number; wording of the proposed change; and rationale for the change.

To purchase CSA Group Standards and related publications, visit CSA Group’s Online Store at [shop.csa.ca](http://shop.csa.ca) or call toll-free 1-800-463-6727 or 416-747-4044.

---

## Copyright © 2017 Underwriters Laboratories Inc.

UL’s Standards for Safety are copyrighted by UL. Neither printed nor electronic copy of a Standard should be altered in any way. All of UL’s Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

This ANSI/UL Standard for Safety consists of the Ninth Edition. The most recent designation of ANSI/UL 121201 as an American National Standard (ANSI) occurred on September 15, 2017. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface. The National Difference Page and IEC Foreword are also excluded from the ANSI approval of IEC-based standards. Any other portions of this ANSI/UL standard that were not processed in accordance with ANSI/UL requirements are noted at the beginning of the impacted sections.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL’s On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

To purchase UL Standards, visit UL’s Standards Sales Site at <http://www.shopulstandards.com/HowToOrder.asp> or call toll-free 1-888-853-3503.

---

## CONTENTS

|  |    |
|--|----|
| <b>PREFACE</b> .....   | 6  |
| <b>1 Scope</b> .....   | 9  |
| 1.1 Introduction .....   | 9  |
| 1.2 Applicable to Class I and II, Division 2 and Class III, Divisions 1 and 2 locations .....                        | 9  |
| 1.3 Applicable to associated nonincendive field wiring apparatus .....   | 10 |
| 1.4 Applicable ambient conditions .....  | 10 |
| 1.5 Not applicable to specified ignition mechanisms .....  | 10 |
| 1.6 Not applicable to specific products .....  | 10 |
| <b>2 Reference publications</b> .....  | 10 |
| <b>3 Definitions</b> .....   | 10 |
| <b>4 General requirements</b> .....  | 15 |
| 4.1 Requirements based upon normal operating conditions .....  | 15 |
| 4.2 General-purpose requirements .....   | 15 |
| 4.3 Consideration of subsequent conditions following nonincendive field wiring faults .....                          | 15 |
| 4.4 Component standards .....  | 15 |
| <b>5 Requirements for Class I, Division 2 equipment</b> .....  | 15 |
| 5.1 General .....  | 15 |
| 5.2 Enclosures .....   | 16 |
| 5.3 Fuses used in circuits subject to overloading .....  | 16 |
| 5.4 Fuses replaceable from outside of the enclosure .....  | 17 |
| 5.5 Circuit breakers .....   | 17 |
| 5.6 Batteries and battery-powered equipment .....  | 17 |
| <b>6 Requirements for Class II, Division 2, Class III, Divisions 1 and 2 equipment</b> .....                         | 17 |
| 6.1 Protection methods .....   | 17 |
| 6.2 Portable battery-powered equipment .....   | 18 |
| 6.3 Thermal ignition .....   | 19 |
| 6.4 Gasket and seal specification .....  | 19 |
| <b>7 Nonincendive circuits and nonincendive field wiring</b> .....   | 19 |
| 7.1 Spark ignition evaluation .....  | 19 |
| 7.2 Nonincendive circuit evaluation .....  | 19 |
| 7.3 Evaluation by analysis .....   | 20 |
| 7.4 Associated nonincendive field wiring apparatus .....   | 20 |
| 7.5 Nonincendive field wiring apparatus .....  | 21 |
| 7.6 Nonincendive field wiring circuit .....  | 21 |
| 7.7 Interconnection of nonincendive field wiring apparatus with associated nonincendive field wiring apparatus ..... | 21 |
| <b>8 Normally nonarcing components</b> .....   | 22 |
| 8.1 Components considered as nonarcing in normal operation .....   | 22 |
| 8.2 Connectors and plug-in components .....  | 22 |
| 8.3 Plug-in fuses that can be replaced in normal operating conditions .....  | 22 |
| 8.4 Circuit breakers .....   | 22 |
| 8.5 Lamps .....  | 23 |
| 8.6 Connectors .....   | 23 |
| 8.7 Manually operated components .....   | 23 |
| 8.8 Connections on exterior of enclosure .....   | 23 |
| <b>9 Marking</b> .....   | 25 |
| 9.1 General-purpose marking .....  | 25 |
| 9.2 Hazardous location related marking .....   | 25 |
| 9.3 Information for battery-powered equipment .....  | 27 |

|      |  |    |
|------|--|----|
| 9.4  | Nonincendive field wiring connections  | 27 |
| 9.5  | Optional zone marking (US only)  | 29 |
| 9.6  | Alternate use of Division parameter designations for nonincendive field wiring       | 30 |
| 9.7  | Connectors and lampholders   | 30 |
| 9.8  | Fuseholders  | 31 |
| 9.9  | Circuit breakers   | 31 |
| 9.10 | External plugs and sockets   | 31 |
| 9.11 | Oil immersed equipment   | 31 |
| 9.12 | Multiple warning markings  | 32 |
| 10   | Surface temperature requirements   | 32 |
| 10.1 | Determination of maximum surface temperature   | 32 |
| 10.2 | Surface temperature  | 32 |
| 10.3 | Surface temperature of small components  | 33 |
| 11   | Spark ignition testing of nonincendive circuits                                      | 33 |
| 11.1 | Spark test apparatus   | 33 |
| 11.2 | Ignition test conditions   | 34 |
| 12   | Evaluation of nonincendive components  | 34 |
| 12.1 | Ratings, preconditioning, and test for nonincendive components                       | 34 |
| 12.2 | Spark ignition test for nonincendive components                                      | 34 |
| 13   | Evaluation of sealed devices   | 35 |
| 13.1 | Ratings, construction, preconditioning, and test for sealed devices                  | 35 |
| 13.2 | Air leakage test   | 36 |
| 14   | Evaluation of enclosed-break devices   | 36 |
| 14.1 | Ratings, construction, preconditioning, and test for enclosed-break devices          | 36 |
| 14.2 | Tests for enclosed-break devices   | 37 |
| 15   | Enclosure ingress protection for Class II and III                                    | 37 |
| 15.1 | Construction and tests for enclosures  | 37 |
| 15.2 | Dust-blast method  | 38 |
| 15.3 | Circulating dust method  | 38 |
| 15.4 | Atomized-water method  | 39 |
| 15.5 | Gasket test  | 39 |
| 15.6 | Temperature aging  | 40 |
| 16   | Drop tests and impact tests  | 40 |
| 16.1 | Portable equipment   | 40 |
| 16.2 | Drop test for portable equipment   | 41 |
| 16.3 | Impact test for fixed stationary equipment used in Class I location                  | 41 |
| 16.4 | Impact test for fixed or stationary equipment used in Class II or Class III location | 41 |
| 17   | Evaluation of an oil immersed equipment  | 41 |
| 17.1 | General  | 41 |
| 17.2 | Enclosure  | 42 |
| 17.3 | Oil requirements   | 42 |
| 17.4 | Temperature test   | 42 |
| 18   | Manufacturer's instructions  | 42 |
| 18.1 | Information in addition to that required by general-purpose standards                | 42 |
| 18.2 | Information for connections on exterior of enclosure                                 | 43 |
| 18.3 | Information for equipment with nonincendive field wiring connections                 | 43 |
| 18.4 | Information for component replacement or equipment disconnection                     | 44 |
| 18.5 | Information for equipment containing nonincendive components                         | 44 |

**Annex A – Normative References (normative)**

**Annex B – Common Standards – Safety Requirements for Electrical Equipment (informative)**

**Annex C – Suggested Warnings with French Equivalent (informative)**

Currently in preview, click buy full versi

## PREFACE

This is the harmonized CSA Group and UL standard for Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations. It is the Third edition of CSA-C22.2 No. 213 and the Ninth edition of UL 121201. This edition of CSA-C22.2 No. 213 supersedes the previous edition published in 2016. This edition of UL 121201 supersedes the previous ISA-12.12.01-2015 edition published on August 21, 2015.

This harmonized standard was prepared by the CSA Group and Underwriters Laboratories Inc. (UL).

Efforts have been made to synchronize the UL edition number with that of the previous corresponding ISA standard with which this standard is now harmonized with CSA. As a result, one or more UL edition numbers have been skipped to align per the previous ISA edition number.

The ISA-12.12.01-2015 standard is being maintained until September 15, 2022 for reference purposes only.

This standard is considered suitable for use for conformity assessment within the stated scope of the standard.

This standard was reviewed by the CSA Integrated Committee on Hazardous Location Products, under the jurisdiction of the CSA Technical Committee on Industrial Products and the CSA Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the CSA Technical Committee.

This standard has been approved by the American National Standards Institute (ANSI) as an American National Standard.

### Application of Standard

Where reference is made to a specific number of samples to be tested, the specified number is to be considered a minimum quantity.

**Note:** Although the intended primary application of this standard is stated in its scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

### Level of Harmonization

This standard uses the IEC format but is not based on, nor is it considered equivalent to, an IEC standard.

This standard is published as an identical standard for CSA Group and UL.

An identical standard is a standard that is exactly the same in technical content except for national differences resulting from conflicts in codes and governmental regulations. Presentation is word for word except for editorial changes.

### Reasons for Differences From IEC

There is no corresponding IEC standard.

## Interpretations

The interpretation by the standards development organization of an identical or equivalent standard is based on the literal text to determine compliance with the standard in accordance with the procedural rules of the standards development organization. If more than one interpretation of the literal text has been identified, a revision is to be proposed as soon as possible to each of the standards development organizations to more accurately reflect the intent.

The following people served as members of STP 60079 and participated in the review of this standard:

| <b>NAME</b>           | <b>COMPANY</b>                                   |
|-----------------------|--|
| *B. Zimmermann, Chair | R Stahl Inc.                                     |
| *T. Adam              | FM Approvals LLC                                 |
| R. Allen              | Honeywell Inc.                                   |
| D. Ankele             | UL LLC   |
| S. Bihler-Lopez       | CML Inc.   |
| S. Blais              | Appleton Group                                   |
| K. Boegli             | KBB Consulting                                   |
| R. Brownlee           | Pepperl + Fuchs Inc.                             |
| D. Burns              | Shell P&T — Innovation / R&D                     |
| R. Chalmers           | Industrial Scientific Corp.                      |
| *C. Coache            | National Fire Protection Association             |
| D. Cook               | Shelby County Department of Development Services |
| M. Coppler            | Det Norske Veritas Certification Inc.            |
| D. Mario              | Consultant                                       |
| T. Dubaniewicz        | NIOSH  |
| G. Edwards            | Rosemount Inc.                                   |
| M. Ehrmann            | R Stahl Inc                                      |
| M. Egloff             | Montana Tech, University of Montana              |
| D. El Tawy            | Solar Turbines Inc.                              |
| *A. Engler            | Det Norske Veritas DNV                           |
| Z. Fosse              | DEKRA Certification Inc                          |
| G. Gurinder           | Gurinder Garcha Consulting                       |
| D. Grady              | Talema Group                                     |
| R. Holub              | DuPont   |
| P. House              | Thermon Mfg. Co.                                 |
| *B. Johnson           | Thermon Mfg. Co.                                 |
| R. Johnson            | Source IEC                                       |
| *P. Kelly             | UL LLC   |
| S. Kiddle             | ABB Inc  |
| *P. Kovscek           | Industrial Scientific Corp.                      |
| A. Kreider            | Phoenix Contact Development & Manufacturing Inc. |
| *J. Kuntscher         | Thermon Mfg Co.                                  |
| W. Lawrence           | FM Approvals LLC                                 |
| E. Leubner            | Eaton's Crouse-Hinds Business                    |
| W. Lowers             | WCL Corp.  |
| *N. Ludlam            | FM Approvals Ltd.                                |
| R. Martin             | USCG   |
| *R. Masek             | CSA Group  |
| E. Massey             | Baldor Electric Co.                              |
| W. McBride            | Northern Electric Co.                            |
| T. Michalski          | Killark Electric Mfg. Co.                        |

Table Continued on Next Page

---

**Table Continued**

| <b>NAME</b>     | <b>COMPANY</b>                                      |
|-----------------|---|
| J. Miller       | Detector Electronics Corp.                          |
| *O. Murphy      | Honeywell Inc.                                      |
| D. Nachtigall   | Rockwell Automation                                 |
| D. Nedorostek   | Bureau of Safety & Environmental Enforcement (BSEE) |
| A. Page         | Bud Page Consultant                                 |
| T. Patel        | Littelfuse Inc.                                     |
| P. Rigling      | Measurement Technology Ltd.                         |
| *K. Robinson    | Occupational Safety and Health Adm.                 |
| J. Ruggieri     | General Machine Corp.                               |
| *J. Scheller    | Baldor Electric Co.                                 |
| P. Schimmoeller | CSA Group   |
| *T. Schnaare    | Rosemount Inc.                                      |
| *A. Schnuelle   | CML Inc.  |
| R. Seitz        | ARTECH Engineering                                  |
| S. Sharma       | Lindsay Corp.                                       |
| R. Sierra       | US Coast Guard                                      |
| M. Spencer      | Transcanada / Columbia Pipeline Group               |
| G. Steinman     | Thomas & Betts                                      |
| *R. Teather     | Det Norske Veritas Certification Inc.               |
| W. VanHill      | Intertek  |
| D. Wechsler     | American Chemistry Council                          |
| R. Wigg         | E-x Solutions International Pty Ltd.                |
| *K. Wolf        | Intertek  |
| T. Woods        | GE Oil & Gas  |
| R. Zalosh       | Firexplo  |

---

\* Non-voting member

## 1 Scope

### 1.1 Introduction

1.1.1 The purpose of this standard is to provide minimum requirements for the design, construction, and marking of electrical equipment or parts of such equipment for use in Class I and Class II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations.

1.1.2 This equipment, in normal operation, is not capable of causing ignition of the surrounding atmosphere under the conditions prescribed in this standard, although the equipment may contain electronic components used in an incendive circuit and may also have field wiring that is an incendive circuit.

1.1.3 In addition, it is the intent of this document to establish uniformity in test methods for determining the suitability of the equipment and associated circuits and components as they relate to potential ignition of a specific flammable gas or vapour-in-air mixture, combustible dust, easily ignitable fibers, or flyings.

### 1.2 Applicable to Class I and II, Division 2 and Class III, Divisions 1 and 2 locations

1.2.1 This standard applies only to equipment, circuits, and components for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations as defined in the National Electrical Code® (NEC®) ANSI/NFPA 70 or in the Canadian Electrical Code, Part I (CE Code, Part I) CSA C22.1.

**NOTE 1** Some equipment designed for use in unclassified locations is permitted by the NEC® or CE Code, Part I for installation in Division 2 locations. The judgment of acceptability for the installation would be determined by the authority having jurisdiction. Such equipment would not have the hazardous location marking or documentation described in this standard. It is anticipated that such equipment would comply with the other requirements in this standard and that the determination of compliance is elementary (e.g., a nonarcing instrument inside a Type 4 or Type 12 enclosure used in a Class II, Division 2 location).

**NOTE 2** Throughout this standard, references to CAN/CSA C22.2 No. 60079-0 and UL 60079-0 are made as CSA/UL 60079-0. Similarly references to CAN/CSA C22.2 No. 60079-1 and UL 60079-1 are made as CSA/UL 60079-1. Similarly references to CAN/CSA C22.2 No. 60079-11 and UL 60079-11 are made as CSA/UL 60079-11. Similarly references to CAN/CSA C22.2 No. 60079-15 and UL 60079-15 are made as CSA/UL 60079-15.

**NOTE 3** The US and Canadian adoptions of IEC 60079-0, IEC 60079-1, IEC 60079-6, IEC 60079-11, and IEC 60079-15 may be adopted at different revision levels and may have different National Deviations.