

Control and instrumentation cables



Legal Notice for Standards

Canadian Standards Association (CSA) standards are developed through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA is a private not-for-profit company that publishes voluntary standards and related documents. CSA has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA and the users of this document (whether it be in printed or electronic form), CSA is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA's and/or others' intellectual property and may give rise to a right in CSA and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



CANADIAN STANDARDS
ASSOCIATION

CSA Standards Update Service

C22.2 No. 239-09

November 2009

Title: *Control and instrumentation cables*

Pagination: **57 pages** (x preliminary and 47 text), each dated **November 2009**

Automatic notifications about any updates to this publication are available.

- To register for e-mail notifications, and/or to download any existing updates in PDF, enter the Online Store at **www.ShopCSA.ca** and click on **My Account** on the navigation bar.

The **List ID** for this document is **2420348**.

- To receive printed updates, please complete and return the attached card.



Name _____

Organization _____

Address _____

City _____

Province/State _____

Country _____ Postal/Zip Code _____

E-mail _____

I consent to CSA collecting and using the above information to send me updates relating to this publication.

Visit CSA's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

C22.2 No. 239-09

Currently in preview, click buy full version

**ASSOCIATION CANADIENNE DE
NORMALISATION**

BUREAU CENTRAL DE L'INFORMATION
5060, SPECTRUM WAY, BUREAU 100
MISSISSAUGA ON L4W 5N6
CANADA

**CANADIAN STANDARDS
ASSOCIATION**

CONSOLIDATED MAILING LIST
5060 SPECTRUM WAY, SUITE 100
MISSISSAUGA ON L4W 5N6
CANADA

| |
|----------------------------|
| Affranchir suffisamment |
| Place Stamp Here |

CSA Standard

C22.2 No. 239-09
Control and instrumentation cables



**CANADIAN STANDARDS
ASSOCIATION**

®Registered trade-mark of Canadian Standards Association

*Published in November 2009 by Canadian Standards Association
A not-for-profit private sector organization
5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6
1-800-463-6727 • 416-747-4044*

Visit our Online Store at www.ShopCSA.ca



The Canadian Standards Association (CSA) prints its publications on Rolland Enviro100, which contains 100% recycled post-consumer fibre, is EcoLogo and Processed Chlorine Free certified, and was manufactured using biogas energy.

To purchase CSA Standards and related publications, visit CSA's Online Store at www.ShopCSA.ca or call toll free 1-800-463-6727 or 416-747-4044.

ISSN 1978-1-55491-326-8

Technical Editor: Leonard Letea

© Canadian Standards Association — 2009

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

Contents

Technical Committee on Wiring Products vi

Integrated Committee on Control, Instrument, Communication, and Marine Cables vii

Preface x

1 Scope 1

2 Reference publications 2

3 Definitions 3

4 General requirements 4

5 Construction 4

5.1 Conductors 4

5.1.1 Materials 4

5.1.2 Sizes 5

5.1.3 Stranding 5

5.1.4 Diameter and area 5

5.1.5 Joints 5

5.1.6 DC resistance 5

5.1.7 Thermocouples 6

5.2 Insulation 6

5.2.1 Materials 6

5.2.2 Thickness 7

5.3 Non-metallic insulation covering 7

5.3.1 General 7

5.3.2 Thermoplastic insulated conductors 7

5.3.3 EP insulated conductors 7

5.3.4 XLPE insulated conductors 7

5.3.5 Silicone rubber insulated conductors 8

5.4 Shields 8

5.4.1 Material 8

5.4.2 Alternative material 8

5.4.3 Drain wires 8

5.4.4 Shield isolation 8

5.5 Assembly and identification 8

5.5.1 Assembly 8

5.5.2 Identification of conductors 8

5.6 Non-metallic jackets 9

5.6.1 General 9

5.6.2 Inner jackets 9

5.6.3 Outer non-metallic coverings 9

5.6.4 Non-metallic jacket materials 9

5.7 Metallic outer coverings 9

5.7.1 General 9

5.7.2 Aluminum sheath 10

5.7.3 Interlocked armour 10

- 5.7.4 Galvanized steel wire armour 10
- 5.8 Jackets over metallic sheath or armour 11
- 5.9 Optional components 11
- 5.10 Temperature rating of cable 12

6 Tests 12

- 6.1 Electrical 12
 - 6.1.1 Spark 12
 - 6.1.2 Insulation resistance 12
 - 6.1.3 Circuit continuity of conductors 12
 - 6.1.4 Dielectric withstand 13
- 6.2 Physical and flammability tests on complete cable 13
 - 6.2.1 Low-temperature impact test — No. 14 AWG and larger (optional) 13
 - 6.2.2 Cold bend test 13
 - 6.2.3 Flammability 13
 - 6.2.4 Weathering (optional) 14
- 6.3 Tests on interlocked armoured cable 14
 - 6.3.1 Flexibility 14
 - 6.3.2 Tension 14
 - 6.3.3 Elongation 15
- 6.4 Flexibility tests on aluminum sheathed cables 15
- 6.5 Mechanical damage — Impact (for corrugated sheath only) 15
- 6.6 Mechanical damage — Crushing (for corrugated sheath only) 16

7 Marking 16

- 7.1 Marking on product 16
- 7.2 Marking on packages 17

8 High-temperature control and instrumentation cable 17

- 8.1 General 17
- 8.2 Construction 18
 - 8.2.1 Conductors 18
 - 8.2.2 Insulation 18
 - 8.2.3 Cabling 18
 - 8.2.4 Jacket 19
 - 8.2.5 Aluminum sheath and interlocked armour 19
 - 8.2.6 Covering over armour 19
 - 8.2.7 Temperature rating of the cable 19
- 8.3 Tests 19
- 8.4 Marking 19
 - 8.4.1 Marking on product 19
 - 8.4.2 Marking on packages 20

9 Halogen-free, limited-smoke control and instrumentation cables 20

- 9.1 General 20
- 9.2 Properties of materials 20
 - 9.2.1 General 20
 - 9.2.2 Insulation 20
 - 9.2.3 Jacket 20
- 9.3 Tests on completed cable 21
- 9.4 Marking 21

Annexes

- A** (informative) — Steel wire armour used in control and instrumentation cable 39

- B** (informative) — Rating of cable jacket in high ambient temperature 40
C (informative) — Metric sizes 41
D (informative) — Low-temperature handling 47

Tables

- 1** — Diameters of solid conductors and cross-sectional areas of stranded conductors 21
2 — Maximum dc resistance of conductors at 25 °C, $\Omega \cdot \text{km}$ 22
3 — Combinations of PVC insulation 23
4 — Properties of filled thermoplastic polyethylene 23
5 — Average insulation thickness, mm 24
6 — Thickness of reduced wall insulation and nylon coverings, mm 24
7 — Thickness of overall jacket, mm 24
8 — Properties of thermoplastic jackets other than polyethylene 25
9 — Properties of thermoset jackets 26
10 — Minimum thickness of smooth aluminum sheath, seamed or seamless, mm 27
11 — Minimum thickness of corrugated aluminum sheath, seamed or seamless, mm 27
12 — Minimum thickness of metal strip, mm 28
13 — Minimum weight of zinc coating for wire armour 28
14 — Size of galvanized steel wire armour 28
15 — Galvanized steel wire diameter tolerance 29
16 — Thickness of jacket over metallic sheath or armour, mm 29
17 — Spark test voltage 29
18 — Minimum insulation resistance at 15 °C, $\text{G}\Omega \cdot \text{m}$ 30
19 — Mandrel diameter 31
20 — Mandrel diameters for cold bend test — Multiple-conductor cables 31
21 — Mandrel diameter for flexing after weatherometer test 31
22 — Physical properties of high-temperature insulation and fluorine-containing jacket materials 32
23 — Fluorine-containing polymer minimum average insulation thickness, mm 33
24 — Physical and electrical properties of silicone rubber insulation and jacket materials 33
25 — Minimum average silicone rubber insulation thickness, mm 34
26 — Thickness of fluorine-containing polymer jacket, mm 34
27 — Thickness of silicone rubber jacket, mm 34
28 — Properties of halogen-free thermoplastic insulation 35
29 — Properties of halogen-free thermoset insulation 36
30 — Properties of halogen-free thermoplastic jacket 37
31 — Properties of halogen-free thermoset jacket 38

Technical Committee on Wiring Products

| | | |
|-------------------|--|------------------------|
| K.L. Rodel | Hubbell Canada LP, Pickering, Ontario <i>Representing Manufacturers</i> | <i>Chair</i> |
| S. Paulsen | Province of New Brunswick, Fredericton, New Brunswick <i>Representing Regulatory Authorities</i> | <i>Vice-Chair</i> |
| B. Haydon | Canadian Standards Association, Mississauga, Ontario | <i>Project Manager</i> |

Representing Regulatory Authorities

| | |
|-----------------------|--|
| G. Montminy | Régie du bâtiment du Québec, Québec, Québec |
| T. Olechna | Electrical Safety Authority, Mississauga, Ontario |
| A.Z. Tsisserev | City of Vancouver, Vancouver, British Columbia |

Representing Manufacturers

| | |
|-----------------------|---|
| C. Davis | Electro Cables Incorporated, Trenton, Ontario |
| P. Desilets | Leviton Manufacturing of Canada Limited, Pointe-Claire, Québec |
| B.F. O'Connell | Tyco Thermal Controls (Canada) Ltd., Trenton, Ontario |
| D.S. Reith | Nelson Canada Inc., Markham, Ontario |

Representing General Interests

| | |
|---------------------|--|
| B. Beland | Sherbrooke, Québec |
| D.H. Dunsire | Winnipeg, Manitoba |
| C. Simon | ConocoPhillips Canada Ltd., Calgary, Alberta |
| I. Simmons | British Columbia Institute of Technology, Burnaby, British Columbia |

Integrated Committee on Control, Instrument, Communication, and Marine Cables

| | | |
|-------------------------|--|-------------------|
| D. Drysdale | Nexans Canada Inc., Fergus, Ontario | <i>Chair</i> |
| S. Hawkins | ShawCor Ltd., Toronto, Ontario | <i>Vice-Chair</i> |
| E. Aberbach | General Cable Industries, Inc., Willimantic, Connecticut, USA | |
| J. Baer | Superior Telecommunications Inc., Atlanta, Georgia, USA | |
| T.S. Bhat | Rockbestos-Surprenant Cable Corporation, East Granby, Connecticut, USA | |
| R. Blair | Draka Cableteq USA, North Dighton, Massachusetts, USA | |
| R. Bright | AmerCable, Inc., Houston, Texas, USA | |
| M. Cadorette | Produits Shell Canada Limitée, Montréal, Québec | |
| J.R. Cancelosi | The Okonite Company, Ramsey, New Jersey, USA | |
| W.F. Constantine | Draka Cableteq USA, North Dighton, Massachusetts, USA | |
| T. Corder | Underwriters Laboratories Inc., Research Triangle Park, North Carolina, USA | |
| C. Davis | Electro Cables Incorporated, Trenton, Ontario | |
| G. Davis | Electro Cables Incorporated, Trenton, Ontario | |
| G.L. Dorna | Belden Wire & Cable Company, Engineering Center, Richmond, Indiana, USA | |
| R. Duquet | Harbour Industries (Canada) Limited, Farnham, Québec | |

| | |
|-----------------------|---|
| J. Eby | Eby Energy Products, Inc., Missouri City, Texas, USA |
| T. Guida | Underwriters Laboratories Inc., Melville, New York, USA |
| B. Harmer | CSA International, Toronto, Ontario |
| J. Johnson | Electro Cables Incorporated, Trenton, Ontario |
| D.B. Kiddoo | AlphaGary Corporation, Leominster, Massachusetts, USA |
| J.F. Kirby | Transport Canada Marine Safety, Ottawa, Ontario |
| C. Lemay | Prysmian Power Cables and Systems Canada Ltd., Saint-Jean-sur-Richelieu, Québec |
| Y.C. Li | The Corporation of the Town of Markham, Markham, Ontario |
| J.A. Lynch | Transport Canada Marine Safety, Ottawa, Ontario |
| B. Milau | Underwriters Laboratories Inc., Melville, New York, USA |
| N. Moubed | Anixter Canada Inc., Mississauga, Ontario |
| B.F. O'Connell | Tyco Thermal Controls (Canada) Ltd., Trenton, Ontario |
| R. Pawluk | United Wire & Cable Incorporated, Richmond Hill, Ontario |
| D.E. Popoff | Marine Industrial Cable Corp., New Orleans, Louisiana, USA |
| D.S. Reith | Nexans Canada Inc., Markham, Ontario |
| A. Roland | General Cable Industries, Inc., Highland Heights, Kentucky, USA |
| V. Rowe | Westbank, British Columbia |
| T. Rudd | Belden (Canada) Inc., Cobourg, Ontario |
| J.A. Ruggieri | General Machine Corp., Fairfax Station, Virginia, USA |

| | | |
|-----------------------|---|------------------------|
| G. Shoshani | Rockbestos-Surprenant Cable Corporation, East Granby, Connecticut, USA | |
| A.Z. Tsisserev | City of Vancouver, Vancouver, British Columbia | |
| J. Turner | Swansea Consulting, Toronto, Ontario | |
| D. Verhage | Domtech Inc., Trenton, Ontario | |
| J.H. Walling | Beaconsfield, Québec | |
| J. Willner | Bolton, Ontario | |
| B. Woodrow | Hamilton, Ontario | |
| L. Letea | Canadian Standards Association, Mississauga, Ontario | <i>Project Manager</i> |

Preface

This is the third edition of CSA C22.2 No. 239, *Control and instrumentation cables*, one of a series of Standards issued under the *Canadian Electrical Code, Part II*. It supersedes the previous editions, published in 1997 and 1991.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Integrated Committee on Control, Instrument, Communication, and Marine Cables, under the jurisdiction of the Technical Committee on Wiring Products and the Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the Technical Committee.

Interpretations: The Strategic Steering Committee on Requirements for Electrical Safety has provided the following direction for the interpretation of standards under its jurisdiction: "The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA's procedures for interpretation shall be followed to determine the intended safety principle".

November 2009

Notes:

- (1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- (2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- (3) *This publication was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as "substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity". It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.*
- (4) *CSA Standards are subject to periodic review, and suggestions for their improvement will be referred to the appropriate committee.*
- (5) *All enquiries regarding this Standard, including requests for interpretation, should be addressed to Canadian Standards Association, 5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6.*
 - Requests for interpretation should*
 - (a) define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - (b) provide an explanation of circumstances surrounding the actual field condition; and*
 - (c) be phrased where possible to permit a specific "yes" or "no" answer.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are published in CSA's periodical Info Update, which is available on the CSA Web site at www.csa.ca.

C22.2 No. 239-09

Control and instrumentation cables

1 Scope

1.1

This Standard applies to multiple-conductor control and instrumentation cables (including thermocouple cables and thermocouple extension cables) having a voltage rating not exceeding 1000 V and intended for installation in accordance with the *Canadian Electrical Code, Part I*.

Note: *The designations for such cables are "CIC" for unarmoured cables and "ACIC" for armoured cables.*

1.2

This Standard applies to cables rated 1000 V, 600 V, 300 V, and 150 V, and to temperature ratings up to 105 °C. This Standard also includes specific requirements for high-temperature control and instrumentation cables rated 125 to 250 °C.

1.3

This Standard applies to multiple-conductor thermoplastic or thermoset-insulated assemblies, shielded or unshielded, twisted or cabled, paired or grouped into units, jacketed or unjacketed, sheathed or unsheathed, armoured or unarmoured, and any combinations thereof.

1.4

This Standard includes specific requirements for halogen-free limited-smoke control and instrumentation cables.

1.5

This Standard permits the inclusion of additional components, such as optical fiber members and communications wire used for installation purposes only. No requirements for such components are specified.

1.6

This Standard does not apply to cables intended for internal wiring of electrical equipment, e.g., switchboard and equipment wire, or to cables that undergo repeated flexing.

1.7

In CSA Standards, "shall" is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; "should" is used to express a recommendation or that which is advised but not required; and "may" is used to express an option or that which is permissible within the limits of the standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.