

Low-voltage fuses — Part 10: Class L fuses



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Update No. 1

C22.2 No. 248.10-11

January 2017

Note: For information about the **Standards Update Service**, go to **shop.csa.ca** or e-mail **techsupport@csagroup.org**.

Title: *Low-Voltage Fuses — Part 10: Class L Fuses* — originally published May 2011

The following revisions have been formally approved and are marked by a vertical line in the margin on the attached replacement pages:

Revised	Title page, copyright page, and Clause 1
New	None
Deleted	None

- Update your copy by inserting these revised pages.
- Keep the pages you remove for reference.



Association of Standardization and Certification
NMX-J-009/248/10-ANCE
Second Edition



Canadian Standards Association
CSA C22.2 No. 248.10-11
Third Edition



Underwriters Laboratories Inc.
UL 248-10
Third Edition

Low-Voltage Fuses – Part 10: Class L Fuses

May 13, 2011

(Title Page Reprinted: January 13, 2017)



ANSI/UL 248-10-2011 (R2015)

Commitment for Amendments

This standard is issued jointly by the Association of Standardization and Certification (ANCE), the Canadian Standards Association (operating as "CSA Group"), and Underwriters Laboratories Inc. (UL). Comments or proposals for revisions on any part of the standard may be submitted to ANCE, CSA Group, or UL at anytime. Revisions to this standard will be made only after processing according to the standards development procedures of ANCE, CSA Group, and UL. CSA Group and UL will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue. ANCE will incorporate the same revisions into a new edition of the standard bearing the same date of issue as the CSA Group and UL pages.

Copyright © 2017

Rights reserved in favor of ANCE.

ISBN 978-1-55491-640-5 © 2017 CSA Group

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

CSA Standards are subject to periodic review, and suggestions for their improvement will be referred to the appropriate committee. To submit a proposal for change to CSA Standards, please send the following information to inquires@csa.ca and include "Proposal for change" in the subject line: Standard designation (number); relevant clause, table, and/or figure number; wording of the proposed change; and rationale for the change.

To purchase CSA Standards and related publications, visit CSA's Online Store at www.ShopCSA.ca or call toll-free 1-800-463-6727 or 416-747-4044.

Copyright © 2017 Underwriters Laboratories Inc.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

This ANSI/UL Standard for Safety consists of the Third Edition including revisions through August 18, 2015. The most recent designation of ANSI/UL 248-10 as an American National Standard (ANSI) occurred on August 18, 2015. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

To purchase UL Standards, visit Comm 2000 at <http://www.comm-2000.com/HowToOrder.aspx> or call toll-free 1-888-853-3503.

CONTENTS

Preface	4
1 General	5
1.1 Scope	5
4 Classification	5
5 Characteristics	5
5.2 Voltage rating	5
5.3 Current rating	5
5.5 Interrupting rating	5
5.6 Peak let-through current and clearing I^2t characteristics	7
6 Marking	8
7 Construction	8
7.1 Dimensions	8
7.2 Current-carrying parts	8
8 Tests	10
8.2 Verification of temperature rise and current-carrying capacity	10
8.3 Verification of overload operation	11
8.4 Verification of operation at rated voltage	11
8.5 Verification of peak let-through current and clearing I^2t characteristics	12

Preface

This is the harmonized ANCE, CSA, and UL standard for Low-Voltage Fuses – Part 10: Class L Fuses. It is the second edition of NMX-J-009/248/10-ANCE, the third edition of CSA C22.2 No. 248.10-11, and the third edition of UL 248-10. This edition of NMX-J-009-248/10-ANCE cancels the previous edition published in 2000. This edition of CSA C22.2 No. 248.10-11 supersedes the previous edition published in 2000.

This harmonized standard was prepared by the Association of Standardization and Certification (ANCE), the Canadian Standards Association (CSA), and Underwriters Laboratories Inc., (UL).

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

The present Mexican Standard was developed by the CT 32 from the Comité de Normalización de la Asociación de Normalización y Certificación, A.C., CONANCE, with the collaboration of the fuse manufacturers and users.

This standard was reviewed by the CSA Subcommittee on Fuses and Fuseholders, under the jurisdiction of the CSA Technical Committee on Industrial Products and the CSA Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the CSA Technical Committee.

This standard has been approved by the American National Standards Institute (ANSI) as an American National Standard.

A UL standard is current only if it incorporates the most recently adopted revisions, all of which are itemized on the transmittal notice that accompanies the latest set of revised requirements.

Where reference is made to a specific number of samples to be tested, the specified number is to be considered a minimum quantity.

Note: Although the intended primary application of this standard is stated in its scope, it is important to note that it remains the responsibility of the user of the standard to judge its suitability for their particular purpose.

Level of Harmonization

This standard is published as an identical standard for ANCE, CSA, and UL. An identical standard is a standard that is exactly the same in technical content except for national differences resulting from conflicts in codes and governmental regulations. Presentation is word for word except for editorial changes.

Interpretations

The interpretation by the standards development organization of an identical or equivalent standard is based on the literal text to determine compliance with the standard in accordance with the procedural rules of the standards development organization. If more than one interpretation of the literal text has been identified, a revision is to be proposed as soon as possible to each of the standards development organizations to more accurately reflect the intent.

Low-Voltage Fuses – Part 10: Class L Fuses

1 General

NOTE –

This Part is intended to be read together with the Standard for Low-Voltage Fuses – Part 1: General Requirements, hereafter referred to as Part 1. The numbering of the clauses in this Part corresponds to like numbered Clauses in Part 1. The requirements of Part 1 apply unless modified by this Part. For Clauses not shown below, refer to the Standard for Low-Voltage Fuses – Part 1: General Requirements, NMX-J-009/248/1-ANCE ♦ CSA C22.2 No. 248.1-11 ♦ UL 248-1.

1.1 Scope

This Part applies to Class L fuses rated 100 – 6000 A and 600 V ac. DC ratings are optional.

4 Classification

Class L fuses are non-renewable, current-limiting bolt-in type with an interrupting rating of 200,000 A, or at the manufacturer's option 300,000 A. Class L fuses are divided into nine body sizes with the maximum current rating I_n for each size specified in this part. Time-delay ratings are optional.

5 Characteristics

5.2 Voltage rating

For AC, the rating shall be 600 V ac.

The DC voltage rating may be different from the AC rating.

5.3 Current rating

Refer to Figure A for the range of current ratings in each body size.

5.5 Interrupting rating

For AC, 200,000 A or 300,000 A at the manufacturer's option (300,000 A not applicable in Mexico).

For DC, the preferred ratings are 20,000, 50,000, 100,000, 150,000, 200,000, or 300,000 A.