

**Medium-voltage AC contactors,
controllers, and control centres**



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

*CSA C22.2 No. 253:20
November 2020*

Title: *Medium-voltage AC contactors, controllers, and control centres*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **24277-2**

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.



Association of Standardization and Certification
NMX-J-564/106-ANCE
Third Edition



CSA Group
CSA C22.2 No. 253:20
Third Edition



Underwriters Laboratories Inc.
UL 347
Seventh Edition

Medium-Voltage AC Contactors, Controllers, and Control Centers

November 23, 2020



ANSI/UL 347-2020

Commitment for Amendments

This standard is issued jointly by the Association of Standardization and Certification (ANCE), the Canadian Standards Association (operating as "CSA Group"), and Underwriters Laboratories Inc. (UL). Comments or proposals for revisions on any part of the standard may be submitted to ANCE, CSA Group, or UL at anytime. Revisions to this standard will be made only after processing according to the standards development procedures of ANCE, CSA Group, and UL. CSA Group and UL will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue. ANCE will incorporate the same revisions into a new edition of the standard bearing the same date of issue as the CSA Group and UL pages.

Copyright © 2020 ANCE

Rights reserved in favor of ANCE.

ISBN 978-1-4883-2407-9 © 2020 Canadian Standards Association

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

This Standard is subject to review within five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include "Proposal for change" in the subject line: Standard designation (number); relevant clause, table and/or figure number; wording of the proposed change; and rationale for the change.

To purchase CSA Group Standards and related publications, visit CSA Group's Online Store at store.csagroup.org or call toll-free 1-800-463-6727 or 416-777-4044.

Copyright © 2020 Underwriters Laboratories Inc.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

This ANSI/UL Standard for Safety consists of the Seventh Edition.

The most recent designation of ANSI/UL 347-2020 as an American National Standard (ANSI) occurred on November 23, 2020. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

To purchase UL Standards, visit UL's Standards Sales Site at <http://www.shopulstandards.com/HowToOrder.aspx> or call toll-free 1-888-853-3503.

CONTENTS

Preface	7
1 General	9
1.1 Scope and object	9
1.2 Normative references, component standards, and general requirements	9
2 Normal and Special Service Conditions	10
2.1 Normal service conditions	10
2.2 Special service conditions	10
3 Definitions	11
3.1 General terms	11
3.2 Assemblies of controlgear	13
3.3 Parts of assemblies	13
3.4 Switching devices	13
3.5 Parts of a controller	15
3.6 Operation	16
3.7 Characteristic quantities	17
3.101 Fuses	20
3.201 Medium-voltage fuse	21
3.202 Index of definitions	21
4 Controller and Control Center Ratings and Characteristics	25
4.1 Rated maximum voltage (U_r)	25
4.2 Rated insulation level (U_d), (U_p)	25
4.3 Rated frequency (f_r)	26
4.4 Rated continuous current and temperature rise	26
4.5 Rated short-time withstand current (I_k)	26
4.6 Rated peak and momentary withstand current	27
4.7 Rated duration of short-circuit (t_k)	27
4.8 Rated supply voltage of operating devices and of auxiliary and control circuits (U_a)	28
4.9 Rated supply frequency of closing and opening devices and of control circuits	28
4.10 Rated pressure of compressed gas supply for installation and/or operation	28
4.101 Rated operational current and rated operational power (I_e)	28
4.102 Rated duties	28
4.103 Rated making and breaking capacities	28
4.104 Utilization category	28
4.105 Mechanical endurance (standard and optional)	29
4.106 Electrical endurance	29
4.107 Coordination with medium-voltage fuses	29
4.108 Types and characteristics of automatic change-over devices and automatic acceleration control devices	29
4.109 Types and characteristics of autotransformers or reactors	29
4.110 Types and characteristics of the starting resistors for rheostatic motor starters	30
4.111 Characteristics dependent on starter type	30
4.112 Rated capacitive switching currents	30
4.201 Characteristics of Class E2 controllers	31
4.202 Fault-interrupting rating	31
4.203 Control center short-circuit rating	31
4.204 Starting duty of reduced-voltage starters	32
4.205 Duty rating for solid state resistive load controllers	33
5 Design and Construction	33
5.1 Requirements for liquids	33
5.2 Requirements for gases	33
5.3 Provisions for protective grounding	33
5.4 Auxiliary and control equipment	35

5.5	Dependent power operation	35
5.6	Stored energy operation.....	35
5.7	Independent manual operation	35
5.8	Operation of releases.....	35
5.9	Low- and high-pressure interlocking and monitoring devices	35
5.10	Markings.....	35
5.11	Interlocks	41
5.12	Position indication.....	42
5.13	Degrees of protection (optional)	43
5.14	Spacings.....	43
5.15	Gas and vacuum tightness	44
5.16	Liquid tightness	44
5.17	Flammability	44
5.18	Electromagnetic compatibility	44
5.19	X-ray emission	45
5.101	Types of relay or release	45
5.102	Enclosures	45
5.201	Latched controllers.....	48
5.202	Power circuit isolating means.....	48
5.203	Equipment protection	50
5.204	Service equipment.....	51
5.205	Internal wiring.....	55
5.206	Terminals and connections	57
5.207	Bus bar connections.....	58
5.208	Connector and grounding kits	58
5.209	Insulating material.....	58
5.210	Wire-bending space for field-installed conductors.....	58
5.211	Field-installed accessories (kits).....	59
5.212	Blank spaces, provision for future controllers, and spare controllers.....	59
5.213	Insulated bus (optional).....	60
5.214	Controllers – general requirements.....	60
6	Type Tests	60
6.1	General	60
6.2	Dielectric tests.....	61
6.3	Radio interference voltage (RIV) test.....	64
6.4	Resistance measurement.....	65
6.5	Temperature-rise tests	66
6.6	Short-time, momentary, and peak withstand current bus tests	71
6.101	Mechanical tests.....	73
6.102	Make and break capacity.....	74
6.103	Overload test.....	76
6.104	Fault interruption test	78
6.105	Verification of operating limits and characteristics of overload relays	82
6.106	Verification of coordination with SCPDs	83
6.107	Electrical endurance tests.....	83
6.108	Motor switching tests.....	83
6.109	Capacitive current switching tests	83
6.201	Switching capacity test – isolating means	85
6.202	Short-time capability	86
6.203	Driven rain test	88
6.204	Mechanical tests of viewing panes	89
6.205	Enclosure ground integrity test.....	89
6.206	Shutter integrity test.....	89
6.207	Rod entry test	89
6.208	Operation tests for all solid state controllers	90
7	Routine Tests.....	91

7.1	Power-frequency voltage withstand test on the main circuit.....	91
7.2	Power-frequency voltage withstand test on auxiliary and control circuits	92
7.3	Measurement of the resistance of the main circuit	92
7.4	Tightness test (vacuum integrity test)	92
7.5	Design and visual checks	92
7.101	Operating tests	92
7.102	Tests dependent on controller type	93
7.201	Routine tests – general.....	93
TABLES		94
FIGURES		100

Annex A (Normative) – References

Annex B – (Reserved)

Annex C (Informative) – Markings required to be translated and suggested French and Spanish translations

Annex D (Informative) – Standards for components

Annex E (Normative) – Voltage Dividers Used in Medium Voltage Controllers

E1	Scope	119
E2	Definitions	119
E3	Construction	119
E4	Performance.....	120
E4.2	Dielectric withstand test	120

No Text on This Page

Currently in preview, click buy full version

Preface

This is the harmonized ANCE, CSA Group, and UL standard for medium-voltage ac contactors, controllers, and control centres. It is the third edition of NMX-J-564/106-ANCE, the third edition of CSA C22.2 No. 253:20, and the seventh edition of UL 347. This edition of NMX-J-564/106-ANCE supersedes the previous edition published on January 2016. This edition of CSA C22.2 No. 253 supersedes the previous edition published on January 2016. This edition of UL 347 supersedes the previous edition published on January 29, 2016.

This harmonized Standard was prepared by the Association of Standardization and Certification (ANCE), CSA Group and Underwriters Laboratories Inc. The efforts and support of the medium-voltage control manufacturing industry and the CANENA Technical Harmonization Subcommittee THSC TC17, VGT – Medium Voltage Controllers, which includes representatives of UL, CSA Group, ANCE and North American medium voltage control manufacturers, are gratefully acknowledged.

This standard is considered suitable for use for conformity assessment within the stated scope of the standard.

The present Mexican Standard was developed by the CT GTD – Generación, Transmisión y Distribución from the Comité de Normalización de la Asociación de Normalización y Certificación, A.C., CONANCE, with the collaboration of the medium-voltage controller manufacturers and users.

This Standard was reviewed by the CSA Integrated Committee on Industrial Control, under the jurisdiction of the CSA Technical Committee on Industrial Products and the CSA Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the CSA Technical Committee.

Application of Standard

Where reference is made to a specific number of samples to be tested, the specified number is to be considered a minimum quantity.

Note: Although the intended primary application of this standard is stated in its scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

Level of harmonization

This Standard was prepared by comparing UL 347, existing CSA Group standards, and ANCE and IEC 60470-2000 requirements. These requirements were reviewed, compared, and, where possible, harmonized. Where harmonization was not possible due to local installation codes, the differing requirements are noted in the text of the document. When conflicts between existing North American and IEC practices existed, the practice in North America is retained.

This Standard is published as an equivalent standard for ANCE, CSA Group, and UL.

An equivalent standard is a standard that is substantially the same in technical content, except as follows: Technical national differences are allowed for codes and governmental regulations as well as those recognized as being in accordance with NAFTA Article 905, for example, because of fundamental climatic, geographical, technological, or infrastructural factors, scientific justification, or the level of protection that the country considers appropriate. Presentation is word for word except for editorial changes.

Formatting

This Standard is formatted to facilitate comparison to IEC 60470 requirements, and to IEC 60694, which is the common clauses document to which IEC 60470 is subservient. Requirements are categorized and

arranged in the clause numbering structure currently used for IEC 60470. Where the requirements in this Standard are equivalent to those in IEC 60470, the subclause is assigned the equivalent IEC subclause number. Where this Standard does not include a subclause equivalent to those in IEC 60470, the entry "[Vacant]" is shown for the IEC 60470 subclause number. Where this Standard includes a requirement not shown in IEC 60470, the subclause is assigned a number of a higher numerical value than those used in the IEC document.

In order to simplify the cross-referencing of corresponding requirements, the following clause numbering system is used:

- The clauses follow the IEC 60470 (and IEC 60694) format for clauses 1 through 7.
- Subclauses numbered .1 through .99 (but not subdivisions, e.g., those numbered .1.1, .1.2, .1.3, etc.) correspond to subclauses in IEC 60470 (and IEC 60694).
- Subclauses numbered .101 through .199 correspond to subclauses in IEC 60470.
- Subclauses numbered .201 through .299 are CANENA requirements not found or numbered in IEC 60470.

The purpose of this Standard is to harmonize as far as practicable all rules and requirements of a general nature in order to obtain uniformity of requirements and tests throughout the corresponding range of equipment and to avoid the need for testing to different standards.

Interpretations

The interpretation by the standards development organization of an identical or equivalent standard is based on the literal text to determine compliance with the standard in accordance with the procedural rules of the standards development organization. If more than one interpretation of the literal text has been identified, a revision is to be proposed as soon as possible to each of the standards development organizations to more accurately reflect the intent.

MEDIUM-VOLTAGE AC CONTACTORS, CONTROLLERS, AND CONTROL CENTERS

1 General

1.1 Scope and object

This standard is applicable to ac contactors applied at voltages in the range of 1 501V to 15kV, and metal-enclosed contactor-based controllers, control centers, and other control assemblies and associated equipment applied at voltages in the range of 751V to 15kV, designed for operation at frequencies of 50 or 60 Hz on three-phase systems. These requirements cover equipment intended for use in ordinary (non-hazardous) locations and installed in accordance with the applicable local installation codes and standards (see Annex [A](#), Item 1). These requirements, as modified by the applicable national standards for fire pump controllers, also cover fire pump controllers (see Annex [A](#), Item 2).

This standard also includes requirements for controllers intended for service entrance applications. (See [5.204](#) and Annex [A](#), Item 3.)

This standard also includes requirements for equipment incorporating solid state switching elements intended for starting, stopping, regulating, controlling, or protecting heating and other resistive loads, having ac voltage ratings in the range of 1 501V to 15kV.

This standard does not cover:

- a) equipment for use in classified (hazardous) locations as defined in the applicable installation codes or standards;
- b) components contained in contactors and contactor-based controllers for which individual component standards exist; and
- c) auxiliary low voltage control assemblies (see Annex [A](#), Item 4).

This standard also includes requirements for reduced-voltage solid state controllers. It does not, however, cover equipment consisting solely of electronic or solid state devices, circuits, or systems, nor does it cover electronic variable speed motor controllers (power conversion equipment). This standard does not cover controllers using only solid state devices in the main circuit.

1.2 Normative references, component standards, and general requirements

1.2.1 General

Products covered by this standard shall comply with the reference installation codes and standards noted in Annex [A](#).

For undated references to standards, such reference shall be considered to refer to the latest edition and all revisions to that edition up to the time when this standard was approved. For dated references to standards, such reference shall be considered to refer to the dated edition and all revisions published to that edition up to the time the standard was approved.