



CSA C22.2 No. 62091:20
Low-voltage switchgear and controlgear — Controllers for
drivers of stationary fire pumps
(IEC 62091:2007, MOD)



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA C22.2 No. 62091:20
September 2020

Title: *Low-voltage switchgear and controlgear — Controllers for drivers of stationary fire pumps*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **127 72**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada’s economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada



Standards Council of Canada
Conseil canadien des normes

Cette Norme Nationale du Canada est disponible en versions française et anglaise.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

**A trademark of the Canadian Standards Association, operating as “CSA Group”*

National Standard of Canada

CSA C22.2 No. 62091:20

***Low-voltage switchgear and controlgear —
Controllers for drivers of stationary fire pumps
(IEC 62091:2007, MOD)***

Note: For brevity, this Standard will be referred to as “CSA C22.2 No. 62091” throughout.

SEPTEMBER 30, 2020

This national standard is based on publication IEC 62091, First Edition (2007).

*Prepared by
International Electrotechnical Commission*



Reviewed by



Association of Standardization
and Certification
NMX-J-XXXX
First Edition



CSA Group
CSA C22.2 No. 62091:20
First Edition
(IEC 62091:2007, MOD)



Underwriters Laboratories Inc.
UL 62091
First Edition

ICS 29.130.10



ANSI/UL 62091-2020

Commitment for Amendments

This standard is issued jointly by the Association of Standardization and Certification (ANCE), the Canadian Standards Association (operating as "CSA Group"), and Underwriters Laboratories Inc. (UL). Comments or proposals for revisions on any part of the standard may be submitted to ANCE, CSA Group, or UL at anytime. Revisions to this standard will be made only after processing according to the standards development procedures of ANCE, CSA Group, and UL. CSA Group and UL will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue. ANCE will incorporate the same revisions into a new edition of the standard bearing the same date of issue as the CSA Group and UL pages.

Copyright © 2020 ANCE

Rights reserved in favor of ANCE.

ISBN 978-1-4883-2121-4 © 2020 Canadian Standards Association

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

This Standard is subject to review within five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. The technical content of IEC and ISO publications is kept under constant review by IEC and ISO. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include "Proposal for change" in the subject line: Standard designation (number); relevant clause, table, and/or figure number; wording of the proposed change; and rationale for the change.

To purchase CSA Group Standards and related publications, visit CSA Group's Online Store at store.csagroup.org or call toll-free 1-800-463-6727 or 416-777-4444.

Copyright © 2020 Underwriters Laboratories Inc.

UL's Standards for Safety are copyrighted by UL. Neither printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

This ANSI/UL Standard for Safety consists of the First Edition.

The most recent designation of ANSI/UL 62091 as an American National Standard (ANSI) occurred on September 30, 2020. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface. The National Difference Page and IEC Foreword are also excluded from the ANSI approval of IEC-based standards. Any other portions of this ANSI/UL standard that were not processed in accordance with ANSI/UL requirements are noted at the beginning of the impacted sections.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

To purchase UL Standards, visit UL's Standards Sales Site at <http://www.shopulstandards.com/HowToOrder.aspx> or call toll-free 1-888-853-3503.

CONTENTS

PREFACE	7
NATIONAL DIFFERENCES	9
FOREWORD	11
INTRODUCTION	13
1 Scope and object	15
1DV Modification to Clause 1 by adding the following:	16
2 Normative references	16
2DV Modification to Clause 2 by adding the following:	18
3 Terms and definitions	18
3.36DV Add the following:	23
4 Classification	26
4.1 Electric fire pump controller	26
4.2 Residential fire pump controller (pump driven by an electric motor only)	26
4.3 Diesel engine fire pump controller	26
4.4 Foam pump controller (pump driven either by an electric motor or by a diesel engine)	26
5 Characteristics	27
5.1 Electrical quantities	27
5.2 Hierarchy of importance for the various characteristics	27
5.3 Electric fire pump controller	28
5.4 Residential fire pump controller	28
5.5 Diesel engine fire pump controller	29
5.6 Foam pump controller	29
5.7 Fire pump controller test protocol	30
6 Product information	30
6.1 Rated values and other electrical characteristics	30
6.2 Marking	31
6.3 Instructions for installation, operation and maintenance	37
7 Normal service, mounting and transport conditions	37
7.1 General	37
7.2 Water temperature	38
7.3 Humidity	38
7.4 Degrees of pollution	38
7.5 EMC considerations	38
7.5DV Modification to 7.5 by replacing the first paragraph with the following:	38
8 Constructional, functional and performance requirements	38
8.1 General	38
8.1DV Modification to 8.1 by adding the following:	39
8.2 Constructional requirements for the type-tested devices	39
8.3 Priority of operations for electric fire pump controllers	47
8.4 Functional and performance requirements for components	48
8.5 Priority of operations for electric fire pump controllers	57
8.6 Functional and performance requirements for electric controllers	58
8.6.11DV Addition of the following to Clause 8.6:	68
8.7 Residential fire pump controllers	69
8.8 Diesel engine fire pump controllers	71
8.9 Automatic operation of a diesel engine drive controller – pressure-actuated	77
8.10 Automatic operation of a diesel engine drive controller – non-pressure-actuated	78
8.11 Methods of stopping diesel engine fire pump controllers	78
8.12 Testing of diesel engine fire pump controllers	80

8.13	Additional functional and performance requirements for foam pump controllers	80
8.14	EMC requirements	82
9	Tests	83
9.1	Kinds of test	83
9.2	Compliance with construction requirements	84
9.3	Compliance with performance requirements	84
9.4	EMC tests	99
9.5	Routine tests	101
	Table 7DV Addition:	104
	Table 8DV Addition:	105
	Table 9DV Addition:	107
	Table 10DV Addition:	109
	Table 11DV Addition:	109
	Table 12DV Addition:	111
	Table 13DV Addition:	111
	Table 14DV Addition:	112
	Table 15DV Addition:	113
	Table 16DV Addition:	114
	Table 17DV Addition:	115
	Table 18DV Addition:	116
	Table 19DV Addition:	116
	Table 20DV Addition:	117
	Table 21DV Addition:	117
	Table 22DV Addition:	119
	Table 23DV Addition:	120
	Table 24DV Addition:	120
	Table 25DV Addition:	121
	Figure 6DV Addition:	129
	Figure 7DV Addition:	130
	Figure 8DV Addition:	131
	Figure 9DV Addition:	132

Annex A (informative) Informative materials

Annex ADV	Modification to Annex A as follows:	134
-----------	---	-----

Annex DVA (normative) References

Annex DVA	Add Annex DVA as follows:	135
-----------	---------------------------------	-----

Annex DVB (normative) Standards for components

Annex DVB	Add Annex DVB as follows:	138
-----------	---------------------------------	-----

Annex DVC (informative) French and Spanish translations and markings

Annex DVC	Add Annex DVC as follows:	142
-----------	---------------------------------	-----

Annex DVD (informative) Test samples

Annex DVD	Add Annex DVD as follows:	143
-----------	---------------------------------	-----

Annex DVE (normative) Additional Requirements for use in Canada, Mexico and the United States

Annex DVE Add Annex DVE as follows:..... 144

Bibliography

Currently in preview, click buy full versi

No Text on This Page

Currently in preview, click buy full version

PREFACE

This is the harmonized ANCE, CSA Group, and UL Standard for Low-Voltage Switchgear and Controlgear – Controllers for Drivers of Stationary Fire Pumps. It is the First edition of NMX-J-XXXX, CSA C22.2 No. 62091, and UL 62091.

This harmonized standard is based on IEC Publication 62091: First Edition, Low-voltage switchgear and controlgear – Controllers for drivers of stationary fire pumps, issued January 2007, and the requirements pertaining to fire pump controllers from the 2019 and past editions of NFPA 20, Standard for the Installation of Stationary Pumps for Fire Protection. This document is intended to replace NMX-J-626-ANCE-2015/UL 218/CSA C22.2 No. 263-15, published in September 2015, to provide globally accepted requirements for fire pump controllers. IEC 62091 is copyrighted by the IEC.

This harmonized standard was prepared by the Association of Standardization and Certification (ANCE), CSA Group, and Underwriters Laboratories Inc. (UL). The efforts and support of the Technical Harmonization Subcommittee, Fire Pump Controllers, CANENA THSC 121A-62091 on the Harmonization of Electrotechnical Standards of the Nations of the Americas (CANENA), are gratefully acknowledged.

This standard is considered suitable for use for conformity assessment within the stated scope of the standard.

The present Mexican Standard was reviewed and approved by the Comité de Normalización de la Asociación de Normalización y Certificación, A.C., CONANCE.

This standard was reviewed by the CSA Subcommittee on Fire Pump Controllers, under the jurisdiction of the CSA Technical Committee on Industrial Products and the CSA Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the CSA Technical Committee. This standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

Application of Standard

Where reference is made to a specific number of samples to be tested, the specified number is to be considered a minimum quantity.

Note: Although the intended primary application of this standard is stated in its scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

Level of Harmonization

This standard adopts the IEC text with national differences.

This standard is published as an equivalent standard for ANCE, CSA Group and UL.

An equivalent standard is a standard that is substantially the same in technical content, except as follows: Technical national differences are allowed for codes and governmental regulations as well as those recognized as being in accordance with NAFTA Article 905, for example, because of fundamental climatic, geographical, technological, or infrastructural factors, scientific justification, or the level of protection that the country considers appropriate. Presentation is word for word except for editorial changes.

All national differences from the IEC text are included in the ANCE, CSA Group, and UL versions of the standard. While the technical content is the same in each organization's version, the format and presentation may differ.

Reasons for Differences From IEC

Differences from the IEC are being added in order to address safety and regulatory situations present in Mexico, the US and Canada.

Interpretations

The interpretation by the standards development organization of an identical or equivalent standard is based on the literal text to determine compliance with the standard in accordance with the procedural rules of the standards development organization. If more than one interpretation of the literal text has been identified, a revision is to be proposed as soon as possible to each of the standards development organizations to more accurately reflect the intent.

IEC Copyright

For ANCE, the text, figures, and tables of International Electrotechnical Commission Publication 62091, *Low-voltage switchgear and controlgear – Controllers for drivers of stationary fire pumps*, issued 01-2007, are used in this Standard according to the guidelines provided in the ISO/IEC/POCOSA.

For CSA Group, the text, figures, and tables of International Electrotechnical Commission Publication 62091, *Low-voltage switchgear and controlgear – Controllers for drivers of stationary fire pumps*, copyright 2007, are used in this standard with the consent of the International Electrotechnical Commission. The IEC Foreword and Introduction are not a part of the requirements of this standard but are included for information purposes only.

These materials are subject to copyright claims of IEC and UL. No part of this publication may be reproduced in any form, including an electronic retrieval system, without the prior written permission of UL. All requests pertaining to the Standard for Low-Voltage Switchgear and Controlgear – Controllers for Drivers of Stationary Fire Pumps, UL 62091, should be submitted to UL.

NATIONAL DIFFERENCES

National Differences from the text of International Electrotechnical Commission (IEC) Publication 62091, Low-voltage switchgear and controlgear – Controllers for drivers of stationary fire pumps, copyright 2007, are indicated by notations (differences) and are presented in bold text. The national difference type is included in the body.

There are five types of National Differences as noted below. The difference type is noted on the first line of the National Difference in the standard. The standard may not include all types of these National Differences.

DR – These are National Differences based on the **national regulatory requirements**.

D1 – These are National Differences which are based on **basic safety principles and requirements**, elimination of which would compromise safety for consumers and users of products.

D2 – These are National Differences from IEC requirements based on existing **safety practices**. These requirements reflect national safety practices, where empirical substantiation (for the IEC or national requirement) is not available or the text has not been included in the IEC standard.

DC – These are National Differences based on the **component standards** and will not be deleted until a particular component standard is harmonized with the IEC component standard.

DE – These are National Differences based on **editorial comments or corrections**.

Each national difference contains a description of what the national difference entails. Typically one of the following words is used to explain how the text of the national difference is to be applied to the base IEC text:

Addition / Add - An addition entails adding a complete new numbered clause, subclause, table, figure, or annex. Addition is not meant to include adding select words to the base IEC text.

Modification / Modify - A modification is an altering of the existing base IEC text such as the addition, replacement or deletion of certain words or the replacement of an entire clause, subclause, table, figure, or annex of the base IEC text.

Deletion / Delete - A deletion entails complete deletion of an entire numbered clause, subclause, table, figure, or annex without any replacement text.

No Text on This Page

FOREWORD

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR – CONTROLLERS FOR DRIVERS OF STATIONARY FIRE PUMPS

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.

2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.

3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.

4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.

5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.

6) All users should ensure that they have the latest edition of this publication.

7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.

8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62091 has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

This first edition cancels and replaces the technical specification published in 2003. It constitutes a technical revision and now has the status of an International Standard.

The text of this standard is based on the following documents:

FDIS	Report on voting
17B/1527/FDIS	17B/1536/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

IEC 62091 pertains to life-safety equipment and is based in part on NFPA 20 (1996) *Standard for the Installation of Centrifugal Fire Pumps*. When called upon to work by automatic signal, manual-electric signal or manual-emergency actuation, the controller is expected to start the pump driver (motor or diesel engine) because “the building is on fire”. Failure to carry out its task will increase fire damage to the building, its contents and people therein.

These controllers default to a RUN state. They are intended to be located in compliance with local requirements which generally will place them in pump rooms or pump houses that have some specified degree of fire protection. These locations often have sweating overhead pipes, are possibly sprinklered and are in the vicinity of vaults housing other building distribution equipment.

Fire pumps are intended to boost water pressure. Many sprinkler systems are assumed to have small leaks for which “Jockey Pumps” (also known as make-up pumps) are installed to maintain desired pressure in the sprinkler pipes, thus preventing the main fire pump from excessive starts and stops. Experience has shown that leakage water flowing through the fire pump (at rest) over long periods of pump inactivity can carry sand, aggregates, rocks, rust and such which collect in the fire pump. These contaminants may prevent normal starting until the pump impeller accelerates to clear the pump housing. This standard recognizes the condition of under-exercised fire pumps by permitting up to 20 s at locked rotor current, whether the starts are “cold starts” (initial starts) or “hot starts” (restarts). Starting a distressed pump may cause temporary or permanent damage to electrical conductors, equipment and the motor, because shutdown for equipment protection could possibly permit its destruction by fire along with the building and its contents.

Several examples of the construction and installation applications between a fire pump controller and other controllers include the following:

(1) all fire pump controllers

- a) The main circuit conductors and components are considered to be sacrificial (i.e. temporary and permanent damage levels are permitted) during any attempt to start a distressed motor/pump and to keep it operating.
- b) They are expected to provide a high degree of reliability to start the pump driver automatically and suppress a fire upon sensing a pressure drop in the sprinkler pipe or by other automatic fire detection equipment.
- c) Failures in external control circuits should not prevent operations of pumps from all other internal or other external means.
- d) External control circuits are expected to be arranged so that failure of any external circuit (open or short-circuit) will not prevent operation of pump(s) from all other internal or external means. Breakage, disconnecting, shorting of the wires or loss of power to these circuits can cause continuous running of the fire pump but should not prevent the controller(s) from starting the fire pump(s) due to causes other than these external circuits.
- e) External automatic starting means should be accomplished by opening a normally closed contact on the external means to de-energize a normally energized control circuit in the controller.
- f) While external start buttons or other starting means are permitted, the controller should not be equipped with any means to accommodate remote stopping (a remote STOP button should not be used).
- g) Nuisance starts are permitted in the case where a failure of internal control components might cause the motor to start running.

(2) electric motor fire pump controllers

- a) They are expected to include means for external, manual mechanical operation of the controller in the event of loss of ability to close the contactor electrically/magnetically.
- b) Thermally reactive over-current protective devices should not be permitted. The controller should provide short-circuit and locked rotor protection only.
- c) Releases of the FPC-overcurrent protective devices (short-circuit protective and locked rotor protective devices) are expected to permit it to carry 300 % of rated operational motor current for an extended period of time.

(3) diesel engine fire pump controllers

- a) Should provide means to automatically exercise the engine on a weekly basis.
- b) When an automatic or manual signal to start/run exists, (except under TEST) the controller should not shut down the engine for any reason except OVERSPEED. When in TEST mode, the controller may shut down under low oil pressure and high engine temperature conditions. The two conditions mentioned illustrate the sacrificial nature while fighting a fire.

Therefore, the most significant purpose of this standard is to characterize the unique features of fire pump controllers.

An installation with two fire pumps will increase the reliability and safety of the installation, especially if the two fire pumps are supplied from two different power supplies. This is especially true during maintenance or repairing of a single controller, as fire protection is still being maintained by the other fire pump.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR – CONTROLLERS FOR DRIVERS OF STATIONARY FIRE PUMPS

1 Scope and object

This International Standard applies to controllers intended for starting, controlling and stopping stationary fire pumps, including automatic and non-automatic types for alternating current electric motor or diesel engine-driven fire pumps. It is anticipated that a controller only controls a single driver.

Controllers for electric motor-driven fire pumps always include suitable short-circuit protection as an integral part of the controller. These controllers may include an integral power transfer switch. These controllers are rated 1 000 V a.c. maximum.

Controllers for diesel engine-driven fire pumps include electrical circuits that operate various control and supervisory functions, such as remote control (starting), alarms, signals, indicators, and the proper operation of battery chargers.

The most significant purpose of this standard is to characterize the unique features of fire pump controllers. A further purpose is to prescribe a procedure for exercising the controllers to verify that the unique features are operative. For the purpose of this standard, this procedure is described as the “fire pump controller test protocol”.

The object of this standard is to state the following:

- a) the unique characteristics of fire pump controllers, their associated equipment and their operational functions;
- b) the tests intended for confirming that these conditions have been met, and the methods to be adopted for these tests;
- c) the information to be given with the equipment, or in the manufacturer's literature.

In this context, this standard gives the requirements for all of the electrical functions associated with both the electric motor-driven and the diesel engine-driven fire pumps. Special applications such as explosive atmospheres, nuclear installations, ships, aircraft, etc. are not covered by this standard. Referring to electric power sources, the requirements of this standard apply only to the extent that they place limits on the nature, behaviour and characteristics of the electrical energy that is supplied to the service entrance (see IEC 60364-5-55).

The requirements of this standard apply neither to the method nor to the means by which the electrical energy is generated. In addition, they do not apply to the installation between the origin of the installation and the fire pump controller, which are to be found in the IEC 60364 series. This standard does not apply to diesel engine-driven electric generators which may be associated with a stationary fire pump installation.

EMC considerations are correlated with other IEC standards for similar products:

- a) for electric fire pump controllers, EMC considerations are covered by this standard, and
- b) for diesel engine fire pump controllers, d.c. batteries are the intended source of electrical control power.