



Three-phase, pad-mounted distribution transformers with separable insulated high-voltage connectors



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by treaty or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF form.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA C227.4:21
March 2021

Title: *Three-phase, pad-mounted distribution transformers with separable insulated high-voltage connectors*

To register for e-mail notification about any updates to this publication

- go to www.csagroup.org/store/
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **128 05**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada



Standards Council of Canada
Conseil canadien des normes

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada

Cette Norme Nationale du Canada n'est disponible qu'en anglais.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

**A trademark of the Canadian Standards Association, operating as “CSA Group”*

National Standard of Canada

CSA C227.4:21

***Three-phase, pad-mounted
distribution transformers with
separable insulated high-voltage
connectors***



*®A trademark of the Canadian Standards Association,
operating as "CSA Group."*



*Published in March 2021 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at www.csagroup.org/store/
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 29.020; 29.180; 29.080.10
ISBN 978-1-4883-3455-9*

*© 2021 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Technical Committee on Distribution Transformers	4
Subcommittee on Overhead and Pad-Mounted Distribution Transformers	7
Preface	10
1 Scope	12
2 Reference publications	13
3 Definitions and abbreviations	14
3.1 Definitions	14
3.2 Abbreviations	15
4 Electrical characteristics	16
4.1 kVA ratings	16
4.2 Electrical connection and designation	16
4.2.1 Voltage designation	16
4.2.2 Angular displacement	16
4.2.3 Core bonding	16
4.2.4 Standard high-voltage winding connection	16
4.2.5 GrdY-GrdY-connected transformers	16
4.3 Temperature rise	16
4.4 Loading capabilities	17
4.5 Off-circuit voltage taps	17
4.6 Rated voltages	17
4.6.1 High-voltage winding(s) ratings and required BIL ratings	17
4.6.2 Low-voltage winding(s) ratings and required BIL ratings	17
4.7 Operating voltage range	17
4.8 Radio interference	17
4.9 Audible sound	17
4.10 Short-circuit capability	18
4.10.1 General	18
4.10.2 Transformers with impedance greater than 4%	18
4.11 Impedance	18
4.12 Energy efficiency	18
5 Mechanical characteristics	18
5.1 General	18
5.1.1 Dimensions	18
5.1.2 Transformer tank	18
5.1.3 Lifting provisions	19
5.1.4 Jacking provision	19
5.1.5 Transformer base	19
5.1.6 Drain plugs, pressure-relief device, and liquid-level indicator	19
5.1.7 Accessibility of internal components	19
5.1.8 Transformer assembly	19

5.1.9	Off-circuit tap changer and voltage selector switch	19
5.1.10	Transformer accessories	19
5.1.11	Drip tray	19
5.1.12	Load-break switch	20
5.1.13	Liquid insulant	20
5.1.14	Radiators and transformer compartment	20
5.2	Cable entrance compartment	20
5.2.1	Compartment arrangement	20
5.2.2	Transformer integrity and locking provisions	21
5.2.3	Hinges	21
5.2.4	Sill	21
5.2.5	Internal flange	21
5.2.6	Doors and roof	21
5.3	Fusing	21
5.3.1	Two-fuse system	21
5.3.2	Fuse identification	22
5.3.3	Bayonet fuse label	22
6	Bushings, terminals, and grounding	22
6.1	Bushings and terminals	22
6.1.1	General	22
6.1.2	High-voltage bushings	23
6.1.3	Low-voltage bushings	23
6.2	Grounding	23
6.2.1	Grounding spade terminals	23
6.2.2	Grounding assembly	24
6.2.3	Neutral terminal	24
7	Tests	24
7.1	General	24
7.2	Routine tests	24
7.3	Tolerances for routine tests	25
7.3.1	Ratio	25
7.3.2	Losses and exciting current	25
7.3.3	Tolerance for impedance	25
7.4	Type tests	26
7.4.1	General	26
7.4.2	Standard type tests	26
7.5	Dielectric tests	26
7.5.1	General	26
7.5.2	Applied voltage test	26
7.5.3	Induced voltage test	26
7.5.4	Impulse strength tests	27
7.6	Temperature rise test	27
7.6.1	Method	27
7.6.2	Test conditions	27
7.7	Short-circuit tests	27
7.8	Transformer integrity test	27

8	Quality of work and finish	27
8.1	Finish performance	27
8.2	Colour	27
8.3	Welding	27
8.4	Dimensional tolerance	28
9	Markings	28
9.1	Nameplate and connection diagram	28
9.1.1	Combination nameplate	28
9.1.2	Location	28
9.1.3	Information on nameplate	28
9.2	Information plates	29
9.3	Terminal markings	29
9.4	Transformer markings	29
9.4.1	Label materials	29
9.4.2	Information on the inside of the transformer compartment	29
9.4.3	Warning labels	29
9.4.4	Information on exterior of the transformer	30
10	Optional items	30
11	Packaging	31
12	Quality management system	31

Annex A (normative)	— Distribution transformer warning labels	63
Annex B (informative)	— Commentary	68

Preface

This is the third edition of CSA C227.4, *Three-phase, pad-mounted distribution transformers with separable insulated high-voltage connectors*. It supersedes the previous editions published in 2006 and 1978.

The major changes in this edition include the following:

- a) expanded scope to include 34.5 kV system nominal voltage, and discontinued use of the terms “insulation class” and “preferred voltages”;
- b) updated references to other industry standards;
- c) clarified requirements with off-circuit voltage taps and added informative note on dual-voltage transformers with taps;
- d) added requirements to the optional load break switch ratings since previous IEEE references are obsolete;
- e) modified and clarified requirements with the two-fuse system, also removing tables with manufacturer specific part numbers;
- f) improved routine test requirements to better align with IEEE. For example, no-load losses and exciting current will be at 100% rated voltage instead of 105%;
- g) added no internal fuse warning markings;
- h) clarified and expanded additional optional items in Clause 10. For example, routine partial discharge testing has been added based on the experience and procedures of users;
- i) the continued inclusion of the electrical characteristics that apply to the transformers covered by this Standard, which were previously provided in CAN/CSA-C22.7 and
- j) added Clause B.5.3.1.1 to explain the removal of fusing tables.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Subcommittee on Overhead and Pad-Mounted Distribution Transformers, under the jurisdiction of the Technical Committee on Distribution Transformers and the Strategic Steering Committee on Power Engineering and Electromagnetic Compatibility, and has been formally approved by the Technical Committee.

This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

Notes:

- 1) Use of the singular does not exclude the plural (and vice versa) when the sense allows.
- 2) Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.
- 3) This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.
- 4) To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:
 - a) define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;
 - b) provide an explanation of circumstances surrounding the actual field condition; and
 - c) where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

- 5) This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include "Proposal for change" in the subject line:
- a) Standard designation (number);
 - b) relevant clause, table, and/or figure number;
 - c) wording of the proposed change; and
 - d) rationale for the change.

CSA C227.4:21

Three-phase, pad-mounted distribution transformers with separable insulated high-voltage connectors

1 Scope

1.1

This Standard specifies the requirements for three-phase, pad-mounted distribution transformers, consisting of a transformer and a cable entrance compartment with provision for separable insulated high-voltage connectors, intended primarily for operation by electric utilities on three-phase underground distribution systems having primary voltages as shown in Clause [4.6](#).

1.2

This Standard applies to three-phase, 60 Hz, pad-mounted, liquid-filled distribution transformers, rated at 3000 kVA or below, up to 34.5 kV system nominal voltage, and with separable insulated high-voltage connectors. The transformers are suitable for mounting outdoors on pads without additional protective enclosures.

1.3

This Standard includes voltage ratings, kVA ratings, certain mechanical characteristics, and test procedures. The Standard also includes the following performance characteristics: energy efficiency (in accordance with CAN/CSA-C802.1), temperature rise, loading capabilities, audible sound level, and radio influence voltage (RIV).

1.4

When this equipment is intended for operation by other than an electric utility, it is the purchaser's responsibility to ensure that the unit meets the requirements of the appropriate electrical inspection authority.

1.5

This Standard allows for the interchangeability of a dead-front, pad-mounted unit by another of the same basic physical size from a different manufacturer for transformers rated 125 kV BIL and below, without modifications to cables or pad. This Standard covers terminal arrangements for both radial and loop-feed systems, including certain minimum dimensions and certain specific dimensions.

1.6

In this Standard, "shall" is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the Standard; "should" is used to express a recommendation or that which is advised but not required; and "may" is used to express an option or that which is permissible within the limits of the Standard.